



Automatización Eléctrica

Especialistas en Automatización

At the end of this document you will find links to products related to this catalog. You can go directly to our shop by clicking [HERE](#)

General Information

| | |
|------------------------|--|
| Extended Product Type: | DDA202 A S-63/0,1 |
| Product ID: | 2CSB202201R2630 |
| EAN: | 8012542799306 |
| Catalog Description: | DDA202 A S-63/0,1 - RCD Block |
| Long Description: | The RCD block DDA200 series is suitable for assembly with MCBs S200 series. It assures protection against the effects of sinusoidal alternating and direct pulsating earth fault currents with an intentional tripping delay, in order to realize the selectivity with downstream instantaneous devices. Applications: commercial, industrial. |

Categories

Products » Low Voltage Products and Systems » Modular DIN Rail Products » Residual Current Devices RCDs » Residual Current Devices RCD Blocks

Ordering

| | |
|-------------------------|---------------|
| EAN: | 8012542799306 |
| Minimum Order Quantity: | 1 piece |
| Customs Tariff Number: | 85363030 |

Dimensions

| | |
|---------------------|----------|
| Product Net Width: | 0.070 m |
| Product Net Height: | 0.093 m |
| Product Net Depth: | 0.069 m |
| Product Net Weight: | 0.210 kg |

Container Information

| | |
|-------------------------------|---------------|
| Package Level 1 Units: | 1 piece |
| Package Level 1 Width: | 0.077 m |
| Package Level 1 Height: | 0.076 m |
| Package Level 1 Length: | 0.102 m |
| Package Level 1 Gross Weight: | 0.245 kg |
| Package Level 1 EAN: | 8012542799313 |

Technical

| | |
|----------------------------------|-----------------|
| Standards: | EN 61009 Ann. G |
| Operating Characteristic: | Selective |
| Type of Residual Current: | A type |
| Rated Residual Current: | 100 mA |
| Rated Current (I _n): | 63 A |
| Number of Poles: | 2 |
| Power Loss: | 5 W |
| Rated Voltage (U _r): | 230/400 V |

Environmental

| | |
|--------------|---|
| RoHS Status: | Planned to follow EU Directive 2002/95/EC August 18, 2005 and amendment after 2007 Q3 |
|--------------|---|

Certificates and Declarations (Document Number)

| | |
|---------------------------------|-----------------|
| Declaration of Conformity - CE: | ITSCE127DDA200 |
| RoHS Information: | 2CSC427001K0201 |

Classifications

| | |
|-----------------------------|---|
| Object Classification Code: | Q |
| ETIM 4: | EC002297 - Residual current circuit breaker (RCCB) module |
| ETIM 5: | EC002297 - Residual current circuit breaker (RCCB) module |





Automatización Eléctrica
Especialistas en Automatización

Below is a list of articles with direct links to our shop Electric Automation Network where you can see:

- Quote per purchase volume in real time.
- Online documentation and datasheets of all products.
- Estimated delivery time enquiry in real time.
- Logistics systems for the shipment of materials almost anywhere in the world.
- Purchasing management, order record and tracking of shipments.

To access the product, [click on the green button.](#)

| Product | Code | Reference | Product link |
|-------------------------------|-----------------|------------------|----------------------------|
| DDA202 A S-63/0,1 - RCD Block | 2CSB202201R2630 | DDA202AS-63/0,1 | Buy on EAN |