



Electric Automation
Automation specialists

Reference: OTP125B4U
Code: 1SCA022401R5300

OTP125B4U Enclosed switch

Buy it at Electric Automation Network



Enclosed switch 4-p.400V AC23A 50A AC22A 125A Plastic enclosure IP65 Black
Selector handle

Ordering

EAN:	6417019131382
Minimum Order Quantity:	1 piece
Customs Tariff Number:	85365080

Dimensions

Product Net Width:	200 mm
Product Net Height:	400 mm
Product Net Depth:	140 mm
Product Net Weight:	2.5 kg

Container Information

Package Level 1 Units:	1 piece
Package Level 1 Width:	203 mm
Package Level 1 Height:	187 mm
Package Level 1 Length:	407 mm
Package Level 1 Gross Weight:	2.6 kg
Package Level 1 EAN:	6417019131382

Environmental

RoHS Status:	Planned to follow EU Directive 2002/95/EC August 18, 2005 and amendment after 2009 Q4
--------------	---

Additional Information

Cable Entry Position:	Top and bottom
Cable Outlets Per Side:	Blank cable entries
Conventional Thermal Current (I_{the}):	Fully Enclosed 100 A
Degree of Protection:	acc. to IEC 60529 IP65
Enclosure Material:	Plastic
IIT Publishing Status:	Level 0 - Information enabled
Number of Poles:	4
Pollution Degree:	3
Position of Line Terminals:	Top In - Bottom Out
Position of Neutral Terminals:	Top In - Bottom Out
Position of PE Terminals:	Top In - Bottom Out
Product Main Type:	OT125
Product Name:	Enclosed switch
Rated Operational Current AC-21A (I_e):	(690 V) 125 A (500 V) 125 A (380 ... 415 V) 125 A
Rated Operational Current AC-22A (I_e):	(500 V) 125 A (690 V) 125 A
Rated Operational Current AC-23A (I_e):	(380 ... 415 V) 90 A (500 V) 70 A (690 V) 50 A
Rated Operational Voltage:	750 V

Certificates and Declarations (Document Number)

BV Certificate:	1SCC340018D0202
Data Sheet, Technical Information:	1SCC340009C0201
Declaration of Conformity - CE:	1SCC340003D0203
DNV Certificate:	1SCC340019D0201
GL Certificate:	1SCC301042D0201
LR Certificate:	1SCC340016D0202
RoHS Information:	1SCC340034D0201

Classifications

ETIM 5:	EC000249 - Protection switch disconnecter housing
Object Classification Code:	Q