



Electric Automation
Automation specialists

Reference: T6L630 1000V
Code: 1SDA060321R1

T6L630 PR222DS/P-LSI In=630 3pFF
1000VAC

Buy it at Electric Automation Network



C.BREAKER TMAX T6L 630 1000V AC FIXED THREE-POLE WITH FRONT TERMINALS
AND SOLID-STATE RELEASE IN AC PR222DS-LSI R 630

Ordering

EAN:	8015644627898
Minimum Order Quantity:	1 piece
Customs Tariff Number:	85362090

Dimensions

Product Net Width:	210 mm
Product Net Height:	268 mm
Product Net Depth:	103.5 mm
Product Net Weight:	9.5 kg

Container Information

Package Level 1 Units:	1 piece
Package Level 1 Width:	305 mm
Package Level 1 Height:	285 mm
Package Level 1 Length:	370 mm
Package Level 1 Gross Weight:	11 kg

Package Level 1 EAN:	8015644627898
----------------------	---------------

Additional Information

Electrical Durability:	7000 cycle 60 cycles per hour
Mechanical Durability:	20000 cycle 120 cycles per hour
Number of Poles:	3
Power Loss:	at Rated Operating Conditions per Pole 20 W
Product Main Type:	SACE Tmax T
Product Name:	Automatic Circuit Breaker
Product Type:	CB
Rated Current (I_n):	630 A
Rated Impulse Withstand Voltage (U_{imp}):	8 kV
Rated Insulation Voltage (U_i):	1000 V
Rated Operational Voltage:	1000 V AC 1000 V DC
Rated Service Short-Circuit Breaking Capacity (I_{cs}):	(1000 V AC) 6 kA
Rated Short-time Withstand Current (I_{cw}):	for 1 s 7,6 A
Rated Ultimate Short-Circuit Breaking Capacity (I_{cu}):	(1000 V AC) 12 kA
Rated Uninterrupted Current (I_u):	630 A
Release Type:	EL
Standards:	IEC 60947
Sub-type:	T6
Terminal Connection Type:	Fixed Circuit-Breakers Front
Test Voltage Max (U_{test}):	3500 V
Version:	F

Certificates and Declarations (Document Number)

Data Sheet, Technical Information:	1SDC210023D0201
Declaration of Conformity - CE:	1SDL000165R0006

Classifications

ETIM 4:	EC000228 - Power circuit-breaker for trafo/generator/ installation prot.
ETIM 5:	EC000228 - Power circuit-breaker for trafo/generator/ installation prot.
Object Classification Code:	Q

UNSPSC:

39121100