



**Electric Automation**  
Automation specialists

Reference: T7V1250  
Code: 1SDA062973R1

T7V 1250 PR332/P LI In=1250A 4p F F

Buy it at Electric Automation Network



C.BREAKER TMAX T7V 1250 FIXED FOUR-POLE WITH FRONT TERMINALS AND LEVER OPERATING MECHANISM AND SOLID-STATE RELEASE IN AC PR332/P-LI R 1250

### Ordering

EAN:	8015644655228
Minimum Order Quantity:	1 piece
Customs Tariff Number:	85362090

### Dimensions

Product Net Width:	280 mm
Product Net Height:	268 mm
Product Net Depth:	154 mm
Product Net Weight:	12.5 kg

### Container Information

Package Level 1 Units:	1 piece
Package Level 1 Width:	360 mm
Package Level 1 Height:	350 mm
Package Level 1 Length:	360 mm
Package Level 1 Gross Weight:	14 kg

Package Level 1 EAN:	8015644655228
----------------------	---------------

## Environmental

RoHS Status:	Planned to follow EU Directive 2002/95/EC August 18, 2005 and amendment after 2007 Q2
--------------	---

## Additional Information

Number of Poles:	4
Power Loss:	at Rated Operating Conditions per Pole 78,3 W
Product Main Type:	SACE Tmax T
Product Name:	Automatic Circuit Breaker
Product Type:	CB
Rated Current ( $I_n$ ):	1250 A
Rated Operational Voltage:	690 V AC
Rated Service Short-Circuit Breaking Capacity ( $I_{cs}$ ):	(220 V AC) 200 kA (230 V AC) 200 kA (380 V AC) 150 kA (400 V AC) 150 kA (415 V AC) 150 kA (440 V AC) 130 kA (500 V AC) 100 kA (690 V AC) 45 kA
Rated Short-time Withstand Current ( $I_{cw}$ ):	for 1 s 15 A
Rated Ultimate Short-Circuit Breaking Capacity ( $I_{cu}$ ):	(220 V AC) 20 kA (230 V AC) 20 kA (380 V AC) 150 kA (400 V AC) 150 kA (415 V AC) 150 kA (440 V AC) 130 kA (500 V AC) 100 kA (690 V AC) 60 kA
Rated Uninterrupted Current ( $I_u$ ):	1250 A
Release Type:	EL
Standards:	IEC 60947
Sub-type:	T7
Suitable For:	T7
Suitable for Product Class:	Moulded Case Circuit Breakers
Terminal Connection Type:	Fixed Circuit-Breakers Front
Version:	F

## Certificates and Declarations (Document Number)

Data Sheet, Technical Information:	1SDC210015D0201
Declaration of Conformity - CE:	1SDL000165R0007

GL Certificate:	1SDL000163R0056
RoHS Information:	1SDL000201R0001

## Classifications

ETIM 4:	EC000228 - Power circuit-breaker for trafo/generator/ installation prot.
ETIM 5:	EC000228 - Power circuit-breaker for trafo/generator/ installation prot.
Object Classification Code:	Q
UNSPSC:	39121100