



**Electric Automation**  
Automation specialists

Reference: XT2S160  
Code: 1SDA067831R1

XT2S 160 Ekip M-I In=52A 3p F F

Buy it at Electric Automation Network



C.BREAKER TMAX XT2S 160 FIXED THREE-POLE WITH FRONT TERMINALS AND SOLID-STATE RELEASE IN AC EKIP-M-I R 52 A

### Ordering

|                         |               |
|-------------------------|---------------|
| EAN:                    | 8015644017279 |
| Minimum Order Quantity: | 1 piece       |
| Customs Tariff Number:  | 85362090      |

### Dimensions

|                     |         |
|---------------------|---------|
| Product Net Width:  | 90 mm   |
| Product Net Height: | 130 mm  |
| Product Net Depth:  | 82.5 mm |
| Product Net Weight: | 1.2 kg  |

### Container Information

|                               |         |
|-------------------------------|---------|
| Package Level 1 Units:        | 1 piece |
| Package Level 1 Width:        | 130 mm  |
| Package Level 1 Height:       | 208 mm  |
| Package Level 1 Length:       | 145 mm  |
| Package Level 1 Gross Weight: | 1.2 kg  |

|                      |               |
|----------------------|---------------|
| Package Level 1 EAN: | 8015644017279 |
|----------------------|---------------|

## Additional Information

|  |  |
|--|--|
| Circuit Breaker Type to be Associated:                       | Motor protection   |
| Electrical Durability:                                       | 120 cycles per hour<br>8000 cycle  |
| Mechanical Durability:                                       | Nr. Operations 240 cycles per hour<br>Nr. Operations 25000 cycle   |
| Number of Poles:   | 3  |
| Opening Time:  | CB with SOR 15 ms<br>CB with UVR 15 ms   |
| Product Main Type:   | SACE Tmax XT   |
| Product Name:  | Automatic Circuit Breaker  |
| Product Type:  | CB   |
| Rated Current ( $I_n$ ):                                     | 52 A   |
| Rated Frequency (f):   | 50 / 60 Hz   |
| Rated Impulse Withstand Voltage ( $U_{imp}$ ):               | 8 kV   |
| Rated Insulation Voltage ( $U_i$ ):                          | 1000 V   |
| Rated Operational Voltage:                                   | 690 V AC<br>500 V DC   |
| Rated Service Short-Circuit Breaking Capacity ( $I_{cs}$ ):  | (220 V AC) 85 kA<br>(220 V AC) 85 kA<br>(380 V AC) 50 kA<br>(415 V AC) 50 kA<br>(440 V AC) 50 kA<br>(500 V AC) 36 kA<br>(690 V AC) 12 kA |
| Rated Ultimate Short-Circuit Breaking Capacity ( $I_{cu}$ ): | (220 V AC) 85 kA<br>(230 V AC) 85 kA<br>(380 V AC) 50 kA<br>(415 V AC) 50 kA<br>(440 V AC) 50 kA<br>(500 V AC) 36 kA<br>(690 V AC) 12 kA |
| Rated Uninterrupted Current ( $I_u$ ):                       | 160 A  |
| Rated Voltage ( $U_r$ ):                                     | 690 V  |
| Release Type:  | EL   |
| Standards:   | IEC 60947  |
| Sub-type:  | XT2  |
| Terminal Connection Type:                                    | Fixed Circuit-Breakers<br>Front  |
| Version:   | F  |

## Certificates and Declarations (Document Number)

|                                    |                 |
|------------------------------------|-----------------|
| Data Sheet, Technical Information: | 1SDC210033D0201 |
|------------------------------------|-----------------|

|                                 |                 |
|---------------------------------|-----------------|
| Declaration of Conformity - CE: | 1SDL000165R0010 |
| GL Certificate:                 | 1SDL000163R0093 |
| LR Certificate:                 | 1SDL000163R0100 |

## Classifications

|                             |   |
|-----------------------------|---|
| ETIM 4:                     | EC000228 - Power circuit-breaker for trafo/generator/<br>installation prot. |
| ETIM 5:                     | EC000228 - Power circuit-breaker for trafo/generator/<br>installation prot. |
| Object Classification Code: | Q   |
| UNSPSC:                     | 39120000  |