



**Automatización Eléctrica**  
Especialistas en Automatización

At the end of this document you will find links to products related to this catalog. You can go directly to our shop by clicking HERE. [HERE](#)

## Device coupler - FB-2SP/E - 2316052

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (<http://phoenixcontact.com/download>)



Device coupler for Foundation Fieldbus and PROFIBUS PA with terminal connections for two spurs connected to fieldbus end devices

### Product Description

The FB-2SP/E has terminal blocks for two spur connections to each device coupler. The device coupler provides short-circuit protection to the fieldbus trunk. Voltage and communication are routed via the TBUS connection system to multiple installed device couplers.



### Key Commercial Data

Packing unit	1 STK
GTIN	 4 055626 000916

### Technical data

#### Note

Utilization restriction	EMC: class A product, see manufacturer's declaration in the download area
-------------------------	---

#### Dimensions

Width	17.5 mm
Height	89.7 mm
Depth	70.4 mm

#### Ambient conditions

Ambient temperature (operation)	-40 °C ... 85 °C (depending on set rated current)
Ambient temperature (storage/transport)	-40 °C ... 85 °C
Permissible humidity (operation)	10 % ... 95 % (non-condensing)
Degree of protection	IP20

#### General

Standards/regulations	IEC 60529, IEC 61158-2
-----------------------	------------------------

# Device coupler - FB-2SP/E - 2316052

## Technical data

### General

	EN 61326, EN 60068-2-27, EN 60068-2-6, EN 60079-0, EN 60079-11, EN 60079-15
	NE21
	FF-846
Mounting position	On horizontal DIN rail NS 35 in acc. with EN 60715
Net weight	222 g
Housing material	PA 66-FR
Color	green
Fieldbus Foundation	FF-846

### Power supply

Supply voltage range	10.5 V DC ... 32 V DC (via FB-ET/E)
Max. current consumption	3.5 mA (no load)
Conductor cross section flexible max.	0.20 mm <sup>2</sup>
Conductor cross section flexible min.	2.50 mm <sup>2</sup>
Conductor cross section solid max.	0.20 mm <sup>2</sup>
Conductor cross section solid min.	2.50 mm <sup>2</sup>
Max. AWG conductor cross section, flexible	12
Min. AWG conductor cross section, flexible	24
Conductor cross section AWG max.	12
Conductor cross section AWG min.	24

### Serial interface

Interface 1	Foundation Fieldbus and PROFIBUS PA Segment
Connection method	Pluggable COMBICON screw connection for each spur
Termination resistor	via FB-ET/E
Conductor cross section solid min.	0.2 mm <sup>2</sup>
Conductor cross section solid max.	2.5 mm <sup>2</sup>
Conductor cross section flexible min.	0.2 mm <sup>2</sup>
Conductor cross section flexible max.	2.5 mm <sup>2</sup>
Conductor cross section AWG min.	24
Conductor cross section AWG max.	12
Torque	0.5 Nm ... 0.6 Nm
Output nominal voltage	≤ 32 V (each spur)
Maximum output current	45 mA (per spur)

### Safety data

Max. output voltage $U_o$	$U_i$
Max. output current $I_o$	50 mA (per spur)
Max. output power $P_o$	$U_o \times I_o$
Group	IIC
Max. external capacity $C_o$	60 nF

# Device coupler - FB-2SP/E - 2316052

## Technical data

### Safety data

Group	IIC
Max. external inductivity L <sub>o</sub>	250 µH
ATEX	Sira 14ATEX4018X; # II 3(3)G Ex nA [ic] IIC T4 Gc; Ex nA [ic] IIC T4 Gc, FISCO ic spurs
IECEX	IECEX SIR 14.0011X; Ex nA [ic] IIC T4 Gc; Ex nA [ic] IIC T4 Gc, FISCO ic spurs
CSA, USA/Canada	Class I, Div. 2, Groups A,B,C,D Ex nL IIC T4 FNICO, Ex ic IIC T4 FISCO ic Ex nA [nL] IIC T4, Ex nA [ic] IIC T4 Ex nA [nL] IIC T4 FNICO spurs, Ex nA [ic] IIC T4 FISCO ic spurs Class I, Zone 2 AEx nL IIC T4 FNICO, AEx ic IIC T4 FISCO ic AEx nA [nL] IIC T4, AEx nA [ic] IIC T4 AEx nA [nL] IIC T4 FNICO spurs, AEx nA [ic] IIC T4 FISCO ic spurs

### Standards and Regulations

Shock	15g, 11 ms
Standards/regulations	IEC 60529, IEC 61158-2
	EN 61326, EN 60068-2-27, EN 60068-2-6, EN 60079-0, EN 60079-11, EN 60079-15
	NE21
	FF-846
Vibration (operation)	1g, 10 Hz - 150 Hz
Fieldbus Foundation	FF-846
Group	IIC
	IIC
ATEX	Sira 14ATEX4018X; # II 3(3)G Ex nA [ic] IIC T4 Gc; Ex nA [ic] IIC T4 Gc, FISCO ic spurs
IECEX	IECEX SIR 14.0011X; Ex nA [ic] IIC T4 Gc; Ex nA [ic] IIC T4 Gc, FISCO ic spurs
CSA, USA/Canada	Class I, Div. 2, Groups A,B,C,D Ex nL IIC T4 FNICO, Ex ic IIC T4 FISCO ic Ex nA [nL] IIC T4, Ex nA [ic] IIC T4 Ex nA [nL] IIC T4 FNICO spurs, Ex nA [ic] IIC T4 FISCO ic spurs Class I, Zone 2 AEx nL IIC T4 FNICO, AEx ic IIC T4 FISCO ic AEx nA [nL] IIC T4, AEx nA [ic] IIC T4 AEx nA [nL] IIC T4 FNICO spurs, AEx nA [ic] IIC T4 FISCO ic spurs

## Classifications

### eCl@ss

eCl@ss 5.1	27259205
eCl@ss 6.0	27259090
eCl@ss 8.0	27242608

# Device coupler - FB-2SP/E - 2316052


## Classifications

ETIM

ETIM 4.0	EC001600
ETIM 5.0	EC001604

## Drawings

Circuit diagram



Connection diagram: FB-2SP

Phoenix Contact 2016 © - all rights reserved  
<http://www.phoenixcontact.com>

PHOENIX CONTACT GmbH & Co. KG  
Flachsmarktstr. 8  
32825 Blomberg  
Germany  
Tel. +49 5235 300  
Fax +49 5235 3 41200  
<http://www.phoenixcontact.com>



Below is a list of articles with direct links to our shop Electric Automation Network where you can see:

- Quote per purchase volume in real time.
- Online documentation and datasheets of all products.
- Estimated delivery time enquiry in real time.
- Logistics systems for the shipment of materials almost anywhere in the world.
- Purchasing management, order record and tracking of shipments.

To access the product, [click on the green button.](#)

Product	Code	Reference	Product link
Device coupler for Foundation Fieldbus and PROFIBUS PA with terminal connections for two spurs connected to fieldbus end devices	2316052	FB-2SP/E	<a href="#">Buy on EAN</a>