Three-phase busbar link, Circuit-breaker: 3, 153 mm, For PKZM0-... or PKE12, PKE32 without side mounted auxiliary contacts or voltage releases



Part no. B3.1/3-PKZ0

044946

EL Number 4357201

| (Norway) | |
|--|---|
| General specifications | Fatar Marilla @ action DO Accessory Throughout hospitals |
| Product name | Eaton Moeller® series B3 Accessory Three-phase busbar link |
| Part no. | B3.1/3-PKZ0 |
| EAN | 4015080449461 |
| Product Length/Depth | 155 millimetre |
| Product height | 34 millimetre |
| Product width | 11 millimetre |
| Product weight | 0.064 kilogram |
| Certifications | UL 508 UL CE CSA UL Category Control No.: NLRV CSA File No.: 98494 CSA-C22.2 No. 14 IEC/EN 60947-4-1 CSA Class No.: 3211-06 UL File No.: E36332 |
| Product Tradename | B3 |
| Product Type | Accessory |
| Product Sub Type | Three-phase busbar link |
| Features & Functions | |
| Color | Black |
| Electric connection type | Fork |
| Features | Insulated |
| Functions | Can be extended by rotating installation |
| Number of phases | 3 |
| Number of poles | Three-pole |
| General information | |
| Mounting width | 45 + 9 mm |
| Overvoltage category | III |
| Pollution degree | 3 |
| Product category | Accessories |
| Rated impulse withstand voltage (Uimp) | 6000 V AC |
| Suitable for | 3 Circuit-breakers |
| Climatic environmental conditions | |
| Ambient operating temperature - min | -25 °C |
| Ambient operating temperature - max | 55 °C |
| Electrical rating | |
| Rated operational voltage (Ue) - max | 690 V |
| Rated operational voltage (Ue) at AC - max | 690 V |
| Rated uninterrupted current (Iu) | 63 A |
| Short-circuit rating | |
| Rated conditional short-circuit current (Iq) | 0 kA |
| Rated short-time withstand current (Icw) | 0 kA |
| Design verification | |
| Equipment heat dissipation, current-dependent Pvid | 5.1 W |
| Heat dissipation capacity Pdiss | 0 W |
| Heat dissipation per pole, current-dependent Pvid | 1.7 W |

| Rated operational current for specified heat dissipation (In) | 63 A |
|--|--|
| | |
| Static heat dissipation, non-current-dependent Pvs | 0 W |
| 10.2.2 Corrosion resistance | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | Meets the product standard's requirements. |
| 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | Meets the product standard's requirements. |
| 10.2.5 Lifting | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | Meets the product standard's requirements. |
| 10.3 Degree of protection of assemblies | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | Is the panel builder's responsibility. |
| 10.9.2 Power-frequency electric strength | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility. |
| 10.10 Temperature rise | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Phase busbar (EC000215)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Phase busbar (ecl@ss13-27-37-13-06 [ACN992016])

| Number of phases | | 3 |
|--|-----|-------|
| Number of poles | | 3 |
| Suitable for number of devices | | 3 |
| Module width | mm | 54 |
| Cross section | mm² | 0 |
| Length | mm | 155 |
| Can be cut to size | | No |
| Width in number of modular spacings | | 8.5 |
| Rated permanent current lu | А | 63 |
| Type of electric connection | | Fork |
| Insulated | | Yes |
| Rated surge voltage | kV | 6 |
| Conditioned rated short-circuit current Iq | kA | 0 |
| Max. rated operation voltage Ue | V | 690 |
| Rated short-time withstand current lcw | kA | 0 |
| Suitable for devices with N-conductor | | No |
| Suitable for devices with auxiliary switch | | No |
| Colour | | Black |
| | | |