## **DATASHEET - T0-2-8231/I1**

Step switches, T0, 20 A, surface mounting, 2 contact unit(s), Contacts: 4, 60 °, maintained, Without 0 (Off) position, 1-4, Design number 8231



Part no.	T0-2-8231/l1
	207106
EL Number	1456337
(Norway)	

## **General specifications**

General specifications	
Product name	Eaton Moeller® series T0 Step switch
Part no.	T0-2-8231/l1
EAN	4015082071066
Product Length/Depth	137 millimetre
Product height	102 millimetre
Product width	80 millimetre
Product weight	0.264 kilogram
Certifications	IEC/EN 60947-3 VDE 0660 IEC/EN 60947 IEC/EN 60204
Product Tradename	ТО
Product Type	Step switch
Product Sub Type	None
Catalog Notes	Rated Short-time Withstand Current (Icw) for a time of 1 second
Features & Functions	
Features	Complete device in housing
Fitted with:	Black thumb grip and front plate
Inscription	1-4
Number of poles	Single-pole
General information	
Degree of protection	IP65
Degree of protection (front side)	IP65 NEMA 12
Lifespan, mechanical	400,000 Operations
Mounting method	Surface mounting
Mounting position	As required
Number of contact units	2
Operating frequency	1200 Operations/h
Overvoltage category	III.
Pollution degree	3
Product category	Control switches
Rated impulse withstand voltage (Uimp)	6000 V AC
Safe isolation	440 V AC, Between the contacts, According to EN 61140
Safety parameter (EN ISO 13849-1)	B10d values as per EN ISO 13849-1, table C.1
Shock resistance	15 g, Mechanical, According to IEC/EN 60068-2-27, Half-sinusoidal shock 20 ms
Suitable for	Ground mounting
Switching angle	60 °
Туре	Step switch
Climatic environmental conditions	
Ambient operating temperature - min	-25 °C
Ambient operating temperature - max	40 °C
Ambient operating temperature (enclosed) - min	-25 °C
Ambient operating temperature (enclosed) - max	40 °C
Climatic proofing	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78
Terminal capacities	
Terminal capacity (flexible with ferrule)	1 x (0.75 - 2.5) mm <sup>2</sup> , ferrules to DIN 46228

01/21/2024

	2 x (0.75 - 2.5) mm <sup>2</sup> , ferrules to DIN 46228
Terminal capacity (solid/stranded)	1 x (1 - 2.5) mm <sup>2</sup> 2 x (1 - 2.5) mm <sup>2</sup>
Screw size	M3.5, Terminal screw
Tightening torque	1 Nm, Screw terminals 8.8 lb-in, Screw terminals
Electrical rating	
Rated breaking capacity at 220/230 V (cos phi to IEC 60947-3)	100 A
Rated breaking capacity at 400/415 V (cos phi to IEC 60947-3)	110 A
Rated breaking capacity at 500 V (cos phi to IEC 60947-3)	80 A
Rated breaking capacity at 660/690 V (cos phi to IEC 60947-3)	60 A
Rated operating voltage (Ue) at AC - max	690 V
Rated operational current (Ie) at AC-3, 220 V, 230 V, 240 V	11.5 A
Rated operational current (Ie) at AC-3, 380 V, 400 V, 415 V	11.5 A
Rated operational current (Ie) at AC-3, 500 V	9 A C
Rated operational current (Ie) at AC-3, 660 V, 690 V	4.9 A
Rated operational current (Ie) at AC-21, 440 V	20 A
Rated operational current (Ie) at AC-23A, 230 V	13.3 A
Rated operational current (Ie) at AC-23A, 400 V, 415 V	13.3 A
Rated operational current (Ie) at AC-23A, 500 V	13.3 A
Rated operational current (Ie) at AC-23A, 690 V	7.6 A
Rated operational current (Ie) at DC-1, load-break switches I/r = 1 ms	10 A
Rated operational current (Ie) at DC-13, control switches $L/R$ = 50 ms	10 A
Rated operational current (Ie) at DC-21, 240 V	1A
Rated operational current (Ie) at DC-23A, 24 V	10 A
Rated operational current (Ie) at DC-23A, 48 V	10 A
Rated operational current (Ie) at DC-23A, 60 V	10 A
Rated operational current (Ie) at DC-23A, 120 V	5 A
Rated operational current (Ie) at DC-23A, 240 V	5 A
Rated operational current (Ie) star-delta at AC-3, 230 V	20 A
Rated operational current (Ie) star-delta at AC-3, 400 V	20 A
Rated operational current (Ie) star-delta at AC-3, 500 V	15.6 A
Rated operational current (Ie) star-delta at AC-3, 690 V	8.5 A
Rated operational power at AC-3, 415 V, 50 Hz	5.5 kW
Rated operational power at AC-3, 500 V, 50 Hz	5.5 kW
Rated operational power at AC-3, 690 V, 50 Hz	4 kW
Rated operational power at AC-23A, 220/230 V, 50 Hz	3 kW
Rated operational power at AC-23A, 400 V, 50 Hz	5.5 kW
Rated operational power at AC-23A, 500 V, 50 Hz	7.5 kW
Rated operational power at AC-23A, 690 V, 50 Hz	5.5 kW
Rated operational power star-delta at 220/230 V, 50 Hz	5.5 kW
Rated operational power star-delta at 380/400 V, 50 Hz	7.5 kW
Rated operational power star-delta at 500 V, 50 Hz	7.5 kW
Rated operational power star-delta at 690 V, 50 Hz	5.5 kW
Rated uninterrupted current (Iu)	20 A
Uninterrupted current	Rated uninterrupted current lu is specified for max. cross-section.
hort-circuit rating	
Rated conditional short-circuit current (Iq)	6 kA
Rated short-time withstand current (Icw)	320 A, Contacts, 1 second
Short-circuit protection rating	20 A gG/gL, Fuse, Contacts
witching capacity	
Load rating	1.6 x I# (with intermittent operation class 12, 40 % duty factor) 2 x I# (with intermittent operation class 12, 25 % duty factor) 1.3 x I# (with intermittent operation class 12, 60 % duty factor)
Number of contacts in series at DC-21A, 240 V	1
Number of contacts in series at DC-23A, 24 V	1
Number of contacts in series at DC-23A, 48 V	2

he product standard's requirements. he product standard's requirements. he product standard's requirements. he product standard's requirements. stance only in connection with protective shield. ot apply, since the entire switchgear needs to be evaluated. ot apply, since the entire switchgear needs to be evaluated. he product standard's requirements. ot apply, since the entire switchgear needs to be evaluated. the product standard's requirements. ot apply, since the entire switchgear needs to be evaluated. the product standard's requirements. ot apply, since the entire switchgear needs to be evaluated. the product standard's requirements. ot apply, since the entire switchgear needs to be evaluated. anel builder's responsibility. anel builder's responsibility. The specifications for the switchgear must be ed. anel builder's responsibility. The specifications for the switchgear must be ed.
the product standard's requirements. the product standard's requirements. the product standard's requirements. stance only in connection with protective shield. to tapply, since the entire switchgear needs to be evaluated. to tapply, since the entire switchgear needs to be evaluated. the product standard's requirements. to tapply, since the entire switchgear needs to be evaluated. the product standard's requirements. to tapply, since the entire switchgear needs to be evaluated. the product standard's requirements. to tapply, since the entire switchgear needs to be evaluated. the product standard's requirements. to tapply, since the entire switchgear needs to be evaluated. anel builder's responsibility. anel bu
the product standard's requirements. the product standard's requirements. the product standard's requirements. stance only in connection with protective shield. at apply, since the entire switchgear needs to be evaluated. at apply, since the entire switchgear needs to be evaluated. the product standard's requirements. at apply, since the entire switchgear needs to be evaluated. the product standard's requirements. at apply, since the entire switchgear needs to be evaluated. the product standard's requirements. at apply, since the entire switchgear needs to be evaluated. anel poulct standard's requirements. anel builder's responsibility. anel builder's responsibility.
the product standard's requirements. the product standard's requirements. the product standard's requirements. stance only in connection with protective shield. to apply, since the entire switchgear needs to be evaluated. to apply, since the entire switchgear needs to be evaluated. the product standard's requirements. to apply, since the entire switchgear needs to be evaluated. the product standard's requirements. to apply, since the entire switchgear needs to be evaluated. the product standard's requirements. to apply, since the entire switchgear needs to be evaluated. to apply, since the entire switchgear needs to be evaluated. anel builder's responsibility. anel builder's responsibility. anel builder's responsibility.
the product standard's requirements. the product standard's requirements. the product standard's requirements. stance only in connection with protective shield. tot apply, since the entire switchgear needs to be evaluated. tot apply, since the entire switchgear needs to be evaluated. the product standard's requirements. tot apply, since the entire switchgear needs to be evaluated. the product standard's requirements. tot apply, since the entire switchgear needs to be evaluated. the product standard's requirements. tot apply, since the entire switchgear needs to be evaluated. the product standard's requirements. anel builder's responsibility. anel builder's responsibility.
the product standard's requirements. the product standard's requirements. the product standard's requirements. stance only in connection with protective shield. to tapply, since the entire switchgear needs to be evaluated. to tapply, since the entire switchgear needs to be evaluated. the product standard's requirements. to tapply, since the entire switchgear needs to be evaluated. the product standard's requirements. to tapply, since the entire switchgear needs to be evaluated. the product standard's requirements. to tapply, since the entire switchgear needs to be evaluated. anel builder's responsibility.
the product standard's requirements. the product standard's requirements. the product standard's requirements. stance only in connection with protective shield. tot apply, since the entire switchgear needs to be evaluated. tot apply, since the entire switchgear needs to be evaluated. the product standard's requirements. tot apply, since the entire switchgear needs to be evaluated. the product standard's requirements. tot apply, since the entire switchgear needs to be evaluated. the product standard's requirements. tot apply, since the entire switchgear needs to be evaluated. tot apply, since the entire switchgear needs to be evaluated. anel builder's responsibility.
the product standard's requirements. the product standard's requirements. the product standard's requirements. stance only in connection with protective shield. to apply, since the entire switchgear needs to be evaluated. to apply, since the entire switchgear needs to be evaluated. the product standard's requirements. to apply, since the entire switchgear needs to be evaluated. the product standard's requirements. to apply, since the entire switchgear needs to be evaluated. the product standard's requirements. to apply, since the entire switchgear needs to be evaluated. the product standard's requirements. to apply, since the entire switchgear needs to be evaluated. to apply, since the entire switchgear needs to be evaluated.
the product standard's requirements. the product standard's requirements. the product standard's requirements. stance only in connection with protective shield. to apply, since the entire switchgear needs to be evaluated. to apply, since the entire switchgear needs to be evaluated. the product standard's requirements. to apply, since the entire switchgear needs to be evaluated. the product standard's requirements. to apply, since the entire switchgear needs to be evaluated. the product standard's requirements. to apply, since the entire switchgear needs to be evaluated. the product standard's requirements.
the product standard's requirements. the product standard's requirements. the product standard's requirements. stance only in connection with protective shield. tot apply, since the entire switchgear needs to be evaluated. tot apply, since the entire switchgear needs to be evaluated. the product standard's requirements. tot apply, since the entire switchgear needs to be evaluated. the product standard's requirements. tot apply, since the entire switchgear needs to be evaluated. the product standard's requirements.
the product standard's requirements. the product standard's requirements. the product standard's requirements. stance only in connection with protective shield. the apply, since the entire switchgear needs to be evaluated. the product standard's requirements. the product standard's requirements. the apply, since the entire switchgear needs to be evaluated.
the product standard's requirements. the product standard's requirements. the product standard's requirements. stance only in connection with protective shield. tot apply, since the entire switchgear needs to be evaluated. tot apply, since the entire switchgear needs to be evaluated. the product standard's requirements.
the product standard's requirements. the product standard's requirements. the product standard's requirements. stance only in connection with protective shield. the apply, since the entire switchgear needs to be evaluated. the apply, since the entire switchgear needs to be evaluated.
the product standard's requirements. the product standard's requirements. the product standard's requirements. stance only in connection with protective shield. the apply, since the entire switchgear needs to be evaluated.
he product standard's requirements. he product standard's requirements. he product standard's requirements. stance only in connection with protective shield.
he product standard's requirements. he product standard's requirements. he product standard's requirements.
he product standard's requirements. he product standard's requirements.
he product standard's requirements.
he product standard's requirements.
ined t 0 (Off) position
$_{\rm 2}$ per 100,000 switching operations statistically determined, at 24 V DC, 10
ai

## **Technical data ETIM 9.0**

Low-voltage industrial components (EG000017) / Control switch (EC002611)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Off-load switch, circuit breaker, control switch / Control switch (ecl@ss13-27-37-14-14 [ACN998016])

Type of switch		Level switch
Number of poles		1
Max. rated operation voltage Ue AC	V	690
Rated permanent current lu	А	20
Number of switch positions		4
With zero (off) position		No
With retraction in 0-position		No

Device construction	Surface mounted device
Width in number of modular spacings	0
Suitable for floor mounting	Yes
Suitable for front mounting	No
Suitable for distribution board installation	No
Suitable for intermediate mounting	No
Complete device in housing	Yes
Type of control element	Toggle
Front shield size	48x48 mm
Degree of protection (IP), front side	IP65
Degree of protection (NEMA), front side	12