Pushbutton, RMQ-Titan, Flat, maintained, red, inscribed, Bezel: titanium



Part no. M22-DR-R-X0

216628

EL Number 4355611

(Norway)

General specifications	
Product name	Eaton Moeller® series M22 Pushbutton
Part no.	M22-DR-R-X0
EAN	4015082166281
Product Length/Depth	30 millimetre
Product height	30 millimetre
Product width	30 millimetre
Product weight	0.011 kilogram
Certifications	CSA-C22.2 No. 94-91 UL File No.: E29184 CSA-C22.2 No. 14-05 UL UL Category Control No.: NKCR IEC/EN 60947-5 CE CSA IEC/EN 60947 CSA Class No.: 3211-03 VDE 0660 CSA File No.: 012528 UL 508 DNV GL LR
Product Tradename	M22
Product Type	Pushbutton
Product Sub Type	None
Features & Functions	
Bezel color	Titanium
Bezel material	Plastic
Design	Flat Classical
Features	Labelled
Fitted with:	Front ring
Functions	Stay-put/spring-return function can be changed on device
Inscription	Inscribed
General information	
Degree of protection	IP66 NEMA 3R NEMA 12 NEMA 13 NEMA 4X IP67 IP69K
Degree of protection (front side)	IP67/IP69K NEMA 4X
Lifespan, mechanical	1,000,000 Operations (AC operated)
Opening diameter	22.5 mm
Operating frequency	1800 Operations/h
Product category	RMQ-Titan
Size	Front dimensions: 22 x 22 mm
Туре	Pushbutton actuator
Ambient conditions, mechanical	
Mounting position	As required
Mounting position Shock resistance	As required Mechanical, According to IEC/EN 60068-2-27 30 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms

Connection to SmartWire-DT Actuating force Actuating force Actuating force Actuating force Actuating force Actuating force Actuation color Actuation function Maintained Switching function latching Contacts Force tor positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation apporting Pulsa Rated openational current to specified heat dissipation (in) Static head dissipation, concurrent-dependent Pvid Heat dissipation per pole, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Heat dissipation of resistance Heat dissipation for product standard's requirements. Heat dissipation of the main stability of enclosures 102.22 Verification of the main stability of enclosures 102.23 Verification of resistance of insulating materials to normal heat 102.23 Verification of resistance of insulating materials to normal heat 102.24 Verification of resistance of insulating materials to normal heat 102.25 Verification of resistance of insulating materials to normal heat 102.26 United to the product standard's requirements. 102.27 Inscriptions Meets the product standard's requirements. 102.28 Resistance to ultra-violet (UV) radiation 102.5 Mechanical impact 102.6 Mechanical impact 102.7 Inscriptions Meets the product standard's requirements. 102.8 Meets the product standard's requirements. 102.9 Desen not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. 103.1 Degree of protection of assemblies 104.0 Desenances and creepage distances Meets the product standard's requirements. 105.Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. 105.Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 106. Incorporation of switching devices and components 107. Internal electrical circuits and connections 108. Incorporation of switching devices	Ambient operating temperature - min	-25 °C
Ambient strange temperature - max Climate prording Communication Comection to SmartWire-DT Comection to SmartWire-DT Actuator Actuator Tunction Actuator Tunction Actuator Tunction Comection to SmartWire-DT Actuator United Strange to Tunction Actuator Tunction Comection to SmartWire-DT Actuator United Tunction Comection to SmartWire-DT Red Actuator United Tunction Comection to SmartWire-DT Red Actuator United Tunction Comection to SmartWire-DT Red Actuator United Tunction Comection Tunction Comecti	Ambient operating temperature - max	70 °C
Cimatic profiting Communication Connection to SmartWire- OT Actuator Actuator for Actuator for Actuator for the SmartWire- OT Actuator for Red Actuator on Red Actuator function Actuator function Actuator function Actuator function Actuator function Actuator function Maintained Swotching function latching Contacts Force for positive opening - min ON Design verification Equipment heart dissipation, current dependent Pvid OW Heart dissipation per pole, current dependent Pvid OW Rated operational current for specified heart dissipation into Static heatt dissipation, on-current-dependent Pvid OW Rated operational current for specified heart dissipation into Static heatt dissipation of resistance of insidiation generated by a UW Rated operational current for specified heart dissipation into Static heatt dissipation of resistance of insidiation generated by a UW Rated operational current for specified heart dissipation into Static heatt dissipation of resistance of insidiation generated by a UW Rated operational current for specified heart dissipation into Static heatt dissipation of resistance of insidiation generated by a UW Rated operational current for specified heart dissipation into Static heatt dissipation of resistance of insidiation generated by a UW Static heatt dissipation of resistance of insidiation generated by a reclassing maternals to normal heatt Red static product standard's requirements. Meets the product standard's requirements. 102.2 Mechanical impact Des not apply, since the entire switchgear needs to be evaluated. Des not apply, since the entire switchgear needs to be evaluated. Des not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Des not apply, since the entire switchgear needs to be evaluated. Des not apply, since the entire switchgear needs to be evaluated. Des not apply, since the entire switchgear need	Ambient storage temperature - min	40 °C
Communication Connection to SmartWire-DT Actuator Actuator function Design verification Equipment heat dissipation, currant-dependent Pvid Heat dissipation apapetity Pbiss DW Heat dissipation apapetity Pbiss DW Rated operational current for specified heat dissipation III) Actuator for specification Plus dissipation current for specified heat dissipation III) Day Actuator for specified heat dissipation function actually actual	Ambient storage temperature - max	2° 08
Connection to SmartWire-DT Actustor Actustor Actusted force Actusted record	Climatic proofing	
Actuator Actuator force Actuator function Design verification Temporary that dissipation, current-dependent Pvid Actuator function acpacity Pdiss OW Heat dissipation capacity Pdiss OW Actuator function per pole, current-dependent Pvid Actuator function f	Communication	
Actuator color Actuator function Actuator function Actuator function Actuator function Actuator function Actuator function Body Body Body Body Body Bed Body Body Body Body Body Bed addisplation current-dependent Pvid Body Beat dissippation current-dependent Pvid Beat dissippation current-dependent Pvid Beat dissippation current dependent Pvid Body Beat dissippation current dependent Pvid Body Beat dissippation per pole, current-dependent Pvid Body Beat dissippation per pole, current-dependent Pvid Body Beat dissippation per pole, current-dependent Pvid Body Body Beat dissippation per pole, current-dependent Pvid Body Body Body Body Beat dissippation, non-current-dependent Pvid Body Body	Connection to SmartWire-DT	
Actuator color Actuator function Actuator function Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Alter and substantiant of specification of the substantiant of the substanti	Actuator	
Actuator function Contacts Force for positive opening - min Design verification Equipment heart dissipation, current-dependent Pvid Heat dissipation apacity Pdiss Heat dissipation projec, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs U2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of resistance or insulating materials to normal heat 10.2.2.2 Verification of resistance or insulating materials to normal heat 10.2.2.3 Resistance to ultra-violet (UV) radiation 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creegage distances 10.5 Protection against electric shock 10.6 Rocopporation of switching devices and components 10.7 Inscriptions 10.8 Rocopporation of switching devices and components 10.9 Rocopporation of switching devices and connections 10.9 Rocopporation of switching of medical circuits and conn	Actuating force	5 N
Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation, capacity Pdiss OW Heat dissipation per pole, current-dependent Pvid Attack dissipation, per pole, current-dependent Pvid Bated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs OW 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.2 Verification of tremmal stability of enclosures Meets the product standard's requirements. 10.23.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects Moets the product standard's requirements. 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting Dees not apply, since the entire switchgear needs to be evaluated. 10.26 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.5 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage 10.10 Tietranel electrical circuits and connections Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Tietranel electrical circuits and connections Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device m	Actuator color	Red
Porce for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation, capacity Pdiss OW Heat dissipation capacity Pdiss OW Rated operational current for specified heat dissipation (In) Static heat dissipation, pro-current-dependent Pvid OW 10.22 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.3 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.8 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3 Resist of insu. In a obnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.9 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electric alcruits and connections Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating List the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Actuator function	
Design verification Equipment heat dissipation, current-dependent Pvid 0W Heat dissipation capacity Pdiss 0W Rated operational current for specified heat dissipation (In) 0A Static heat dissipation, non-current-dependent Pvid 0W Rated operational current for specified heat dissipation (In) 0A Static heat dissipation, non-current-dependent Pvs 0W 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.23.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.24.3 Resistance to ultra-violet (UV) radiation Please enquire Dose not apply, since the entire switchgear needs to be evaluated. 10.25 Lifting Dose not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Dose not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Dose not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Dose not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Dose not apply, since the entire switchgear needs to be evaluated. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequecy electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, prov	Contacts	
Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss O W Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs O W 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions 10.3.0 Egree of protection of assemblies 10.4.1 Clearances and creepage distances 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Internal electrical circuits and connections 10.9 Internal electrical circuits and connections 10.9 Power-frequency electric strength 10.9 Tomperature rise Not applicable. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Lis the panel builder's responsibility. Lis the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Force for positive opening - min	0 N
Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (in) O A Static heat dissipation, non-current-dependent Pvs O W 10.22 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/lire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violat (UV) radiation Please enquire Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating La the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Design verification	
Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3.0 Legree of protection of assemblies 10.3.0 Legree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.7 Internal electrical circuits and connections 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Timerrature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Geven meets the requirements, provided the information in the instruction 10.16 Internal electrical circuits and connections 10.17 Internal electrical circuits and connections 10.18 Legree of enclosures made of insulating material 10.19 Internal electrical circuits and connections 10.19 Internal electrical circuits and connections 10.11 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Heave the entry switcheau resets to be evaluated. 10.16 Internal electrical circuits and connections 10.17 Internal electrical circuits and connections 10.18 Legree the entry switcheau resets to be evaluated. 10.19 Legree the entry switcheau rese	Equipment heat dissipation, current-dependent Pvid	0 W
Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 10.2.2 Corrosion resistance 10.2.3 I Verification of thermal stability of enclosures 10.2.3 I Verification of thermal stability of enclosures 10.2.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 10.14 Electromagnetic compatibility 10.15 Short-circuit rating 10.16 Incorporation of evidence and or of the switchgear need to be evaluated. 10.17 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Internal electrical circuits and connections 10.9 Internal electrical circuits and connections 10.9 Internal electrical circuits and connections 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Mechanical function 10.17 Internal electric strength 10.18 Legenal builder's responsibility. The specifications for the switchgear must be observed. 10.19 Mechanical function 10.19 Mechanical function 10.10 Temperature rise 10.10 Temperature rise 10.11 Mechanical function	Heat dissipation capacity Pdiss	0 W
Static heat dissipation, non-current-dependent Pvs 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resists of insul. mat. to abnormal heat/fire by internal elect. effects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting 10.26 Mechanical impact 10.27 Internal electric shock 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Internal electric strength 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function	Heat dissipation per pole, current-dependent Pvid	0 W
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Some apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. In the panel builder's responsibility. The specifications for the switchgear must be observed. In the device meets the requirements, provided the information in the instruction.	Rated operational current for specified heat dissipation (In)	0 A
10.2.3 I Verification of thermal stability of enclosures 10.2.3 2 Verification of resistance of insulating materials to normal heat 10.2.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Degree of insulating material 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.1 Temperature rise 10.9.1 Temperature rise 10.9.1 Short-circuit rating 10.9.2 Responsibility 10.10 Temperature rise 10.11 Short-circuit rating 10.13 Mechanical function 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. In the device meets the requirements, provided the information in the instruction	Static heat dissipation, non-current-dependent Pvs	0 W
10.2.32 Verification of resistance of insulating materials to normal heat 10.2.33 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Resistance of insulating material elect. effects 10.15 Mechanical function 10.16 Incorporation of switching devices and components 10.17 Internal electric according to the evaluated. 10.18 Connections for external conductors 10.19 Internal electric according to the evaluated. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function	10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility.	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation Please enquire Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching evices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed.	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 They are panel builder's responsibility. 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.4 Resistance to ultra-violet (UV) radiation	Please enquire
10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. In the panel builder's responsibility. In the panel builder's responsibility. The specifications for the switchgear must be observed. In the device meets the requirements, provided the information in the instruction	10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must b observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. It is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.2.7 Inscriptions	Meets the product standard's requirements.
10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. 10 sthe panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 1s the panel builder's responsibility. 10.8 Connections for external conductors 1s the panel builder's responsibility. 10.9.2 Power-frequency electric strength 1s the panel builder's responsibility. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 1s the panel builder's responsibility. The specifications for the switchgear must be observed.	10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 When panel builder's responsibility. The specifications for the switchgear must be observed. 10.16 Temperature rise 10.17 Electromagnetic compatibility 10.18 The panel builder's responsibility. The specifications for the switchgear must be observed. 10.19 The device meets the requirements, provided the information in the instruction	10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. Is the panel builder's responsibility. Not applicable. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. Not applicable. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must b observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must b observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must b observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must b observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must b observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.10 Temperature rise	Not applicable.
observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
	10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
	10.13 Mechanical function	

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Front element for push button (EC000221)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for push-button actuators (ecl@ss13-27-37-12-10 [AKF028019])

[AKFUZ0019])		
Colour button		Red
Number of command positions		1
Construction type lens		Round
Hole diameter	mm	22.5
Width opening	mm	0
Height opening	mm	0

Type of button	Flat
Suitable for illumination	No
With protective cover	No
Labelled	Yes
Switching function latching	Yes
Spring-return	No
With front ring	Yes
Material front ring	Plastic
Colour front ring	Titanium
Degree of protection (IP), front side	IP67/IP69K
Degree of protection (NEMA), front side	4X