# **DATASHEET - Q18LWK1-GN/WB**



Illuminated selector switch actuator, momentary, 45°, 18 × 18 mm, 2  $\,$ positions, With thumb-grip, green, with VS anti-rotation tab, with filament bulb, 24 V



Q18LWK1-GN/WB Part no. Catalog No. 038883

Alternate Catalog Q18LWK1-GN-WB

No.

#### **Delivery program**

Don'tory program	
Product range	RMQ16
Basic function	Illuminated selector switch actuator
Single unit/Complete unit	Single unit
Design	With thumb-grip
	momentary
Function:	
	<i>▶</i> 45°
Description	with VS anti-rotation tab with filament bulb, 24 V
	2 positions
Colour	
Thumb-grip	green
Degree of Protection	IP65
Connection to SmartWire-DT	no
Front dimensions	18 × 18 mm

### **Technical data**

Overvoltage category/pollution degree

General			
Standards			IEC/EN 60947
Lifespan, mechanical	Operations	x 10 <sup>6</sup>	>3
Operating frequency	Operations/h		≦ 1800
Operating torque		Nm	≦ 0.2
Degree of protection, IEC/EN 60529			IP65
Climatic proofing			Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
Ambient temperature			
Open		°C	-25 - +60
Enclosed		°C	- 25 - 40
Mounting position			As required
Mechanical shock resistance		g	> 40 according to IEC 60068-2-27 Shock duration 11 ms Sinusoidal
Terminal capacities		$\mathrm{mm}^2$	0.5 - 1.0
Blade terminal			2.8 x 0.8 mm to DIN 46244
Fast-on connectors			2.8 x 0.8 mm to DIN 46247 and IEC 60760
Contacts			
Rated impulse withstand voltage	$U_{\text{imp}}$	V AC	800
Rated insulation voltage	Ui	V	250

III/3

Rated operational voltage	U <sub>e</sub>	V AC 24
Control circuit reliability		
at 24 V DC/5 mA	H <sub>F</sub>	Fault < 10 <sup>-7</sup> (i.e. 1 failure to 10 <sup>7</sup> operations)
at 5 V DC/1 mA	H <sub>F</sub>	Fault $< 5 \times 10^{-6}$ (1 failure in $5 \times 10^{6}$ operations) probability
Use of insulated ferrule ISH 2,8		>24 V AC/DC recommended >50 V AC or 120 V DC is mandatory, even on unused blade terminals

# Design verification as per IEC/EN 61439

3 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1			
Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	0
Heat dissipation per pole, current-dependent	P <sub>vid</sub>	W	0
Equipment heat dissipation, current-dependent	P <sub>vid</sub>	W	0
Static heat dissipation, non-current-dependent	P <sub>vs</sub>	W	1
Heat dissipation capacity	P <sub>diss</sub>	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	60
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Please enquire
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:specifications}$
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

#### **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Front element for selector switch (EC000222)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for selector switches (ecl@ss10.0.1-27-37-12-13 [AKF031014])


[AKF031014])	
Number of switch positions	2
Type of control element	Toggle
Suitable for illumination	Yes
Colour control element	Black
Colour indicator light cap	Green
Construction type lens	Square

Hole diameter	mm	m 16
Width opening	mm	m 0
Height opening	mm	m 0
Switching function latching		No
Spring-return		Yes
With front ring		Yes
Material front ring		Plastic
Colour front ring		Black
Degree of protection (IP), front side		IP65
Degree of protection (NEMA)		1

# Approvals

Product Standards	IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CE marking
UL File No.	E29184
UL Category Control No.	NKCR
CSA File No.	46552
CSA Class No.	3211-03
North America Certification	UL listed, CSA certified
Degree of Protection	UL/CSA Type 1

# **Dimensions**



# **Assets (links)**

**Declaration of CE Conformity** 

00002898

**Instruction Leaflets** 

IL04716016Z2018\_05

# **Additional product information (links)**

IL04716016Z (AWA1160-1429) Mounting of components

IL04716016Z (AWA1160-1429) Mounting of components

 $ftp://ftp.moeller.net/DOCUMENTATION/AWA\_INSTRUCTIONS/IL04716016Z2018\_05.pdf$