

Circuit-breaker, 3 p, 400A



Part no. LZMC3-A400-I
111955

| General specifications | |
|---------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Product name | Eaton Moeller series Power Defense molded case circuit-breaker |
| Part no. | LZMC3-A400-I |
| EAN | 4015081115037 |
| Product Length/Depth | 166 millimetre |
| Product height | 275 millimetre |
| Product width | 140 millimetre |
| Product weight | 5.8 kilogram |
| Compliances | RoHS conform |
| Certifications | VDE 0660 IEC/EN 60947 IEC |
| Product Tradename | Power Defense |
| Product Type | Molded case circuit breaker |
| Product Sub Type | None |
| Delivery program | |
| Application | Use in unearthed supply systems at 690 V |
| Type | Circuit breaker |
| Circuit breaker frame type | LZM3 |
| Number of poles | Three-pole |
| Amperage Rating | 400 A |
| Release system | Thermomagnetic release |
| Features | Protection unit Motor drive optional |
| Special features | Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity I _{cn}) Rated current = rated uninterrupted current: 400 A |
| Technical Data - Electrical | |
| Voltage rating | 690 V - 690 V |
| Voltage rating (DC) | 750 V DC |
| Rated insulation voltage (U _i) | 1000 V AC |
| Rated impulse withstand voltage (U _{imp}) at auxiliary contacts | 6000 V |
| Rated impulse withstand voltage (U _{imp}) at main contacts | 8000 V |
| Rated operational current | 500 A (415 V AC-1, making and breaking capacity) 400 A (415 V AC-3, making and breaking capacity) 500 A (380/400 V AC-1, making and breaking capacity) 400 A (660-690 V AC-3, making and breaking capacity) 500 A (690 V AC -1, making and breaking capacity) |
| Rated short-time withstand current (t = 0.3 s) | 3.3 kA |
| Rated short-time withstand current (t = 1 s) | 3.3 kA |
| Instantaneous current setting (I _i) - min | 2400 A |
| Instantaneous current setting (I _i) - max | 4000 A |
| Overload current setting (I _r) - min | 320 A |
| Overload current setting (I _r) - max | 400 A |
| Short delay current setting (I _{sd}) - min | 0 A |
| Short delay current setting (I _{sd}) - max | 0 A |
| Short-circuit release non-delayed setting - min | 2400 A |
| Short-circuit release non-delayed setting - max | 4000 A |
| Rated short-circuit breaking capacity I _{cs} (IEC/EN 60947) at 230 V, 50/60 Hz | 55 kA |
| Rated short-circuit breaking capacity I _{cs} (IEC/EN 60947) at 400/415 V, 50/60 Hz | 36 kA |
| Rated short-circuit breaking capacity I _{cs} (IEC/EN 60947) at 440 V, 50/60 Hz | 22.5 kA |
| Rated short-circuit breaking capacity I _{cs} (IEC/EN 60947) at 525 V, 50/60 Hz | 9 kA |

| | | |
|----------------------------------------------------------------------------------|--|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Rated short-circuit making capacity I _{cm} at 240 V, 50/60 Hz | | 121 kA |
| Rated short-circuit making capacity I _{cm} at 400/415 V, 50/60 Hz | | 76 kA |
| Rated short-circuit making capacity I _{cm} at 440 V, 50/60 Hz | | 63 kA |
| Rated short-circuit making capacity I _{cm} at 525 V, 50/60 Hz | | 24 kA |
| Rated short-circuit making capacity I _{cm} at 690 V, 50/60 Hz | | 14 kA |
| Short-circuit total breaktime | | < 10 ms |
| Electrical connection type of main circuit | | Screw connection |
| Isolation | | 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) |
| Number of operations per hour - max | | 60 |
| Handle type | | Rocker lever |
| Utilization category | | A (IEC/EN 60947-2) |
| Overvoltage category | | III |
| Pollution degree | | 3 |
| Lifespan, electrical | | 5000 operations at 400 V AC-1 2000 operations at 400 V AC-3 3000 operations at 690 V AC-1 2000 operations at 690 V AC-3 |
| Direction of incoming supply | | As required |
| Technical Data - Mechanical | | |
| Mounting Method | | Built-in device fixed built-in technique Fixed |
| Degree of protection | | IP20 In the area of the HMI devices: IP20 (basic protection type) |
| Degree of protection (IP), front side | | IP40 (with insulating surround) IP66 (with door coupling rotary handle) |
| Degree of protection (terminations) | | IP00 (terminations, phase isolator and band terminal) IP10 (tunnel terminal) |
| Protection against direct contact | | Finger and back-of-hand proof to DIN EN 50274/VDE 0106 part 110 |
| Shock resistance | | 20 g (half-sinusoidal shock 20 ms) |
| Number of auxiliary contacts (change-over contacts) | | 0 |
| Number of auxiliary contacts (normally closed contacts) | | 0 |
| Number of auxiliary contacts (normally open contacts) | | 0 |
| Position of connection for main current circuit | | Front side |
| Climatic proofing | | Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 |
| Special features | | Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity I _{cn}) Rated current = rated uninterrupted current: 400 A |
| Lifespan, mechanical | | 15000 operations |
| Technical Data - Mechanical - Terminals | | |
| Standard terminals | | Screw terminal |
| Terminal capacity (copper busbar) | | M10 at rear-side screw connection |
| Terminal capacity (copper solid conductor/cable) | | 16 mm ² - 185 mm ² (1x) at tunnel terminal |
| Design verification as per IEC/EN 61439 - technical data | | |
| Rated operational current for specified heat dissipation (I _n) | | 400 A |
| Equipment heat dissipation, current-dependent | | 72.48 W |
| Design verification as per IEC/EN 61439 | | |
| 10.2.2 Corrosion resistance | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | Meets the product standard's requirements. |
| 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | Meets the product standard's requirements. |
| 10.3 Degree of protection of assemblies | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | Does not apply, since the entire switchgear needs to be evaluated. |

| | | |
|----------------------------------------------------------|--|----------------------------------------------------------------------------------------------------------------------------------|
| 10.6 Incorporation of switching devices and components | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | Is the panel builder's responsibility. |
| 10.9.2 Power-frequency electric strength | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| Additional information | | |
| Functions | | System and cable protection |