DATASHEET - QSA63N0-00/3



Fuse switch-disconnector, 3 pole, rear mounting, 63 A, NH000/NH00, FS0



Part no. Catalog No.

QSA63N0-00/3 1320203

		Fuse-switch-disconnector
		Main switch maintenance switch
		QSA
		optional
		Suitable for DIN fuse-links (blade contacts type)
		Auxiliary contact or neutral conductor fitted by user.
		3 pole
	N/0	0
	N/C	0
		IP00 IP20 with terminal cover
		rear mounting
		$ \begin{array}{cccccccccccccccccccccccccccccccccccc$
l _u	А	63
		Rated uninterrupted current ${\rm I}_{\rm u}$ is specified for max. cross-section.
	Size	NH000/NH00
		IEC/EN 60947, VDE 0660, IEC/EN 60204 Switch-disconnector according to IEC/EN 60947-3
		Switch-disconnector according to IEC/EN 60947-3
θ	°C	Switch-disconnector according to IEC/EN 60947-3
9 9	0° 0° 0°	Switch-disconnector according to IEC/EN 60947-3 CE, RoHs
		Switch-disconnector according to IEC/EN 60947-3 CE, RoHs -25 - +55
		Switch-disconnector according to IEC/EN 60947-3 CE, RoHs -25 - +55 -30 - +80
θ	°C	Switch-disconnector according to IEC/EN 60947-3 CE, RoHs -25 - +55 -30 - +80 III/3
θ U _{imp}	°C kV	Switch-disconnector according to IEC/EN 60947-3 CE, RoHs -25 - +55 -30 - +80 III/3 6
		N/C

Mechanical variables

Number of poles

03/19/2020

3 pole

Auxiliary contacts			
		N/0	0
		N/C	0
Electrical characteristics			
Rated operational voltage	U _e	V AC	690
Rated uninterrupted current	lu	А	63
Note on rated uninterrupted current $\boldsymbol{!}_u$			Rated uninterrupted current $\mathbf{I}_{\mathbf{u}}$ is specified for max. cross-section.
Heat dissipation per pole, current-dependent	P _{vid}	W	2.3

Design verification as per IEC/EN 61439

Technical data for design verification			
Rated operational current for specified heat dissipation	I _n	А	63
Heat dissipation per pole, current-dependent	P _{vid}	W	2.3
Equipment heat dissipation, current-dependent	P _{vid}	W	0
Static heat dissipation, non-current-dependent	P _{vs}	W	0
Heat dissipation capacity	P _{diss}	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	55
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must b observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must b observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.


Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Fuse switch disconnector (EC001040)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Off-load switch, circuit breaker, control switch / Fuse switch disconnector (ecl@ss10.0.1-27-37-14-01 [AKF058013])			
Version as main switch		Yes	
Version as safety switch		No	
Max. rated operation voltage Ue AC	V	690	
Rated permanent current lu	А	63	
Rated operation power at AC-23, 400 V	kW	30	

Conditioned rated short-circuit current Iq	kA	50
Rated short-time withstand current lcw	kA	0
Suitable for fuses		NH000, NH00
Number of poles		3
With error protection		No
Type of electrical connection of main circuit		Screw connection
Cable entry		Other
Equipped with connectors		Yes
Suitable for ground mounting		Yes
Suitable for front mounting 4-hole		No
Suitable for busbar mounting		No
Type of control element		Other
Position control element		Front side
Motor drive optional		No
Motor drive integrated		No
Version as emergency stop installation		No
Degree of protection (IP), front side		IP00

Dimensions



Assets (links)

Declaration of CE Conformity 00003042 Instruction Leaflets IL008010ZU2018_05

Additional product information (links)

IL008010ZU Safety switch-disconnector

IL008010ZU Safety switch-disconnector

ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL008010ZU2018_05.pdf