Changeover switch, RMQ-Titan, With thumb-grip, maintained, 3 positions, Bezel: black $\,$



Part no. M22S-WRK3 216873

D. 1	F. M. W. O. M. MOON.
Product name	Eaton Moeller® series M22 Changeover switch
Part no.	M22S-WRK3
EAN	4015082168735
Product Length/Depth	46 millimetre
Product height	30 millimetre
Product width	30 millimetre
Product weight	0.013 kilogram
Compliances	CE Marked
Certifications	EN 60947-5 CSA Std. C22.2 No. 94-91 CSA Std. C22.2 No. 14-05 UL 508 IEC 60947-5 VDE UL IEC/EN 60947-5 CSA-C22.2 No. 94-91 CSA CSA-C22.2 No. 14-05 UL Category Control No.: NKCR CSA Class No.: 3211-03 CE IEC/EN 60947 CSA File No.: 012528 UL File No.: E29184 VDE 0660
Product Tradename	M22
Product Type	Changeover switch
Product Sub Type	None
eatures & Functions	
Bezel color	Black
Bezel material	Plastic
Color	Black
Design	With thumb-grip
Fitted with:	Front ring Plunger bridge for the middle contact
Functions	Stay-put/spring-return function, can be changed with coding parts M22-XC-Y
General information	
Accessories	Thumb grip
Degree of protection	NEMA 4X, 13
Degree of protection (front side)	IP66
Lifespan, mechanical	100,000 Operations
Opening diameter	22.5 mm
Operating frequency	2000 Operations/h
Operating frequency	0.3 N·m
Product category	RMQ-Titan
Size	Front diameter: 29.7 mm
Switching angle	60 °
Type	Selector switch actuator
	Octobrol Swalter actuator
Ambient conditions, mechanical	
Mounting position	As required
Shock resistance	Mechanical, According to IEC/EN 60068-2-27

Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Description of Pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs OW 10.22 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Interporature rise 10.10 Temperature rise 10.11 Short-circuit rating OW Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Is the panel builder's responsibility. 10.9 Power-frequency electric strength 10.10 Temperature rise Not applicable. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Not applicable. 11.15 Inscripticult rating	Ambient operating temperature - min	-25 °C
Aminior storage temperature - max Climatic proving Communication Commercian to SmartWire-OT Commercian to SmartWire-OT Web SWO-MMS connections Actuator cotor Actuator function Actuator type Actuator function Actuator type Actuator of a work position of working function intriving Toggle Number of working function intriving Toggle Toggle Number of working function intriving Toggle Toggle Number of working function intriving Toggle Toggle Toggle Toggle Number of working function intriving Toggle Toggle Number of working function intriving Toggle To	Ambient operating temperature - max	70 °C
Communication Connection to SmartNive OT Actuator Actuator with SWD-RMIL connections Ministrated Switch product standard in equirements. Actuator type Actuator yipe Actuator yipe Actuator yipe Tinggle Tinggle Actuator yipe Tinggle Actuator yipe Tinggle Actuator yipe Tinggle Tinggle Actuator yipe Tinggle Tinggle Actuator yipe Tinggle Tinggle Actuator yipe Tinggle Ti	Ambient storage temperature - min	40 °C
Communication Connection to SmartWire-DT Actuator Actuator runction Actuator runction Actuator rupe Actuator rupe Actuator rupe Actuator rupe Actuator rupe Actuator rupe Number of events positione Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvol Heat dissipation capacity Profes Liquipment heat dissipation, provident dependent Pvol Heat dissipation, per pub, current-dependent Pvol Heat dissipation, non-current-dependent Pvol Autuator for specification 10.2.2 Verification of resistance of mululing materials to normal heat 10.2.3 Verification of resistance of unfaulting materials to normal heat 10.2.3 Verification of resistance of unfaulting materials to normal heat 10.2.3 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Mechanical impact 10.3 Diagnee of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection and assemblies 10.6 nonections for events and excellence and components 10.7 Internal electrical circuits and connections 10.8 Clearances and creepage distances 10.8 Clearances and creepage distances 10.9 Des on crapply, since the entire switchpear needs to be evaluated. 10.8 Thermal electrical circuits and connections 10.8 Clearances and creepage distances 10.9 Protection and assemblies 10.9 Des on crapply, since the entire switchpear needs to be evaluated. 10.8 Thermal electrical circuits and connections 10.8 Connections for external conductors 10.8 Light panel builder's responsibility. 10.9 Internal electrical circuits and connections 10.1 Thermal electrical circuits and connections 10.1 Thermal electrical circuits and connections 10.1 Thermal electrical circuits and connections 10.2 Thermal electrical circuits and connections 10.3 Thermal electrical circuits and connections 10.4 Thermal electrical circuits and connections 10.5 Thermal electrical circuits and connections 10.5 Thermal electrical circuits and connections 10.6 The development	Ambient storage temperature - max	90 °C
Connection to SmartWee-DT Actuator color Actuator function Actuator type Toggle Number of swetch pastiones Contacts Force for possive opening - min Design verification Equipment head dissipation, current-dependent Pvid UW Head dissipation capacity Pdias Head dissipation per pole, current-dependent Pvid UW Reted dependent current for specified head dissipation (In) Static head dissipation, non-current-dependent Pvs U2.2 Corrosion resistance Meass the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meass the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist on alm. ant. and normal headfuller by internal elect. effects 10.2.3.3 Resist on alm. ant. and normal headfuller by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Dees not apply, since the entire switchgear needs to be evaluated. 10.2.5 Means he product standard's requirements. 10.2.6 Means he product standard's requirements. 10.2.7 Inscriptions Means the product standard's requirements. 10.2.8 Means he product standard's requirements. 10.2.8 Means he product standard's requirements. 10.2.8 Means he product standard's requirements. 10.2.9 Pears—frequency electric strongth 10.2 Pears—frequency electric strongth 10.3 Inscription and connections for the switchgear needs to be evaluated. 10.4 Inscription and connections for the switchgear need t	Climatic proofing	
Actuator function Actuator function Actuator function Actuator function Actuator type Toggle Number of switch positions Contacts Force for positive opening - min Design verification Equipment hart dissipation, current-dependent Pvid Heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Heat dissipation opening - min Design verification Equipment hart dissipation, current-dependent Pvid Heat dissipation opening - min Design verification Equipment hart dissipation, current-dependent Pvid Heat dissipation opening - min Design verification Equipment hart dissipation, current-dependent Pvid Heat dissipation opening - min Design verification Equipment hart dissipation, current-dependent Pvid Read dissipation proble, current-dependent Pvid Read dissipation opening - min Design verification Read dissipation opening - min Design verification Read displation of the control opening - min Design verification 10.2.3 I Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3 Verification of treatmance of insulating materials to normal heast Meets the product standard's requirements. 10.2.3 I Verification of treatmance of insulating materials to normal heast Meets the product standard's requirements. 10.2.3 I Verification of treatmance of insulating materials to normal heast Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Please enquire Dese not apply, since the entire switchaper needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.2.8 Testing point electric bonck Does not apply, since the entire switchaper needs to be evaluated. 10.3 Incarporation of switching devices and components Does not apply, since the entire switchaper needs to be evaluated. 10.4 Clearances and compage distances Meets the product standard's requirements. 10.3 Percection gaine electric to hock 10.6 Incorporation of switching devices and components 10.7 Incarent electric	Communication	
Actuator function Actuator function Actuator function Actuator function Actuator type Actuator type Actuator type Number of switch positions Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Equipment heat dissipation of apacity Pdiss Actuator for specification Equipment heat dissipation, current-dependent Pvid Heat dissipation of apacity Pdiss Actuator for specification of resistance of insulating materials to normal heat dissipation one-current for specification of thermal stability of enclosures 102.3.1 Verification of thermal stability of enclosures 102.3.2 Verification of thermal stability of enclosures 102.3.2 Verification of resistance of insulating materials to normal heat 102.3.2 Resist of insul. mat. to shoormal heatfire by internal elect. effects 102.4 Resistance to ultra-violet (UV) rediation 102.5 Ufficing 102.5 Ufficing 102.6 Mechanical impact 102.7 Inscriptions Actuator capacity education of essentibles 103.0 Resistance and creepage distances 104.0 Clearances and creepage distances 105.0 Protection of gainst lead of sequipments. 106.1 Clearances and creepage distances 107.1 Inscriptions 108.0 Connections of existicing devices and components 109.0 Peans not apply, since the entire switchgear needs to be evaluated. 109.0 Inscriptions 109.0 Peans not apply, since the entire switchgear needs to be evaluated. 109.1 Instrain electrical circuits and connections 109.2 Power-frequency electric strength 109.3 Insuring of enclosures made of insulating material 101.1 Timperature rise 101.1 Timperature rise 101.1 Short-circuit rating Les the panel builder's responsibility. Les the panel buil	Connection to SmartWire-DT	
Actuator function Maintained Switching anticin latching Actuator type Toggle Number of switch positions Torgle Number of switch positions Torgle Solidacts Force for positive opening - min Design verification Equipment head dissipation, current-dependent Prid Heat dissipation, current-dependent Prid Heat dissipation, current-dependent Prid Heat dissipation capacity Pdiss Heat dissipation current or specified heat dissipation fin Static heat dissipation, non-current-dependent Prid Heat dissipation, current-dependent Prid Heat dissipat	Actuator	
Actuator type Actuator type Actuator type Actuator type Bosine of switch positions Contacts Force for positive opening · min Design verification Equipment hoat dissipation, current-dopendent Pvid Heat dissipation per pole, current-dependent Pvid Ratud operational current for specified heat dissipation (In) Static beat dissipation, non-current-dependent Pvi 10.2.2 Corrosion resistance 10.2.3.1 Verification of resistance of insulating materials to normal heat 10.2.3.1 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance to ultra-violet (UV) radiation 10.2.3.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.3.1 Degree of protection of assemblies 10.3.2 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.3.2 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock. 10.6 Incorporation of Switchgear eneeds to be evaluated. 10.6 Incorporation of switchgear eneeds to be evaluated. 10.7 Internal electrical circuits and connections 10.8 Life connections for external conductors 10.9 Life connections for external conductors 10	Actuator color	Black
Number of switch positions Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation expacity Pdiss OW Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation resistance Meets the product standard's requirements. 102.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.2.3 Verification of resistance of insulating materials to normal heat 102.2.3 Verification of resistance of unsulating materials to normal heat 102.2.3 Resists of insul. mat to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 102.4 Resistance to ultra-violet (I/V) rediation 102.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.6 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 103.6 Degree of protection of sessenblies Does not apply, since the entire switchgear needs to be evaluated. 104.7 Incernal electrical circuits and connections Meets the product standard's requirements. 105. Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 106.8 Incorporation of switching devices and components 107.1 Internal electrical circuits and connections Is the panel builder's responsibility. 108.8 Connections for external conductors Is the panel builder's responsibility. 109.4 Power-frequency electric strength 109.5 Resign of anciosures made of insulating material 101.1 Temperature rise Not applicable. 101.1 Short-circuit rating 101.10 Temperature rise Not applicable. 101.13 Mechanical function The device meets the requirements, provided the information in the instruction	Actuator function	
Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Rated operational for settlements. Resist he product standard's requirements. Resist he product standard's requirements. Resist he product standard's requirements. Resist he product standard's requirements on the entire switchgear needs to be evaluated. Resist he product standard's requirements on the entire switchgear needs to be evaluated. Resist he product standard's requirements on the entire switchgear needs to be evaluated. Resist he panel builder's responsibility. Resist he panel builder's responsibility. Re	Actuator type	Toggle
Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pfiles OW Heat dissipation per pole, current-dependent Pvid OW Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid OW 10.22 Corrosion resistance 10.23.1 Varification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.2 Verification of treatment stability of enclosures Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. 10.3 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. 10.4 Internal electrical recitues and connections Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's respo	Number of switch positions	3
Design verification Equipment heat dissipation, current-dependent Pvid 0W Heat dissipation capacity Pdiss 0W Rated operational current for specified heat dissipation (In) Static heat dissipation, per pole, current-dependent Pvid 0W Rated operational current for specified heat dissipation (In) 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of thermal stability of enclosures 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist of insul. At to abnormal heat/fire by internal elect. effects 10.24.2 Resistance to ultra-violet (UV) radiation 10.25 Lifting 10.26 Mechanical impact 10.27 Inscriptions 10.3 Degree of protection of assemblies 10.3 Degree of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Instantal electrical circuits and connections 10.7 Instantal electrical circuits and connections 10.8 Connections for external conductors 10.9 Protection of assemblies 10.9 Protection against electric shock 10.9 Encorporation of switching devices and components 10.9 Protection against electric shock 10.9 Encorporation of switching devices and components 10.9 Connections for axternal conductors 10.9 Instantal electrical circuits and connections 10.1 Instantal electrical circuits and connect	Contacts	
Requipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss OW Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (in) Static heat dissipation, non-current-dependent Pvs OW Static heat dissipation, non-current-dependent Pvs OW Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.5 Internal electrical circuits and components 10.6 Connections for external conductors In Sincerporation of switching devices and components 10.9 Opened to ply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Opened to ply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Opened to protection of external conductors Is the panel builder's responsibility. 10.9 Protection against electric strength In the panel builder's responsibility. 10.9 Protection against electric strength In the panel builder's responsibility. 10.9 Internal electric strength In the panel builder's responsibility. 10.1 Temperature rise Not applicable. 10.1 Temperature rise Not applicable. 10.1 Short-circuit rating 10.13 Mechanical function The device meets the requirements, provided the information	Force for positive opening - min	0 N
Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24.4 Resistance to ultra-violet (UV) radiation 10.25 Lifting 0 Does not apply, since the entire switchgear needs to be evaluated. 10.26 Mechanical impact 10.27 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electric circuits and connections 10.8 Connections for external conductors 10.9 Protection against electric strongth 10.9 Protection against electric strongth 10.9 Internal electric strongth 10.10 Internal electric strongth 10.11 Internal electric strongth 10.12 Electr	Design verification	
Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist, of insul, mat, to abnormal heat/fire by internal elect, effects 10.24.3 Resistance to ultra-violet (UV) radiation Please enquire 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength 10.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating Lis the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Lis the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Equipment heat dissipation, current-dependent Pvid	0 W
Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Nesist, of insul, mat, to abnormal heat/fire by internal elect, effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.1 Internal electrication of insulating material 10.1 Internal electrication of insulating material 10.1 Internal electrication of external conductors 10.1 Internal electric active strength 10.2 Internal electric active strength 10.3 Impulse withstand voltage 10.4 Electromagnetic compatibility 10.5 the panel builder's responsibility. The specifications for the switchgear must be observed. 10.11 Short-circuit rating 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Heat dissipation capacity Pdiss	0 W
Static heat dissipation, non-current-dependent Pys 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting 10.26 Mechanical impact 10.27 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 A Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. 10.Weets the product standard's requirements. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Encorporation of switching devices and components 10.Encorporation of switching devices and components 10.Encorporation of switching devices and connections 10.1 Is the panel builder's responsibility. 10.9 Power-frequency electric strength 10.1 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.15 Mechanical function 10.16 Meets the product standard's requirements. 10.17 Meets the product standard's requirements. 10.18 Meets the product standard's requirements. 10.19 Meets the product standard's requirements. 10.19 Does not apply, since the entire switchgear needs to be evaluated. 10.19 Does not apply, since the entire switchgear needs to be evaluated. 10.19 Temperature responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function	Heat dissipation per pole, current-dependent Pvid	0 W
Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.9.4 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. In the device meets the requirements, provided the information in the instruction of the switchgear must be observed.	Rated operational current for specified heat dissipation (In)	0 A
10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.1 Experimental impact 10.9.1 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Incorporation of switching devices and components 10.17 Internal electrical circuits and connections 10.18 Lepanel builder's responsibility. 10.19 Temperature rise 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Metropout standard's requirements. 10.29 Meets the product standard's requirements. 10.20 Does not apply, since the entire switchgear needs to be evaluated. 10.16 Meets the product standard's requirements. 10.29 Power-frequency electric shock 10.20 Does not apply, since the entire switchgear needs to be evaluated. 10.21 Electromagnetic compatibility. 10.22 Power-frequency electric strength 10.24 Testing of enclosures made of insulating material 10.25 Legendard's responsibility. 10.26 Legendard's responsibility. 10.27 Legendard's responsibility. 10.28 Legendard's responsibility. 10.29 Legendard's responsibility. 10.29 Legendard's responsibility. 10.20 Legendard's responsibility. 10.29 Legendard's r	Static heat dissipation, non-current-dependent Pvs	0 W
10.2.32 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Meets the product standard's requirements. 10.2 Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Is the panel builder's responsibility. 10.9.1 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Meets the product standard's requirements. 10.16 Meets the product standard's requirements. 10.17 Meets the product standard's requirements. 10.18 Meets the product standard's requirements. 10.19	10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation Please enquire 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Lis the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction.	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation Please enquire Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.2.4 Resistance to ultra-violet (UV) radiation	Please enquire
10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. In the panel builder's responsibility.	10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10 Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. Not applicable. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.7 Inscriptions	Meets the product standard's requirements.
10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. 10 the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Internal electrical circuits and connections 10.16 Is the panel builder's responsibility. 10.17 Is the panel builder's responsibility. 10.18 Is the panel builder's responsibility. 10.19 Is the panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.19 Mechanical function 10.19 The device meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Steppen builder's responsibility. 10.15 Is the panel builder's responsibility. 10.16 Is the panel builder's responsibility. 10.17 Internal electrical circuits and connections 10.18 the panel builder's responsibility. 10.19 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.19 Mechanical function 10.19 The device meets the requirements, provided the information in the instruction	10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Strength	10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 When the panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 The device meets the requirements, provided the information in the instruction	10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Step panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 The device meets the requirements, provided the information in the instruction	10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Not applicable. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.10 Temperature rise	Not applicable.
observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
	10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
	10.13 Mechanical function	

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Front element for selector switch (EC000222)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for selector switches (ecl@ss13-27-37-12-13 [AKF031019])

[AKF031019])		
Number of switch positions	3	
Type of control element	Toggle	
Suitable for illumination	No	
Colour control element	Black	
Colour indicator light cap	Other	

Construction type lens		Round
Hole diameter	mm	22.5
Width opening	mm	0
Height opening	mm	0
Switching function latching		Yes
Spring-return		No
With front ring		Yes
Material front ring		Plastic
Colour front ring		Black
Degree of protection (IP), front side		IP66
Degree of protection (NEMA)		4X, 13