## DATASHEET - Q25S3R-A2



# Key-operated actuator, 3 positions, black, maintained

Powering Business Worldwide™

Part no. **Q25S3R-A2** Catalog No. 072380 Alternate Catalog Q25S3R-A2 No.

**Delivery program** 

Product range	RMQ16
Basic function	Key-operated buttons
Single unit/Complete unit	Single unit
Design	Key operated
	maintained
Function:	
	45° # 45°
	3 positions
Key withdrawable in position	
	0
Degree of Protection	IP65
Front ring	without bezel
Connection to SmartWire-DT	no
Front dimensions	Front dimensions 25 × 25 mm
Information about equipment supplied	With 1 key

#### **Technical data** General

Standards			IEC/EN 60947
Lifespan, mechanical	Operations	x 10 <sup>6</sup>	>3
Operating frequency	Operations/h		≦ 1800
Operating torque		Nm	≦ 0.4
Degree of protection, IEC/EN 60529			IP65
Climatic proofing			Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
Ambient temperature			
Open		°C	-25 - +60
Enclosed		°C	- 25 - 40
Mounting position			As required
Mechanical shock resistance		g	> 40 according to IEC 60068-2-27 Shock duration 11 ms Sinusoidal
Terminal capacities		$mm^2$	0.5 - 1.0
Blade terminal			2.8 x 0.8 mm to DIN 46244
Fast-on connectors			2.8 x 0.8 mm to DIN 46247 and IEC 60760
Contacts			
But the state of t			000

OUIIL	1013	
Rated	impulse	١

Contacts			
Rated impulse withstand voltage	$U_{\text{imp}}$	V AC	800
Rated insulation voltage	Ui	V	250
Overvoltage category/pollution degree			III/3
Rated operational voltage	U <sub>e</sub>	V AC	24
Control circuit reliability			
at 24 V DC/5 mA	$H_{F}$	Fault probabilit	< 10 <sup>-7</sup> , < 1 failure in 10 <sup>7</sup> operations
at 5 V DC/1 mA	H <sub>F</sub>	Fault probabilit	$< 5 \times 10^{-6}$ , $< 1$ failure in $5 \times 10^{6}$ operations
Use of insulated ferrule ISH 2,8			On >24 V AC/DC recommended On >50 V AC or 120 V DC mandatory, also on unoccupied blade terminals

# Design verification as per IEC/EN 61439

Technical data for design verification

Rated operational current for specified heat dissipation In A 0  Heat dissipation per pole, current-dependent P <sub>vid</sub> W 0  Equipment heat dissipation, current-dependent P <sub>vid</sub> W 0  Static heat dissipation, non-current-dependent P <sub>vs</sub> W 0  Heat dissipation capacity P <sub>diss</sub> W 0	
Equipment heat dissipation, current-dependent $P_{vid}$ W 0  Static heat dissipation, non-current-dependent $P_{vs}$ W 0	
Static heat dissipation, non-current-dependent $P_{vs}$ W 0	
Heat dissipation capacity P <sub>diss</sub> W 0	
1 1 7	
Operating ambient temperature min. °C -25	
Operating ambient temperature max. °C 60	
IEC/EN 61439 design verification	
10.2 Strength of materials and parts	
10.2.2 Corrosion resistance Meets the product standard's requirements.	
10.2.3.1 Verification of thermal stability of enclosures  Meets the product standard's requirements.	
10.2.3.2 Verification of resistance of insulating materials to normal heat  Meets the product standard's requirements.	
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects  Meets the product standard's requirements.	
10.2.4 Resistance to ultra-violet (UV) radiation	
10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated.	
10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated.	
10.2.7 Inscriptions  Meets the product standard's requirements.	
10.3 Degree of protection of ASSEMBLIES  Does not apply, since the entire switchgear needs to be evaluated.	
10.4 Clearances and creepage distances  Meets the product standard's requirements.	
10.5 Protection against electric shock  Does not apply, since the entire switchgear needs to be evaluated.	
10.6 Incorporation of switching devices and components  Does not apply, since the entire switchgear needs to be evaluated.	
10.7 Internal electrical circuits and connections Is the panel builder's responsibility.	
10.8 Connections for external conductors Is the panel builder's responsibility.	
10.9 Insulation properties	
10.9.2 Power-frequency electric strength Is the panel builder's responsibility.	
10.9.3 Impulse withstand voltage Is the panel builder's responsibility.	
10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility.	
10.10 Temperature rise Not applicable.	
10.11 Short-circuit rating  Is the panel builder's responsibility. The specifications for the switchg observed.	ar must be
10.12 Electromagnetic compatibility  Is the panel builder's responsibility. The specifications for the switchg observed.	ar must be
10.13 Mechanical function  The device meets the requirements, provided the information in the installed (IL) is observed.	truction

### **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Front element for selector switch (EC000222)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for selector switches (ecl@ss10.0.1-27-37-12-13 [AKF031014])


[AKF031014])		
Number of switch positions		3
Type of control element		Key
Suitable for illumination		No
Colour control element		Black
Colour indicator light cap		Other
Construction type lens		Square
Hole diameter	mm	16
Width opening	mm	0
Height opening	mm	0
Switching function latching		Yes
Spring-return		No
With front ring		Yes
Material front ring		Plastic
Colour front ring		Black
Degree of protection (IP), front side		IP65

Degree of protection (NEMA)	1	

## **Approvals**

Product Standards	IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CE marking
UL File No.	E29184
UL Category Control No.	NKCR
CSA File No.	46552
CSA Class No.	3211-03
North America Certification	UL listed, CSA certified
Degree of Protection	UL/CSA Type 1

### **Dimensions**



Square style

## **Assets (links)**

**Declaration of CE Conformity** 

00002898

**Instruction Leaflets** 

IL04716016Z2018\_05

### **Additional product information (links)**

IL04716016Z (AWA1160-1429) Mounting of components

IL04716016Z (AWA1160-1429) Mounting of

ftp://ftp.moeller.net/DOCUMENTATION/AWA\_INSTRUCTIONS/IL04716016Z2018\_05.pdf