## **DATASHEET - CI-K2H-T3-4**



Insulated enclosure, for T3-4

Part no. CI-K2H-T3-4 Catalog No. 105859



# **Delivery program**

| Basic function                       | insulated enclosure         |
|--------------------------------------|-----------------------------|
|                                      | with metric knock-outs      |
| For use with                         | T3/Z                        |
| For use with                         | 3 - 4 contact units         |
| Information about equipment supplied | with an additional PE clamp |
| Degree of Protection                 | IP65                        |
| Notes 1 contact unit = 2 contacts    |                             |

# **Design verification as per IEC/EN 61439**

| Design vermeation as per 126/214 01433  |                   |    |  |
|---|-------------------|----|--|
| Technical data for design verification  |                   |    |  |
| Rated operational current for specified heat dissipation  | In                | Α  | 0  |
| Heat dissipation per pole, current-dependent  | P <sub>vid</sub>  | W  | 0  |
| Equipment heat dissipation, current-dependent   | P <sub>vid</sub>  | W  | 0  |
| Static heat dissipation, non-current-dependent  | P <sub>vs</sub>   | W  | 0  |
| Heat dissipation capacity   | P <sub>diss</sub> | W  | 18.5   |
| Operating ambient temperature min.  |                   | °C | -25  |
| Operating ambient temperature max.  |                   | °C | 40   |
| Max. radiated heat dissipation with separate mounting, ambient air temperature +20 $^{\circ}\text{C}$                     |                   | W  | 18.5   |
| IEC/EN 61439 design verification  |                   |    |  |
| 10.2 Strength of materials and parts  |                   |    |  |
| 10.2.2 Corrosion resistance   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $$ |                   |    | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation  |                   |    | Meets the product standard's requirements.   |
| 10.2.5 Lifting  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions   |                   |    | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances  |                   |    | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections   |                   |    | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors  |                   |    | Is the panel builder's responsibility.   |
| 10.9 Insulation properties  |                   |    |  |
| 10.9.2 Power-frequency electric strength  |                   |    | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage  |                   |    | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material  |                   |    | Is the panel builder's responsibility.   |
| 10.10 Temperature rise  |                   |    | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating  |                   |    | Is the panel builder's responsibility. The specifications for the switchgear must b observed.                                    |
| 10.12 Electromagnetic compatibility   |                   |    | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
|   |                   |    |  |


#### **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Empty enclosure for switchgear (EC000712)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Empty housing for switch devices (ecl@ss10.0.1-27-37-13-01 [AKN343014])

| (eci@ss10.0.1-21-31-13-01 [AKN343014]) |   |    |                  |
|--|---|----|------------------|
| Material housing                       |   |    | Plastic          |
| Width                                  | m | nm | 100              |
| Height                                 | m | nm | 181              |
| Depth                                  | m | nm | 100              |
| With transparent cover                 |   |    | No               |
| Suitable for emergency stop            |   |    | No               |
| Model                                  |   |    | Surface mounting |
| Degree of protection (IP)              |   |    | IP65             |
| Degree of protection (NEMA)            |   |    | Other            |

#### **Dimensions**



### **Assets (links)**

**Instruction Leaflets** 

IL01502081Z2018\_05

### **Additional product information (links)**

| IL01502081Z (AWA3210-1735) Insulated small enclosures |  |  |  |  |
|---|--|--|--|--|
| IL01502081Z (AWA3210-1735) Insulated small enclosures | ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL01502081Z2018_05.pdf              |  |  |  |
| Technical overview cam switch, switch-disconnector    | http://de.ecat.moeller.net/flip-cat/?edition=HPLTEv1&startpage=4.2                       |  |  |  |
| System overview cam switch T                          | http://de.ecat.moeller.net/flip-cat/?edition=HPLTEv1&startpage=4.4                       |  |  |  |
| System overview switch-disconnector P                 | http://de.ecat.moeller.net/flip-cat/?edition=HPLTEv1&startpage=4.6                       |  |  |  |
| Key to part numbers Cam switch                        | http://de.ecat.moeller.net/flip-cat/?edition=HPLTEv1&startpage=4.8                       |  |  |  |
| Key to part numbers Switch-disconnector               | http://de.ecat.moeller.net/flip-cat/?edition=HPLTEv1&startpage=4.8                       |  |  |  |
| Switches for ATEX                                     | http://www.coopercrouse-hinds.eu/en/products/25-ex-safety-and-main-current-switches.html |  |  |  |