

Diaphragm bolt, M20



Part no. EMS20
225271

| General specifications | | |
|--|--|--|
| Product name | | Eaton Moeller® series LS Accessory Membrane screw |
| Part no. | | EMS20 |
| EAN | | 4015082252717 |
| Product Length/Depth | | 24 millimetre |
| Product height | | 15 millimetre |
| Product width | | 24 millimetre |
| Product weight | | 0.028 kilogram |
| Compliances | | CE |
| Product Tradename | | LS |
| Product Type | | Accessory |
| Product Sub Type | | Membrane screw |
| Features & Functions | | |
| Features | | External diameter of cable up to 13 mm |
| Fitted with: | | Integral push-through diaphragm |
| General information | | |
| Accessory/spare part type | | Accessory |
| Degree of protection | | IP65 IP65, with cable inserted |
| Product category | | Accessories |
| Climatic environmental conditions | | |
| Ambient operating temperature - min | | -25 °C |
| Ambient operating temperature - max | | 70 °C |
| Design verification | | |
| Equipment heat dissipation, current-dependent Pvid | | 0 W |
| Heat dissipation capacity Pdis | | 0 W |
| Heat dissipation per pole, current-dependent Pvid | | 0 W |
| Rated operational current for specified heat dissipation (In) | | 0 A |
| Static heat dissipation, non-current-dependent Pvs | | 0 W |
| 10.2.2 Corrosion resistance | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | Meets the product standard's requirements. |
| 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | Please enquire |
| 10.2.5 Lifting | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | Meets the product standard's requirements. |
| 10.3 Degree of protection of assemblies | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | Is the panel builder's responsibility. |
| 10.9.2 Power-frequency electric strength | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | Not applicable. |
| 10.11 Short-circuit rating | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |

| | | | |
|-------------------------------------|--|--|--|
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 9.0

| | | | |
|--|--|--|-------|
| Low-voltage industrial components (EG000017) / Accessories/spare parts for command devices (EC002024) | | | |
| Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Command and alarm device (accessories) (ecl@ss13-27-37-12-92 [AC0037015]) | | | |
| Type of electrical accessory/spare part | | | Other |
| Type of mechanical accessory/spare part | | | Other |
| Accessory | | | Yes |
| Spare part | | | No |