Control circuit terminal, screw connection



Part no. NZM2-XSTS 260156

EL Number 4358736

(Norway)

(INUI Way)		
General specifications		
Product name	Eaton Moelle	series NZM connection type
Part no.	NZM2-XSTS	
EAN	401508260156	
Product Length/Depth	21 millimetre	
Product height	12.5 millimetro	
Product width	25 millimetre	
Product weight	0.02 kilogram	
Compliances	UL/CSA IEC RoHS conform	1
Certifications	UL (File No. E CSA-C22.2 No UL listed CSA (File No. UL (Category CSA (Class N IEC60947 UL489 CSA certified CE marking	. 5-09 22086) Control Number DIHS)
Product Tradename	NZM	
Product Type	Accessories	
Product Sub Type	Connection ty	pe
Delivery program		
Туре	Accessory Co	ntrol circuit terminal Terminal
Number of poles	Three-pole/Fo	ur-pole
Frame	NZM2	
Suitable for	Screw conne Single-pole	etion
Used with	NZM2(-4), PN	2(-4), N(S)2(-4)
Technical Data - Mechanical - Terminals		
Terminal capacity (stranded cable)	0.75 mm² - 2.5 0.75 mm² - 1.5 18 - 14 AWG/k 18 - 16 AWG/k	mm² (2x) cmil (1x)
Design verification as per IEC/EN 61439		
10.2.2 Corrosion resistance	Meets the pro	duct standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures	Meets the pro	duct standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the pro	duct standard's requirements.
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects		
	Meets the pro	duct standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation		duct standard's requirements. duct standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting	Meets the pro	
	Meets the pro	duct standard's requirements.
10.2.5 Lifting	Meets the pro Does not app	duct standard's requirements. y, since the entire switchgear needs to be evaluated.
10.2.5 Lifting 10.2.6 Mechanical impact	Meets the pro Does not app Does not app Meets the pro	duct standard's requirements. y, since the entire switchgear needs to be evaluated. y, since the entire switchgear needs to be evaluated.
10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions	Meets the pro Does not appi Does not appi Meets the pro Does not appi	duct standard's requirements. y, since the entire switchgear needs to be evaluated. y, since the entire switchgear needs to be evaluated. duct standard's requirements.
10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies	Meets the pro Does not appl Does not appl Meets the pro Does not appl Meets the pro	duct standard's requirements. y, since the entire switchgear needs to be evaluated. y, since the entire switchgear needs to be evaluated. duct standard's requirements. y, since the entire switchgear needs to be evaluated.
10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances	Meets the pro Does not appi Does not appi Meets the pro Does not appi Meets the pro Does not appi	duct standard's requirements. y, since the entire switchgear needs to be evaluated. y, since the entire switchgear needs to be evaluated. duct standard's requirements. y, since the entire switchgear needs to be evaluated. duct standard's requirements.
10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock	Meets the pro Does not appi Does not appi Meets the pro Does not appi Meets the pro Does not appi Does not appi	duct standard's requirements. y, since the entire switchgear needs to be evaluated. y, since the entire switchgear needs to be evaluated. duct standard's requirements. y, since the entire switchgear needs to be evaluated. duct standard's requirements. y, since the entire switchgear needs to be evaluated.
10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components	Meets the pro Does not appl Does not appl Meets the pro Does not appl Meets the pro Does not appl Does not appl Does not appl Is the panel b	duct standard's requirements. y, since the entire switchgear needs to be evaluated. y, since the entire switchgear needs to be evaluated. duct standard's requirements. y, since the entire switchgear needs to be evaluated. duct standard's requirements. y, since the entire switchgear needs to be evaluated. y, since the entire switchgear needs to be evaluated.
10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections	Meets the pro Does not appi Does not appi Meets the pro Does not appi Meets the pro Does not appi Does not appi Is the panel b	duct standard's requirements. y, since the entire switchgear needs to be evaluated. y, since the entire switchgear needs to be evaluated. duct standard's requirements. y, since the entire switchgear needs to be evaluated. duct standard's requirements. y, since the entire switchgear needs to be evaluated. y, since the entire switchgear needs to be evaluated. y, since the entire switchgear needs to be evaluated.
10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors	Meets the pro Does not appi Does not appi Meets the pro Does not appi Meets the pro Does not appi Does not appi Is the panel b	duct standard's requirements. y, since the entire switchgear needs to be evaluated. y, since the entire switchgear needs to be evaluated. duct standard's requirements. y, since the entire switchgear needs to be evaluated. duct standard's requirements. y, since the entire switchgear needs to be evaluated. y, since the entire switchgear needs to be evaluated. y, since the entire switchgear needs to be evaluated. uilder's responsibility.

10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
Additional information	
Model	Other

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Wiring set for power circuit breaker (EC002050)		
Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Wiring set for circuit breaker (ecl@ss13-27-37-04-24 [ACN957016])		
Suitable for number of poles	1	
Model	Other	