



## Residual-current circuit breaker trip block for PLS. 40A, 3 p, 100mA, type A



**Part no.**  
**Catalog No.**

**PBSM-403/01-A-MW**  
**262544**

Similar to illustration

## Delivery program

Basic function			Add-on residual current protection unit
Number of poles			3 pole
Application			Switchgear for residential and commercial applications
Rated current	$I_n$	A	40
Rated short-circuit strength	$I_{cn}$	kA	same as connected PLS up to max. 10
Rated fault current	$I_{\Delta N}$	A	0.1
Type			Type A
Tripping		s...	non-delayed
Product range			PBSM
Sensitivity			Pulse-current sensitive
Impulse withstand current			Partly surge-proof 250 A

## Technical data

### Electrical

Rated frequency	f	Hz	50
Sensitivity			Pulse-current sensitive
Rated current	$I_n$	A	40
Rated impulse withstand voltage	$U_{imp}$	kV	4
lifespan			
Electrical	Operations		$\geq 4000$
Mechanical	Operations		$\geq 20000$

### Mechanical

Standard front dimension		mm	45
Device height		mm	90
Built-in width		mm	107.5 (3TE)
Mounting			fix mounted onto PLS
Degree of Protection			IP40, IP54 (with moisture-proof enclosure)
Terminals top and bottom			Lift terminals
Terminal protection			BGV A3, ÖVE-EN 6
Thickness of busbar material		mm	0.8 - 2
Permissible storage and transport temperatures		°C	-35 - +60
Climatic proofing			25-55°C/90-95% relative humidity according to IEC 60068-2

## Design verification as per IEC/EN 61439

Technical data for design verification			
Rated operational current for specified heat dissipation	$I_n$	A	40
Heat dissipation per pole, current-dependent	$P_{vid}$	W	0
Equipment heat dissipation, current-dependent	$P_{vid}$	W	20
Static heat dissipation, non-current-dependent	$P_{vs}$	W	0
Heat dissipation capacity	$P_{diss}$	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	40
			Starting at 40 °C, the max. permissible continuous current decreases by 3% for every 1 °C
IEC/EN 61439 design verification			

10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

## Technical data ETIM 7.0

Circuit breakers and fuses (EG000020) / Residual current circuit breaker (RCCB) (EC000003)

Electric engineering, automation, process control engineering / Electrical installation, device / Residual current protection system / Residual current circuit breaker (RCCB)  
(ecI@ss10.0.1-27-14-22-01 [AAB906014])

Number of poles			3
Rated voltage		V	400
Rated current		A	40
Rated fault current		mA	100
Rated insulation voltage Ui		V	440
Rated impulse withstand voltage Uimp		kV	4
Mounting method			DIN rail
Leakage current type			A
Selective protection			No
Short-time delayed tripping			No
Short-circuit breaking capacity (Icw)		kA	0
Surge current capacity		kA	0.25
Frequency			50 Hz
Additional equipment possible			Yes
With interlocking device			Yes
Degree of protection (IP)			IP20
Width in number of modular spacings			6.14
Built-in depth		mm	70
Ambient temperature during operating		°C	-25 - 40
Pollution degree			2
Connectable conductor cross section multi-wired		mm <sup>2</sup>	0.75 - 16
Connectable conductor cross section solid-core		mm <sup>2</sup>	0.75 - 16