HALT/STOP-Button, RMQ-Titan, Mushroom-shaped, 38 mm, Non-illuminated, Turn-to-release function, Black, yellow, RAL 9005



Part no. M22S-PVT 271499

| General specifications Product name | Eaton Moeller® series M22 Emergency stop/emergency switching off pushbutt |
|--------------------------------------|--|
| Part no. | M22S-PVT |
| | |
| EAN | 4015082714994 |
| Product Length/Depth | 38 millimetre |
| Product height | 70 millimetre |
| Product width | 38 millimetre |
| Product weight | 0.045 kilogram |
| Compliances | CE Marked |
| Certifications | CSA Std. C22.2 No. 14-05 CSA Std. C22.2 No. 94-91 EN 60947-5 IEC 60947-5 UL 508 VDE CSA Class No.: 3211-03 CSA File No.: 012528 IEC/EN 60947-5 CSA-C22.2 No. 94-91 VDE 0660 IEC/EN 60947 CSA UL Category Control No.: NKCR UL File No.: E29184 CE UL CSA-C22.2 No. 14-05 GL DNV LR |
| Product Tradename | M22 |
| Product Type | Emergency stop/emergency switching off pushbutton |
| Product Sub Type | None |
| | Nulle |
| Features & Functions | |
| Bezel color | Other |
| Base color | Yellow |
| Bezel material | Other |
| Color | Black |
| Design | Mushroom-shaped Classical |
| Illumination | Non-illuminated |
| RAL-number | 9005 |
| Unlocking method | Turn-release |
| General information | |
| Degree of protection | IP67/IP69K NEMA 4X, 13 |
| Lifespan, mechanical | 100,000 Operations |
| Opening diameter | 22.5 mm |
| Operating frequency | 600 Operations/h |
| Product category | RMQ-Titan |
| Size | Front dimensions: 35 mm |
| Туре | Emergency stop pushbutton STOP pushbutton |
| Ambient conditions, mechanical | |
| Mounting position | As required |
| Shock resistance | Mechanical, According to IEC/EN 60068-2-27 50 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms |

| observed. | Climatic environmental conditions | |
|--|--|--|
| Communication Connection to SmartWire-DT Actuator Actuator Actuator Actuator Actuator Signature Actuator Sig | Ambient operating temperature - min | -25 °C |
| Communication Communication Communication Communication to SmartWer-UT Actuation force Actuation force Actuation force Actuation force Actuation force Actuation diameter Actuation function Contacts Fure for positive opening - min Design verification Equipment heat dissipation, current dependent Pvid Heat dissipation, capacity Prios UN Rated operational capacity Prios UN UN Rated operational capacity Prios UN Rated operational capacity Prios UN UN Rated operational capacity Prios UN Rated operational capacity Prios UN Rated operational capacity Prios UN UN UN Rated operational capacity Prios UN UN UN Rated operational capacity Prios UN UN UN UN UN UN UN UN UN U | Ambient operating temperature - max | 70 °C |
| Actuator Actuator color Actuator recion Actuator function Switching function latching Turn to-reliease Force for positive openings - min Dosign verification Equipment head dissipation, current-dependent Pvid Dow Head dissipation, capacity Pdiss Dow Head dissipation, on-current-dependent Pvid Dow Head dissipation of profic, current-dependent Pvid Dow Head dissipation on profic, current-dependent Pvid Dow Head dissipation, non-current dispendent Pvid Dow Head dissipation, non-current dispendent Pvid Dow Head dissipation, non-current-dependent Pvi | Climatic proofing | |
| Actuator Actuator of Parameter Sin N Actuator color Actuator diameter Sin N Actuator diameter Sin N Actuator color Actuator diameter Sin N Busich Record Sin N Busich Sin Sin N Busich Si | Communication | |
| Actuator color Actuator fameter Actuator fameter Actuator fameter Actuator function Contacts Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation appaic, current-dependent Pvid Heat dissipation appaic, profise Attact dissipation appaic, current-dependent Pvid Attact dissipation propie, current for specified heat dissipation (in) Attact dissipation propie, current for propied distance of insulating materials to normal heat dissipation of thermal stability of enclosures 10.2.3 I Verification of resistance of insulating materials to normal heat 10.2.3 Verification of thermal stability of enclosures 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 (Ifing 10.2.6 Meets the product standard's requirements. 10.2.6 Meets the product standard's requirements. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Depretation of assemblies 10.4 Clearnoces and creapage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearnoces and creapage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Interportation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Length of the en | Connection to SmartWire-DT | |
| Actuator color Actuator fameter Actuator function Switching function latching function release Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Prid Heat dissipation, current-dependent Prid Heat dissipation, current-dependent Prid Heat dissipation capacity Pdiss Net dissipation on a current respected heat dissipation (in) Static heat dissipation, one current-dependent Prid OW Heat dissipation, non-current-dependent Prid OW Static heat dissipation, non-current-dependent Prid 10.2.2 Torosion resistance Meets the product standard's requirements. 10.2.3 Verification of resistance of insulating materials to normal heat 10.2.3 Verification of resistance of insulating materials to normal heat 10.2.3 Verification or resistance of insulating materials to normal heat 10.2.4 Static heat dissipation, unat to shonrmal heat/fire by internal elect. effects 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.2.8 Mechanical impact 10.9 protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.2 Power-frequency electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and revepoge distances 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Clearances and revepoge distances 10.9 Protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and components 10.8 Interportation of assemblies 10.9 Protection of assemblies 10.1 Internal electrical circuits and components 10.9 Protection spaints electric shock 10.9 Internal electrical circuits and components 10.1 Internal electrical circuits and components 10.2 Power-frequency electric strength 10.3 Internal electrical circuits and components 10.1 Internal electrical circuits and components 10.1 Internal electrical circuits and components 10.1 Int | Actuator | |
| Actuator diameter Actuator function Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Heat dissipation, non-current-dependent Pvid Heat dissipation, non-current-dependent Pvid Bated operational current for specification for second heat dissipation (In) Static heat dissipation, non-current-dependent Pvid DV Rated operational current for specification bear dissipation (In) Static heat dissipation, non-current-dependent Pvid DV Static heat dissipation, non-current-dependent Pvid DV Static heat dissipation, non-current-dependent Pvid DV Static heat dissipation of thermal stability of enclosures Meets the product standard's requirements. 102.23 I Verification of resistance of insulating materials to normal heat 102.23 Verification of resistance of insulating materials to normal heat 102.24 Resistance of ultra-wiolet (UV) radiation 102.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.2 Fursicitions Meets the product standard's requirements. 102.30 Bogree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 102.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 102.7 Inscriptions Meets the product standard's requirements. 103.8 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 104.1 Clearances and creepage distances Meets the product standard's requirements. 105.2 Prover-frequency electric shock Does not apply, since the entire switchgear needs to be evaluated. 106.1 Incorporation of switching devices and components 107.1 Instrant electrical circuits and connections Is the panel builder's reagonsibility. 108.4 Tassing of enclosures made of insulating material 109.4 Tassing of enclosures reagonsibility. 109.4 Tassing of enclosures made of insulating material 109.1 Short-circuit rating 109.1 Short-circuit | Actuating force | 50 N |
| Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Heat dissipation projec, current-dependent Pvid Met dissipation, non-current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs Met dissipation or resistance Met the product standard's requirements. 10.2.3 1 Verification of thermal stability of enclosures 10.2.3 2 Verification of thermal stability of enclosures 10.2.3 2 Verification of resistance of insulating materials to normal heat 10.2.3 3 Resist of insul. mat to abnormal heat/fire by internal elect. effects Mets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Mechanical impact 10.2.5 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions Mets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Mets the product standard's requirements. 10.5 Protection against electric is took 10.6 Incorporation of swirching devices and components 10.7 Internal electrical circuits and connections 10.8 Incorporation of swirching devices and components 10.9 Power-frequency electric istrongth 10.9 Connections for external conductors 10.9 Reponention of swirching devices and connections 10 | Actuator color | Black |
| Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid No Heat dissipation, non-current-dependent Pvid No Static heat dissipation, non-current-dependent Pvid No Static heat dissipation, non-current-dependent Pvis No 10.2.2 Corrosion resistance Meets the product standard's requirements. No 10.2.3.1 Verification of themal stability of enclosures Meets the product standard's requirements. No 10.2.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. No 10.2.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. No No No No No No No No No N | Actuator diameter | 38 mm |
| Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Design verification Equipment heat dissipation, current-dependent Pvid Design verification Equipment heat dissipation, current-dependent Pvid Design verification or pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs Design verification or provided heat dissipation (In) Design verification or provide | Actuator function | |
| Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss OW Rated operational current for specified heat dissipation [In] Static heat dissipation, per pole, current-dependent Pvid Attain the state dissipation, per pole, current-dependent Pvid OW Rated operational current for specified heat dissipation [In] Static heat dissipation, non-current-dependent Pvid OW 10.22 Corrosion resistance Meets the product standard's requirements. Please enquire Does not apply, since the entire switchgear needs to be evaluated. 10.2.8 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearrances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9 Povaccion against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric stength 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction | Contacts | |
| Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss OW Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid And the dissipation, non-current-dependent Pvs OW Static heat dissipation, non-current-dependent Pvs OW Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Meets the pro | Force for positive opening - min | 0 N |
| Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current dependent Pvs OW 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist. of insul. mat. to abnormal heat/line by internal elect. effects 10.24.4 Resistance to ultra-violet (UV) radiation 10.25.1 Lifting Dees not apply, since the entire switchgear needs to be evaluated. 10.26 Mechanical impact 10.27 Incriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Internal electrical circuits and connections 10.9 Internal electrical circuits and connections 10.9 The panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction | Design verification | |
| Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.24.3 Resistance to ultra-violet (UV) radiation 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.26 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. | Equipment heat dissipation, current-dependent Pvid | 0 W |
| Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of thermal stability of enclosures 10.23.2 Verification of insul. mat. to abnormal heat/fire by internal elect. effects 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24. Resistance to ultra-violet (UV) radiation 10.25. Lifting 10.26 Mechanical impact 10.27 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 10.14 Media function 10.15 Media function 10.15 Indexine the entire switchgear needs to be evaluated. 10.16 Incorporation of switching devices and components 10.17 Internal electric alcircuit sand connections 10.18 Internal electric alcircuit sand connections 10.19 Internal electric alcircuit sand connections 10.20 Power-frequency electric strength 10.30 Impulse withstand voltage 10.40 Internal electric alcircuit rating 10.51 Internal electric alcircuit rating 10.52 Internal publider's responsibility. 10.63 Internal publider's responsibility. 10.74 Internal publider's responsibility. 10.75 Internal publider's responsibility. 10.85 Internal builder's responsibility. 10.96 Internal publider's responsibility. 10.97 Internal publider's responsibility. 10.98 Internal publider's responsibility. 10.9 | Heat dissipation capacity Pdiss | 0 W |
| Static heat dissipation, non-current-dependent Pvs 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resists of insul. mat. to abnormal heat/fire by internal elect. effects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting 10.26 Mechanical impact 10.27 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Onnections for external conductors 10.9 Power-frequency electric strength 10.9 A Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. 10 Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. 10.6 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 the panel builder's responsibility. 10.9 Power-frequency electric strength 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.15 Mechanical function | Heat dissipation per pole, current-dependent Pvid | 0 W |
| 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Dees not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.9.1 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. In the device meets the requirements, provided the information in the instruction. | Rated operational current for specified heat dissipation (In) | 0 A |
| 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Incorporation of switching devices and components 10.17 Internal electric according to the entire switchgear needs to be evaluated. 10.18 Let panel builder's responsibility. 10.29 Power-frequency electric strength 10.30 Impulse withstand voltage 10.4 Testing of enclosures made of insulating material 10.50 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Meets the product standard's requirements. 10.17 Meets the entire switchgear meets be devaluated. 10.18 Meets the product standard's requirements. 10.29 Power-frequency electric strength 10.19 Temperature rise 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Testing of enclosures made of insulating material 10.15 Temperature in the internal electric strength in the instruction of the switchgear must be observed. 10.11 Mechanical function | Static heat dissipation, non-current-dependent Pvs | 0 W |
| 10.2.32 Verification of resistance of insulating materials to normal heat 10.2.33 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Meritand voltage 10.9.3 Impulse withstand voltage 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Meets the product standard's requirements. 10.6 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Internal electric strength 10.9 Internal electric strength 10.9 Internal electric strength 10.9 Internal electric strength 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function | 10.2.2 Corrosion resistance | Meets the product standard's requirements. |
| 10.2.3. Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. In the panel builder's responsibility. In the panel builder's responsibility. In the panel builder's responsibility. The specifications for the switchgear must be observed. In the device meets the requirements, provided the information in the instruction. | 10.2.3.1 Verification of thermal stability of enclosures | Meets the product standard's requirements. |
| 10.24 Resistance to ultra-violet (UV) radiation Please enquire 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.26 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. | 10.2.3.2 Verification of resistance of insulating materials to normal heat | Meets the product standard's requirements. |
| 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction. | 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects | Meets the product standard's requirements. |
| 10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 They are panel builder's responsibility. 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction | 10.2.4 Resistance to ultra-violet (UV) radiation | Please enquire |
| 10.2.7 Inscriptions Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction | 10.2.5 Lifting | Does not apply, since the entire switchgear needs to be evaluated. |
| Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction | 10.2.6 Mechanical impact | Does not apply, since the entire switchgear needs to be evaluated. |
| Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10 Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. Not applicable. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction | 10.2.7 Inscriptions | Meets the product standard's requirements. |
| Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Electrometric shock Does not apply, since the entire switchgear needs to be evaluated. 15 the panel builder's responsibility. 15 the panel builder's responsibility. 16 the panel builder's responsibility. 17 Is the panel builder's responsibility. 18 the panel builder's responsibility. 19 Is the panel builder's responsibility. 10 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10 Is the panel builder's responsibility. The specifications for the switchgear must be observed. | 10.3 Degree of protection of assemblies | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Internal electrical circuits and connections 10.16 Is the panel builder's responsibility. 10.17 Is the panel builder's responsibility. 10.18 Is the panel builder's responsibility. 10.19 Is the panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Internal electrical circuits and connections 10.16 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.19 Internal electrical circuits and connections 10.19 Internal electrical circuits and connections 10.10 Internal electrical circuits and connections 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Internal electrical circuits and connections 10.14 Internal electrical circuits and connections 10.15 Internal electrical circuits and connections 10.16 Internal electrical circuits and connections 10.17 Internal electrical circuits and connections 10.18 Internal electrical circuits and connections 10.19 Internal electrical circuits and connections 10.19 Internal electrical circuits and connections 10.10 Internal electrical circuits and connections 10.10 Internal electrical circuits and connections 10.11 Internal electrical circuits and connections 10.12 Internal electrical circuits and connections 10.15 Internal electrical circuits and connections 10.16 Internal electrical circuits and connections 10.17 Internal electrical circuits and connections 10.18 Internal electrical circuits and connections 10.19 Internal electrical circuits | 10.4 Clearances and creepage distances | Meets the product standard's requirements. |
| 10.7 Internal electrical circuits and connections 1s the panel builder's responsibility. 10.8 Connections for external conductors 1s the panel builder's responsibility. 10.9.2 Power-frequency electric strength 1s the panel builder's responsibility. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. | 10.5 Protection against electric shock | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. Is the panel builder's responsibility. Not applicable. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction | 10.6 Incorporation of switching devices and components | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction | 10.7 Internal electrical circuits and connections | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Is the panel builder's responsibility. Not applicable. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction | 10.8 Connections for external conductors | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction | 10.9.2 Power-frequency electric strength | Is the panel builder's responsibility. |
| 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction | 10.9.3 Impulse withstand voltage | Is the panel builder's responsibility. |
| 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction | 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility. |
| observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction | 10.10 Temperature rise | Not applicable. |
| observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction | 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| | 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| | 10.13 Mechanical function | |

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Front element for mushroom push-button (EC001038)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for mushroom push-button actuators (ecl@ss13-27-37-12-12 [AKF030019])

| (eci@ss13-27-37-12-12 [ARF030019]) | | |
|------------------------------------|----|-------|
| Colour button | | Black |
| Construction type lens | | Round |
| Diameter cap | mm | 38 |
| Hole diameter | mm | 22.5 |
| Width opening | mm | 0 |
| Height opening | mm | 0 |

| Degree of protection (IP) | | IP67/IP69K |
|-----------------------------|---|--------------|
| Degree of protection (NEMA) | | 4X, 13 |
| Type of button | | High |
| Suitable for illumination | | No |
| With lighting | | No |
| Supply voltage lamp | V | 0 |
| Switching function latching | | Yes |
| Spring-return | | No |
| With front ring | | No |
| Material front ring | | Other |
| Colour front ring | | Other |
| Suitable for emergency stop | | No |
| Unlocking method | | Turn-release |