

Actuator, form XB



LS4-XB Part no. Catalog No. 106860 Alternate Catalog LS4-XB

	livery	nro.	NEOM
116	IIVEIV		
	,	PIO	9

Basic function	actuators
Part group reference	LS(4)ZB
Function	Flat actuator
Description	With the actuator inserted, the N/O contact is open and the NC contact is closed.
For use with	LS4ZB

Technical data

General

Conordi		
Standards		IEC/EN 60947
Climatic proofing		Damp heat, constant, to IEC 60068-2-78; damp heat, cyclical, to IEC 60068-2-30
Mounting position		As required
Terminal capacities	mm^2	
Solid	mm ²	1 x (0.75 - 2.5) 2 x (0.75 - 1.5)
Flexible with ferrule	mm ²	1 x (0.5 - 1.5) 2 x (0.5 - 1.5)
Repetition accuracy	mm	0.02

Contacts/switching capacity

Rated insulation voltage Ui V 500 Rated operational current Ie A AC-15 V V 24 V Ie A 10 220 V 230 V 240 V Ie A 6 380 V 400 V 415 V Ie A 4 DC-13 V V 3 24 V Ie A 3 110 V Ie A 0.8 220 V Ie A 0.3 Supply frequency Hz max. 400 Short-circuit rating to IEC/EN 60947-5-1 Hz max. 400	ontainly output ity			
AC-15 24 V 220 V 230 V 240 V 1e A 6 380 V 400 V 415 V 1e A 1e A 4 DC-13 24 V 1e A 4 A 4 CDC-13 24 V 1e A 3 A 4 CDC-13 110 V 1e A 3 A 4 CDC-13 110 V 1e A 1e	Rated impulse withstand voltage		V AC	6000
AC-15 24 V	Rated insulation voltage		V	500
24 V Ie A 10 220 V 230 V 240 V Ie A 6 380 V 400 V 415 V Ie A 4 DC-13 Ie A 3 24 V Ie A 3 110 V Ie A 0.8 220 V Ie A 0.3 Supply frequency Hz max. 400 Short-circuit rating to IEC/EN 60947-5-1 Hz max. 400	Rated operational current	I _e	Α	
220 V 230 V 240 V	AC-15			
380 V 400 V 415 V	24 V	I _e	Α	10
DC-13 Ie A 3 24 V Ie A 3 110 V Ie A 0.8 220 V Ie A 0.3 Supply frequency Hz max. 400 Short-circuit rating to IEC/EN 60947-5-1 Image: August 100 max. 400	220 V 230 V 240 V	I _e	Α	6
24 V I _e A 3 110 V I _e A 0.8 220 V I _e A 0.3 Supply frequency Hz max. 400 Short-circuit rating to IEC/EN 60947-5-1 T T	380 V 400 V 415 V	I _e	Α	4
110 V I _e A 0.8 220 V I _e A 0.3 Supply frequency Hz max. 400 Short-circuit rating to IEC/EN 60947-5-1	DC-13			
220 V I _e A 0.3 Supply frequency Hz max. 400 Short-circuit rating to IEC/EN 60947-5-1	24 V	I _e	Α	3
Supply frequency Hz max. 400 Short-circuit rating to IEC/EN 60947-5-1	110 V	I _e	Α	0.8
Short-circuit rating to IEC/EN 60947-5-1	220 V	I _e	Α	0.3
	Supply frequency		Hz	max. 400
A 0/1 0	Short-circuit rating to IEC/EN 60947-5-1			
max. tuse A gb/gL 6	max. fuse		A gG/gL	6

Mechanical variables

Mechanical shock resistance (half-sinusoidal shock, 20 ms)			
Standard-action contact		g	25
Operating frequency	Operations/h		≦ 1800

Design verification as per IEC/EN 61439

In	Α	0
P_{vid}	W	0
P_{vid}	W	0
P_{vs}	W	0
P _{diss}	W	0
	P _{vid} P _{vid} P _{vs}	P _{vid} W P _{vid} W P _{vs} W

10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation	Please enquire
10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions	Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9 Insulation properties	
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	Not applicable.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 7.0

Sensors (EG000026) / Actuator for position switch with separate actuator (EC001487)

Electric engineering, automation, process control engineering / Binary sensor technology, safety-related sensor technology / Position switch / Actuator for position switch with separate actuator (ecl@ss10.0.1-27-27-06-05 [BAA078012])

Model Standard actuator