Key-operated actuator, maintained, 2 positions, MS7, Key withdrawable: 0, I, Bezel: titanium



Part no. M22-WRS-MS7 111788

General specifications	
Product name	Eaton Moeller® series M22 Key-operated actuator
Part no.	M22-WRS-MS7
EAN	4015081113385
Product Length/Depth	70 millimetre
Product height	30 millimetre
Product width	30 millimetre
Product weight	0.034 kilogram
Compliances	CE Marked
Certifications	EN 60947-5 CSA Std. C22.2 No. 94-91 UL 508 IEC 60947-5 CSA Std. C22.2 No. 14-05 VDE UL CSA Class No.: 3211-03 CSA UL Category Control No.: NKCR IEC/EN 60947 CE CSA-C22.2 No. 14-05 CSA-C22.2 No. 14-05 CSA-C22.2 No. 14-05 CSA-C25.2 No. 94-91 IEC/EN 60947-5 CSA File No.: 012528 VDE 0660 UL File No.: E29184 LR GL DNV
Develop to Trades a res	
Product Tradename Product Type	M22 Key-operated actuator
Product Sub Type Catalog Notes	None Key withdraw convertible with coding adapters M22-XC Not suitable for master key systems
Features & Functions	
Bezel color	Titanium
Bezel material	Plastic
Color	Black
Design	Key operated Classical
Fitted with:	Front ring
Functions	Stay-put/spring-return function, can be changed with coding parts M22-XC-Y
Key code	MS7
General information	
Accessories	1 key included with supplied equipment.
Degree of protection	NEMA 4X, 13
Degree of protection (front side)	IP66
Lifespan, mechanical	100,000 Operations
Opening diameter	22.5 mm
Operating frequency	100 Operations/h
Operating torque	0.5 N·m
Product category	RMQ-Titan
Switching angle	60 °
Type	Key-operated button
Ambient conditions, mechanical	

Monitor position Schools resistance Schools resistance Schools resistance Schools resistance Anniest specially temperature—aim Anniest special		
Mechanical, According in IECEN 2008-2-27 Ambient operating temperature - miax	Mounting position	As required
Ambient operating temperature - min Ambient operating temperature - max Dimaric proofing Dimaric proofing Communication Communic	Shock resistance	
Ambient operating temperature - max Climatic profring Communication Communicat	Climatic environmental conditions	
Communication Connection to SmartNive-DT Actuator Actuator color Actuator (Actuator Color) Actuator (Actuator (Actuator Color) Actuator (Actuator (Actuator (Actuator Color)) Actuator (Actuator (Actua	Ambient operating temperature - min	-25 °C
Dampi heat, cyclic, 1a IEC 60088-2-30 Communication Connection to SmartWin- UT Actuator Actuator function Number of whitch positions Contacts Force for protibive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation, current for specified heat dissipation (n) 10.2.2 Tourison resistance Meets the product standard's requirements. 10.2.3 Verification of hormal stability of enclosures Meets the product standard's requirements. 10.2.3 Verification of resistance of mulating materials to normal heat 10.2.3 Resistance to altra-violet (UV) radiation 10.2.4 Resistance to altra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchpear needs to be evaluated. 10.2.6 Degree of protection of assemblies 10.2.7 Inscriptions 10.2.8 Operational standard's requirements. 10.2.9 Lifting of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection agents electric shock 10.5 Degree of protection of assemblies 10.6 Concentration and articular interviews to be evaluated. 10.7 Inscriptions 10.8 Concentration of existence of mulating materials to normal head to the product standard's requirements. 10.8 Concentration of existence of mulating materials to normal head 10.7 Inscriptions Meets the product standard's requirements. 10.8 Concentration of existence of mulating materials to normal head 10.9 Degree of protection of assemblies 10.9 D	Ambient operating temperature - max	70 °C
Actuator color Actuator function Actuator functi	Climatic proofing	
Actuator color Actuator function Actuator function Actuator function Actuator function Actuator function Actuator function Actuator type Key Number of switch positions Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid OW Heat dissipation capacity Pdiss OPW Heat dissipation capacity Pdiss OW Heat dissipation, one-current-dependent Pvid OW Rated generational current for specified heat dissipation (In) Static heat dissipation, one-current-dependent Pvid OW Rated dissipation, one-current-dependent Pvid Actuator type with product standard's requirements. 10.2.2 Verification or thermal stability of enclosures 10.2.3 Verification of resistance of insulating materials to normal heat 10.2.3 Verification of resistance of insulating materials to normal heat 10.2.3 Verification of resistance of insulating materials to normal heat 10.2.3 Verification of resistance of insulating materials to normal heat 10.2.3 Verification of resistance of insulating materials to normal heat 10.2.3 Selection of resistance of insulating materials to normal heat 10.2.4 Resistance to ultra-violet [UV] radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.2.8 Meets has product standard's requirements. 10.2.8 Neets has product standard's requirements. 10.2.8 Neets has product standard's requirements. 10.2.9 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.2.1 Practicions gainst electric shock 10.3 Insurances and creepage distances Meets the product standard's requirements. 10.3 Verification of a switching devices and components 10.3 Insurances and creepage distance	Communication	
Actuator function Actuator fype Actuator fyp	Connection to SmartWire-DT	
Actuator function Actuator type Actuator type Actuator type Key Number of switch positions Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Under dissipation or apacity Pdiss Heat dissipation or apacity Pdiss Under dissipation or apacity Pdiss Under dissipation or apacity Pdiss Under dissipation or pole, current-dependent Pvid Heat dissipation or apacity Pdiss Under dissipation or apacity Pdiss Under dissipation or or pole, current-dependent Pvid Under dissipation or processtance Meats dissipation, non-current for specified heat dissipation (in) Static heat dissipation, non-current dependent Pvi Under dissipation or resistance Meats the product standard's requirements. Under the product standard's requirements be requirements. U	Actuator	
Key withdrawable in position	Actuator color	Black
Contacts Force for positive opening - min Design verification Equipment has dissipation, current-dependent Pvid Heat dissipation capacity Pdies Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs OW 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.2.3.1 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.2.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3.3 Resist, of incul, mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-volet (IV) radiation 10.2.5 Listing Does not apply, since the entire switchgear needs to be evaluated. 10.2.2 Inscriptions Meets the product standard's requirements. 10.3.0 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4. Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Last the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the	Actuator function	Key withdrawable in position 1 Switching function latching
Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Reted operational current for specified heat dissipation (In) Rated operational current for specified heat dissipation (In) Rated operational current for specified heat dissipation (In) Da Static heat dissipation, non-current-dependent Pvid DV Rated operational current for specified heat dissipation (In) Da Static heat dissipation, non-current-dependent Pvid DV Rated operational current for specified heat dissipation (In) Da Static heat dissipation, non-current-dependent Pvid DO Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Not protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. Not Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. Not Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. Not applicable. Is the panel builder's responsibility. 10.3 Prover-frequency electric strength Step panel builder's responsibility. Not applicable. In 10.1 Short-circuit rating Step panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction.	Actuator type	Key
Porce for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid OW Rated operational current for specified heat dissipation (In) Strate heat dissipation, non-current-dependent Pvs OW 10.22 Corrosion resistance 10.2.3.1 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist, of insul, mat, to abnormal heat/fire by internal elect, effects 10.2.4 Resistance to ultra-violet (UV) radiation Please enquire 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Meets the product standard's requirements. 10.4 Resistance to ultra-violet (UV) radiation Please enquire 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Reproduct standard's requirements. 10.1 Reproduct standard's requirements. 10.2 Resistance to apply, since the entire switchgear needs to be evaluated. 10.1 Internal electrical circuits and connections 10.1 Internal electrica	Number of switch positions	2
Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss OW Rated operational current for specified heat dissipation (In) Static heat dissipation, per pole, current-dependent Pvid OW Rated operational current for specified heat dissipation (In) 10.2.2 Corrosion resistance OW 10.2.2 Corrosion resistance OE2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist of insul. ant. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating Step panel builder's responsibility. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information	Contacts	
Equipment heat dissipation, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs OW Static heat dissipation, non-current-dependent Pvs OW 10.22 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist, of insul, mat, to abnormal heat/fire by internal elect, effects 10.2.4 Resistance to ultra-violet (UV) radiation Please enquire 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage 10.1 Electromagnetic compatibility 10.1 Temperature rise Not applicable. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction observed.	Force for positive opening - min	0 N
Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24.4 Resistance to ultra-violet (UV) radiation 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.26 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Importance in process and of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Design verification	
Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0W 10.22 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance of insulating materials to normal heat 10.2.3 Resists of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation Please enquire 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed.	Equipment heat dissipation, current-dependent Pvid	0 W
Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance Meets the product standard's requirements. 10.2.31 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.32 Verification of resistance of insulating materials to normal heat 10.2.33 Resist of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.1 Thermal electrication in the insulating material Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.11 Short-circuit rating The device meets the requirements, provided the information in the instruction	Heat dissipation capacity Pdiss	0 W
Static heat dissipation, non-current-dependent Pvs 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.24 Resistance to ultra-violet (UV) radiation Please enquire 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.30 Begree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction of the switchgear must be observed.	Heat dissipation per pole, current-dependent Pvid	0 W
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.9.1 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. The specifications for th	Rated operational current for specified heat dissipation (In)	0 A
10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist, of insul, mat, to abnormal heat/fire by internal elect, effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Impulse withstand voltage 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. In the panel builder's responsibility. In the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Static heat dissipation, non-current-dependent Pvs	0 W
10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Meets the product standard's requirements. 10.2 Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Is the panel builder's responsibility. 10.9.1 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Mechanical function 10.17 Mechanical function 10.18 Mechanical function 10.19 Temperature the requirements, provided the information in the instruction	10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Strenger of protection of insulating material 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation Please enquire Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 10.14 Engine entire switchgear needs to be evaluated. 10.2 Does not apply, since the entire switchgear needs to be evaluated. 10.4 Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 the panel builder's responsibility. 10.9 Power-frequency electric strength 10.9 Is the panel builder's responsibility. 10.9 In panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 In the panel builder's responsibility. The specifications for the switchgear must be observed.	10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.2.4 Resistance to ultra-violet (UV) radiation	Please enquire
10.2.7 Inscriptions Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10 be evaluated. 10 be not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. In the specifications for the switchgear must be observed. In the device meets the requirements, provided the information in the instruction	10.2.7 Inscriptions	Meets the product standard's requirements.
Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 1s the panel builder's responsibility. 10.8 Connections for external conductors 1s the panel builder's responsibility. 10.9.2 Power-frequency electric strength 1s the panel builder's responsibility. 10.9.3 Impulse withstand voltage 1s the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 1s the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Electromagnetic compatibility 10.15 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.18 We panel builder's responsibility. The specifications for the switchgear must be observed. 10.19 Electromagnetic compatibility 10.19 Mechanical function 10.10 The device meets the requirements, provided the information in the instruction	10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.19 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function 10.14 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.16 Is the panel builder's responsibility. The specifications for the switchgear must be observed.	10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Step panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 The device meets the requirements, provided the information in the instruction	10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Not applicable. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.11 Short-circuit rating 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.10 Temperature rise	Not applicable.
observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating	
	10.12 Electromagnetic compatibility	
	10.13 Mechanical function	

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Front element for selector switch (EC000222)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for selector switches (ecl@ss13-27-37-12-13 [AKF031019])

Number of switch positions	2	
Type of control element	Key	

Suitable for illumination		No
Colour control element		Black
Colour indicator light cap		Other
Construction type lens		Round
Hole diameter	mm	22.5
Width opening	mm	0
Height opening	mm	0
Switching function latching		Yes
Spring-return		No
With front ring		Yes
Material front ring		Plastic
Colour front ring		Titanium
Degree of protection (IP), front side		IP66
Degree of protection (NEMA)		4X, 13