DATASHEET - FAZT-C12/1

Miniature circuit breaker (MCB), 12A, 1p, C-Char, AC





Part no.FAZT-C12/1Catalog No.240804Alternate CatalogFAZT-C12/1No.EL-NummerI605569(Norway)

Similar to illustration

Delivery program

Basic function			Miniature circuit-breakers
Number of poles			1 pole
Tripping characteristic			C
Application			Switchgear for industrial and advanced commercial applications
Rated current	I _n	А	12
Rated switching capacity acc. to IEC/EN 60947-2	l _{cu}	kA	25
Product range			FAZ-T

Technical data Electrical

Electrical			
Standards			IEC/EN 60947-2
Rated voltage according to IEC/EN 60947-2	Un	V AC	240
Rated switching capacity acc. to IEC/EN 60947-2	l _{cu}	kA	25
Rated service short-circuit breaking capacity according to IEC/EN 60947-2	I _{cs}		12,5 kA
Max operational voltage according to IEC/EN 60947-2		V AC	254
Rated switching capacity according to IEC/EN 60947-2 (max operational voltage)	l _{cu}	kA	15
Rated service short-circuit breaking capacity according to IEC/EN 60947-2 (max operational voltage)	I _{cs}		7,5 kA
Max operational voltage DC according to IEC/EN 60947-2		V DC	60/pole
Rated voltage according to IEC/EN 60898-1	Un	V AC	240
Rated switching capacity according to IEC/EN 60898-1	I _{cn}	kA	15
Rated service short-circuit breaking capacity according to IEC/EN 60898-1	I _{cs}		7,5 kA
Rated insulation voltage	Ui	V	440
Rated frequency	f	Hz	50/60
Characteristic			B, C, D
Direction of incoming supply			as required
lifespan			
Electrical	Operations		≧ 4000
Mechanical	Operations		≧ 10000
Mechanical			
Standard front dimension		mm	45
Enclosure height		mm	80
Mounting width per pole		mm	17.5
Mounting			Quick attachment with 3 latch positions for top-hat rail IEC/EN 60715
Degree of Protection			IP20
Terminals top and bottom			Twin-purpose terminals
Terminal protection			Finger- and back-of-hand proof according to BGV A3 and ÖVE-EN 6
Terminal capacities		mm ²	1 - 25
Tightening torque of fixing screws		N/m	max. 2.4
Thickness of busbar material		mm	0.8 (exept N 0.5 SU)
Mounting position			As required

10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed.	echnical data for design verification			
Equipment heat dissipation, current-dependent Pail Weil Pail Pa	Rated operational current for specified heat dissipation	I _n	А	12
Naise heat dissipation, non-current-dependent Pain West Heat dissipation capacity Pain W 0 Operating ambient temperature min. "C 40 Operating ambient temperature max. "C 40 102.2 Strongth of materials and parts mest, per +1 °C, results in 0.5% reduction of current carrying capacity 102.2 Strongth of materials and parts Mests the product standard's requirements. 102.3 Vorification of resistance Mests the product standard's requirements. 102.3 Vorification of resistance of insulating materials to abnormal heat Mests the product standard's requirements. 102.4 Vorification of resistance of insulating materials to abnormal heat Mests the product standard's requirements. 102.3 Vorification of resistance of insulating materials to abnormal heat Mests the product standard's requirements. 102.4 Resistance to ultra-violet (W) radiation Mests the product standard's requirements. 102.5 Unition Mests the product standard's requirements. 103.0 period grandecima stability and connections Mests the product standard's requirements. 103.0 period in a stability and connections Mests the product standard's requirements. 103.0 period gradecind respassed distances State panel builde	Heat dissipation per pole, current-dependent	P _{vid}	W	0
Heat dissipation capacity Pease W Constraints Operating ambient temperature min. *	Equipment heat dissipation, current-dependent	P _{vid}	W	2.1
Operating ambient temporature min. Comporating ambient temporature max. Means the product standard's requirements. 10.2.2.3.1.2.5.1.1.2.3.2.1.2.3.1.2.3.1.2.3.1.2.3.1.2.3.1.2.3.1.2.3.1.2.3.1.2.3.1.2.3.1.2.3.1.2.3.1.2.3.1.2.3.1.2.3.1.2.3.1.2.3.1.2.3.1.2.1.2	Static heat dissipation, non-current-dependent	P _{vs}	W	0
Dervating ambient temperature max. PC Dervating ambient temperature max. Insear, per +1*C, results in a 05% reduction of current carrying capacity of current carevich carry of current carrying capacity of current	Heat dissipation capacity	P _{diss}	W	0
Interaction Interaction 10.2 Strength of materials and parts Meets the product standard's requirements. 10.2.3 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.5 Utiling Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Utiling Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Meetsine and creage distances Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching divices and components Does not apply, since the entire switchgear needs to be evaluated. 10.8 Incorporatin of switching divices and components Is	Operating ambient temperature min.		°C	-40
LCLN 61439 design varification Metable of materials and parts 10.22 Strength of materials and parts Metable the product standard's requirements. 10.2.3 Varification of thermal stability of enclosures Metable the product standard's requirements. 10.2.3 Varification of resistance of insulating materials to anormal heat and fire due to internal electric effects Metable the product standard's requirements. 10.2.3 Varification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Metable the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Metable the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Metable the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Metable the product standard's requirements. 10.4 Clearances and creepage distances Metable the product standard's requirements. 10.5 Protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearance and creepage distances Metable panel builder's responsibility. 10.5 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electric clicuits and connections Is the panel builder's responsibili	Operating ambient temperature max.		°C	75
10.2 Strength of materials and parts Meets the product standard's requirements. 10.2.3 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.4 Strances and components Does not apply, since the entire switchgear needs to be evaluated. 10.8 Incorporation of switching devices and components Ste panel builder's responsibility. 10.8 Incorporation for external conductors Is the panel builder's responsibility. 10.8 Incorporation for external conductors Is the panel builder's responsibility.				linear, per +1 °C, results in a 0.5% reduction of current carrying capacity
10.2.2 Corosion resistance Meets the product standard's requirements. 10.2.3.1 Varification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Varification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Meets the product standard's requirements. 10.2.3.2 Varification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Does not apply, since the entire switchgear needs to be evaluated. 10.5 Incorporation of switching devices and components Does not apply, since the entire switchgea	C/EN 61439 design verification			
102.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Meets the product standard's requirements. 102.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 102.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 102.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 102.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.7 Inscriptions Meets the product standard's requirements. 103.5 Protection against electric shock Meets the product standard's requirements. 104.7 Inscriptions Does not apply, since the entire switchgear needs to be evaluated. 105.7 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 106.7 Internal electrical circuits and components Meets the product standard's requirements. 108.2 Prover-frequency electric strength Is the panel builder's responsibility. 108.2 Nome-tions of avitching detricas and components Is the panel builder's responsibility. 108.2 Now-frequency electric strength Is the panel builder's responsibility. 108.2 Now-frequency electric stren	10.2 Strength of materials and parts			
10.2.3.2 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.3 Werification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Does not apply, since the entire switchgear needs to be evaluated. 10.3.2 Begree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.1 Proverting encisures made of insulating material Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.1 Fearper tre rise	10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Dees not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical inpact Dees not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Dees not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Dees not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Dees not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Dees not apply, since the entire switchgear needs to be evaluated. 10.9 Insulation properties Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.1 Temperature rise Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.1 Short-circuit rating Is the panel builder's responsibility. The specific	10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
and fire due to internal electric effectsMeets the product standard's requirements.10.2.4 Resistance to ultra-violet (UV) radiationDoes not apply, since the entire switchgear needs to be evaluated.10.2.5 LiftingDoes not apply, since the entire switchgear needs to be evaluated.10.2.6 Mechanical impactDoes not apply, since the entire switchgear needs to be evaluated.10.2.7 InscriptionsMeets the product standard's requirements.10.3.0 Egree of protection of ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9.1 Nuslation propertiesIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Inpulse withstand voltageIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility.10.12 Electromagnetic compatibilityIs the panel builder's responsibility.10.13 Mechanical functionThe device meets the requirements, provided the information in the instruction	10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.5 LiftingDoes not apply, since the entire switchgear needs to be evaluated.10.2.6 Mechanical inpactDoes not apply, since the entire switchgear needs to be evaluated.10.2.7 InscriptionsMeets the product standard's requirements.10.3 Degree of protection of ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9 Insulation propertiesIs the panel builder's responsibility.10.9.1 Supulse withstand voltageIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility.10.12 Electromagnetic compatibility.Is the panel builder's responsibility.10.13 Mechanical functionIs the panel builder's responsibility.				Meets the product standard's requirements.
10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Does not apply, since the entire switchgear needs to be evaluated. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.1 Nullation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Inpulse withstand voltage Is the panel builder's responsibility. 10.9.1 Temperature rise Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear meeds observed. 10.13 Mechanical function Is the panel builder's responsibility. The specifi	10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.1 Nourse withstand voltage Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Inpulse withstand voltage Is the panel builder's responsibility. 10.9.1 Temperature rise Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.12 Electromagnetic compatibility Is she panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction <	10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.3 Degree of protection of ASSEMBLIES Dees not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.1 Power-frequency electric strength Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.1 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.1 Rules withstand voltage Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.1 Temperature rise Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.7 Inscriptions			Meets the product standard's requirements.
10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear muse observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components Dees not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function It device meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provide the information in the instruction	10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.9 Insulation properties Image: Constraint of the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder is responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function Image: Constraint of the device meets the requirements, provided the information in the instruction	10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise The panel builder is responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9 Insulation properties			
10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton with provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provide the information in the instruction	10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function Image: Compatibility of the information in the instruction	10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
Image: compatibility Image: compatibility 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton wil provide heat dissipation data for the devices.
10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must observed.
	10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must observed.
	10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 7.0


Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss10.0.1-27-14-19-01 [AAB905014])


Release characteristic			C
Number of poles (total)			1
Number of protected poles			1
Rated current		A	12
Rated voltage	,	V	240
Rated insulation voltage Ui	,	V	440
Rated impulse withstand voltage Uimp	l	kV	4
Rated short-circuit breaking capacity Icn EN 60898 at 230 V	I	kA	15
Rated short-circuit breaking capacity Icn EN 60898 at 400 V	I	kA	15
Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V	I	kA	25
Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V	I	kA	25
Voltage type			AC
Frequency	1	Hz	50 - 60

Current limiting class		3
Suitable for flush-mounted installation		No
Concurrently switching N-neutral		No
Over voltage category		3
Pollution degree		2
Additional equipment possible		Yes
Width in number of modular spacings		1
Built-in depth	mm	70.5
Degree of protection (IP)		IP20
Ambient temperature during operating	°C	-25 - 75
Connectable conductor cross section multi-wired	mm²	1 - 25
Connectable conductor cross section solid-core	mm²	1 - 25

Characteristics



Dimensions



Additional product information (links)

Temperature dependency, derating

https://www.eaton.com/content/dam/eaton/technicaldocumentation/technical-data-tables/Derating table FAZ_T.pdf