Box terminal, 4p, bottom up to 630A, size 3



Part no. +NZM3-4-XKCU 266782

Design verification as per IEC/EN 61439 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.2 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting 10.26 Mechanical impact 10.27 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Suppower-frequency electric strength 10.9 A Testing of enclosures made of insulating material 10.94 Testing of enclosures made of insulating material	General specifications	
EVAIL Lampth Clarght Product Lampth Clarght Product Lampth Product Taxlessame Product Taxlessame Product Taxlessame Product Taxlessame Product Taxlessame Product Sibi Paye Product	Product name	Eaton Moeller series NZM connection type
Product Length Coupts Posture Length Posture Length Posture Length Posture Vestight Compliances Product vestight Compliances Product Vestight Compliances Product Toutonome Product Toutonome Product Toutonome Product Sale Type Posture Sale Type Po	Part no.	+NZM3-4-XKCU
Preduct height Preduct widn' Preduct widn' Preduct vidn' Campliances Camplianc	EAN	4015082667825
Product width Product weight Compliances EC Product Tacksonane Produc	Product Length/Depth	80 millimetre
Product weight Complances File Rolfs conform Rolfs Rol	Product height	60 millimetre
Compliances REC Rolk Sonfarm NZM Rolk Sonfarm RZM	Product width	80 millimetre
Product Tradename Product Tradename Product Type Product Type Product Sub	Product weight	0.53 kilogram
Product Type Product Type Connection type Connection type Connection type Connection type Connection type Accessories Connection type Accessory Box terminal Torminal Frame Accessory Box Accessory Box Accessory Box Ac	Compliances	
Product Type Product Sab Type Delivery program Number of poles Amperage Rating Four-pole Subable for Subable for Used with Technical Data - Mechanical Menting position Technical Data - Mechanical Menting position Technical Data - Mechanical - Terminals Terminal capacity (stranded cable) Termin		
Product Sub Type Delivery program Type Accessory Box terminal Terminal Four-pole Amperage Rating Suitable for Comperce table Suitable for Used with Technical Data - Mechanical Mounting opsotion Technical Data - Mechanical Mounting opsotion Technical Data - Mechanical - Terminals Terminal capacity (stranded cable) Terminal capacity (stra		
Type Accessory Box terminal Terminal Number of poles Amperage Rating \$ 830 A Four-pole Suitable for Copper cable Used with Nov. Ag Suitable for Used with Technical Data - Mechanical Mounting position Technical Data - Mechanical - Terminals Terminal capacity (stranded cable) Terminal capacity (stranded cable) Terminal capacity (stranded cable) Terminal capacity (copper strip) Terminal capacity	"	
Accessory Box terminal Terminal Number of poles Amporage Rating Amporage Rating Amporage Rating Suitable for NZMS Suitable for Used with NECHNICAL Data - Mechanical Mounting position Technical Data - Mechanical - Terminals Terminal capacity (stranded cable) Terminal capacity (stranded cable) Terminal capacity (stranded cable) Terminal capacity (copper strip) Te	· · · · · · · · · · · · · · · · · · ·	Connection type
Number of poles	Delivery program	
Amperage Rating Frame Suitable for Cephrical Date - Mechanical Wounding position Technical Date - Mechanical - Terminals Terminal capacity (stranded cable) Terminal capacity (stranded cable) Terminal capacity (copper strip) Terminal capacity (stranded cable) Terminal capacity (stranded c	Туре	Accessory Box terminal Terminal
Frame Suitable for Capper cable Used with Forminal Data - Mechanical Munting position Fechnical Data - Mechanical - Terminals Terminal capacity (stranded cable) Terminal capacity (stranded cable) Terminal capacity (copper strip) Te	Number of poles	Four-pole
Suitable for Copper cable Used with Warming position Fechnical Data - Mechanical Mounting position Fechnical Data - Mechanical - Terminals Torminal capacity (stranded cable) Terminal capacity (stranded cable) Terminal capacity (stranded cable) Terminal capacity (stoper strip) Say Mary 1 mm 2 mm 7 (2) 2 - 500 AWG/kcmil (tx) Terminal capacity (copper strip) Say 1 segments of 15 mm x 1 mm 72 segments of 24 mm x 1 mm or 8 segment of 24 mm x 1 mm 72 segments of 24 mm x 1 mm or 11 segments of 24 mm x 1 mm or 18 segm	Amperage Rating	≦ 630 A
Used with Technical Data - Mechanical Mounting position Fethical Data - Mechanical - Terminals Terminal capacity (stranded cable) Terminal capacity (stranded cable) Terminal capacity (stranded cable) Terminal capacity (copper strip) Terminal capacity (stranded cable) Terminal capacity (stranded capacity (stranded capacity capacity (stranded capacity cap	Frame	NZM3
Mounting position Technical Data - Mechanical - Terminals Terminal capacity (stranded cable) Terminal capacity (stranded cable) Terminal capacity (copper strip) Terminal capacity (stranded cable) Terminal capacity (stranded cable in the sum of	Suitable for	The second secon
Mounting position Technical Data - Mechanical - Terminals Terminal capacity (stranded cable) Terminal capacity (stranded cable) Terminal capacity (copper strip) Terminal capacity (stranded cable) Terminal capacity (s	Used with	NZM3(-4), PN3(-4), N(S)3(-4)
Terminal capacity (stranded cable) Terminal capacity (stranded cable) Terminal capacity (copper strip) Te	Fechnical Data - Mechanical	
Terminal capacity (stranded cable) Terminal capacity (copper strip) Terminal capacity (stranded cable) Terminal capacity (copper strip) Te	Mounting position	Fitted at the bottom
Terminal capacity (copper strip) Terminal capacity (capacity capacity (copper strip) Terminal capacity (capacity capacity (capacity capacity) (capacity capacity capac	Technical Data - Mechanical - Terminals	
Design verification as per IEC/EN 61439 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.2 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting 10.26 Mechanical impact 10.27 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Suppower-frequency electric strength 10.9 A Testing of enclosures made of insulating material 10.94 Testing of enclosures made of insulating material	Terminal capacity (stranded cable)	16 mm² - 120 mm² (2x)
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2.7 Inscriptions 10.2.8 Opes not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.9.1 Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.9.2 Is the panel builder's responsibility.	Terminal capacity (copper strip)	Max. 500 A: 6 segments of 16 mm x 0.8 mm - 10 segments of 24 mm x 1 mm or 11
10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material	Design verification as per IEC/EN 61439	
10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material	10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility.	10.2.3.2 Verification of resistance of insulating materials to normal heat	
10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility.	10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility.		
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.1 Testing of enclosures made of insulating material Is the panel builder's responsibility. Is the panel builder's responsibility.		
Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. Is the panel builder's responsibility.	•	
10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility.	·	
10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility.	· ·	· · · · · · · · · · · · · · · · · · ·
10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility.		
10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.9.5 Does not apply, since the entire switchgear needs to be evaluated. 10.9 Is the panel builder's responsibility.		
10.7 Internal electrical circuits and connections 1s the panel builder's responsibility. 10.8 Connections for external conductors 1s the panel builder's responsibility. 10.9.2 Power-frequency electric strength 1s the panel builder's responsibility. 1o.9.3 Impulse withstand voltage 1s the panel builder's responsibility. 1o.9.4 Testing of enclosures made of insulating material 1s the panel builder's responsibility.	•	
10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility.		
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.9.5 Testing of enclosures made of insulating material		
10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility.		
10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility.		
	10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will

10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
Additional information	
Model	Other

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Wiring set for power circuit breaker (EC002050)		
Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Wiring set for circuit breaker (ecl@ss13-27-37-04-24 [ACN957016])		
Suitable for number of poles	4	
Model	Other	