DATASHEET - XIOC-TERM32



Plug for XIOC digital modules 32DI and 32DO, 40pole, 4m

Powering Business Worldwide

XIOC-TERM32 Part no. Catalog No. 267414

EL-Nummer (Norway)

4519691

Delivery program

| Accessories | Terminations |
|--|---|
| | For digital and analog modules from the XN300 I/O system to the XC-303 modular PLCs |
| Description | 40 pole connector for digital module, with 4 m cable |
| For use with | XIOC-32DI XIOC-32DO |
| Information relevant for export to North America | |
| North America Certification Request filed for UL and CSA | |

| Design verification as per IEC/EN 61439 | | | |
|---|-----------------|----|--|
| echnical data for design verification | | | |
| Static heat dissipation, non-current-dependent | P _{vs} | W | 0 |
| Operating ambient temperature min. | | °C | 0 |
| Operating ambient temperature max. | | °C | 55 |
| C/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $$ | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Meets the product standard's requirements. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | |
| 10.9.2 Power-frequency electric strength | | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | | Is the panel builder's responsibility. |
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 7.0

| PI C's | (FG000024) / | Accessories for | controls | (FC002584) |
|--------|--------------|-----------------|-----------|------------|
| I LU 3 | (LUUUUUZ4// | Accessories ioi | CUITLIOIS | (LUUUZJU4/ |

Electric engineering, automation, process control engineering / Control / Programmable logic control (SPS) / Programmable logic control (SPS, accessories) (ecl@ss10.0.1-27-24-22-92 [AFR333003])

| p in necessary | | |
|------------------------------|-------|--|
| Type of electrical accessory | Plug | |
| Type of mechanical accessory | Other | |

Approvals

| • • | |
|--------------------------------------|------------------------------|
| North America Certification | Request filed for UL and CSA |
| Specially designed for North America | No |
| Current Limiting Circuit-Breaker | No |