## **DATASHEET - F-AT0**



Spring-rod actuator, for ATO-

Part no. F-AT0
Catalog No. 050772
Alternate Catalog F-AT0



**Delivery program** 

| Basic function  | Operating heads                            |  |
|---|--|--|
| Part group reference  | ATO  |  |
| Product range   | Spring-rod actuator                        |  |
| Description   | Not to be used as a safety position switch |  |
| Mode of operation   | Sideways                                   |  |
| For use with  | Basic devices ATO                          |  |
| Snap-action contact   | Only permissible with snap-action contact  |  |
| <b>Notes</b> The operating head can be rotated at 90° intervals to adapt to the specified approach direction. |  |  |

## Design verification as per IEC/EN 61439

| Technical data for design verification   |                   |    |  |
|--|-------------------|----|--|
| Rated operational current for specified heat dissipation   | In                | Α  | 0  |
| Heat dissipation per pole, current-dependent   | P <sub>vid</sub>  | W  | 0  |
| Equipment heat dissipation, current-dependent  | P <sub>vid</sub>  | W  | 0  |
| Static heat dissipation, non-current-dependent   | P <sub>vs</sub>   | W  | 0  |
| Heat dissipation capacity  | P <sub>diss</sub> | W  | 0  |
| Operating ambient temperature min.   |                   | °C | -25  |
| Operating ambient temperature max.   |                   | °C | 70   |
| IEC/EN 61439 design verification   |                   |    |  |
| 10.2 Strength of materials and parts   |                   |    |  |
| 10.2.2 Corrosion resistance  |                   |    | Meets the product standard's requirements.                         |
| 10.2.3.1 Verification of thermal stability of enclosures   |                   |    | Meets the product standard's requirements.                         |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                   |    | Meets the product standard's requirements.                         |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $ \frac{1}{2} \left( \frac{1}{2} \right) = \frac{1}{2} \left( \frac{1}{2} \right) \left($ |                   |    | Meets the product standard's requirements.                         |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                   |    | Please enquire   |
| 10.2.5 Lifting   |                   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact   |                   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions  |                   |    | Meets the product standard's requirements.                         |
| 10.3 Degree of protection of ASSEMBLIES  |                   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances   |                   |    | Meets the product standard's requirements.                         |
| 10.5 Protection against electric shock   |                   |    | Does not apply, since the entire switchgear needs to be evaluated. |

| 10.6 Incorporation of switching devices and components   | Does not apply, since the entire switchgear needs to be evaluated.                                       |
|--|--|
| 10.7 Internal electrical circuits and connections        | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors                 | Is the panel builder's responsibility.   |
| 10.9 Insulation properties                               |  |
| 10.9.2 Power-frequency electric strength                 | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage                         | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility.   |
| 10.10 Temperature rise                                   | Not applicable.  |
| 10.11 Short-circuit rating                               | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
| 10.12 Electromagnetic compatibility                      | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
| 10.13 Mechanical function                                | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

## **Technical data ETIM 7.0**

Sensors (EG000026) / Drive head for position switches/hinge switches (EC001483)

Electric engineering, automation, process control engineering / Binary sensor technology, safety-related sensor technology / Position switch / Drive head for position switches (ecl@ss10.0.1-27-27-06-04 [BAA083012])

Type of control element Spring-rod

## **Dimensions**

