



Lightning symbol + terminal marking, for main switch

Part no. BPF-NZM10
Catalog No. 231363

Delivery program

Product range		Accessories
Accessories		Lightning symbol
Standard/Approval		UL/CSA, IEC
Construction size		NZM3/4
Description		Including terminal marking for main switch
For use with		NZM3(-4), PN3(-4), N(S)3(-4) NZM4(-4), N(S)4(-4)
Inscription		Lightning symbol, big
Notes		
Included as standard in main switch assembly kit		
Marking of the input side of the switch is possible		

Design verification as per IEC/EN 61439

IEC/EN 61439 design verification		
10.2 Strength of materials and parts		
10.2.2 Corrosion resistance		Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures		Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat		Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects		Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation		Meets the product standard's requirements.
10.2.5 Lifting		Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact		Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions		Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES		Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances		Meets the product standard's requirements.
10.5 Protection against electric shock		Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components		Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections		Is the panel builder's responsibility.
10.8 Connections for external conductors		Is the panel builder's responsibility.
10.9 Insulation properties		
10.9.2 Power-frequency electric strength		Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage		Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material		Is the panel builder's responsibility.
10.10 Temperature rise		The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating		Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility		Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function		The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 7.0

Auxiliary material (EG000060) / Warning/signing plate (EC001777)		
Occupational safety, accident prevention / Sign, mandatory sign, traffic sign / Sign / Warning sign (ecl@ss10.0.1-40-20-01-03 [AAE738012])		
Material		Plastic
Material quality		Other
With alert-/information symbol		Yes

With alert-/information text		No
Width	mm	20
Height	mm	1
Diameter	mm	0
Thickness	mm	5
Self adhesive mounting		No
After glowing		No
Colour		Yellow
Mounting method		Other
Waterproof		Yes