## **DATASHEET - FAZ6-C4/3N**



Miniature circuit breaker (MCB), 4 A, 3p+N, characteristic: C, 6 kA



FAZ6-C4/3N Part no. Catalog No. 239169 Alternate Catalog FAZ6-C4/3N

Similar to illustration

Design verification as ner IFC/FN 61439

| Design verification as per IEC/EN 61439                                                                                |                  |   |                                                                                                                                  |
|------------------------------------------------------------------------------------------------------------------------|------------------|---|----------------------------------------------------------------------------------------------------------------------------------|
| Technical data for design verification                                                                                 |                  |   |                                                                                                                                  |
| Rated operational current for specified heat dissipation                                                               | In               | Α | 4                                                                                                                                |
| Equipment heat dissipation, current-dependent                                                                          | P <sub>vid</sub> | W | 4.5                                                                                                                              |
| IEC/EN 61439 design verification                                                                                       |                  |   |                                                                                                                                  |
| 10.2 Strength of materials and parts                                                                                   |                  |   |                                                                                                                                  |
| 10.2.2 Corrosion resistance                                                                                            |                  |   | Meets the product standard's requirements.                                                                                       |
| 10.2.3.1 Verification of thermal stability of enclosures                                                               |                  |   | Meets the product standard's requirements.                                                                                       |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat                                             |                  |   | Meets the product standard's requirements.                                                                                       |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |                  |   | Meets the product standard's requirements.                                                                                       |
| 10.2.4 Resistance to ultra-violet (UV) radiation                                                                       |                  |   | Meets the product standard's requirements.                                                                                       |
| 10.2.5 Lifting                                                                                                         |                  |   | Does not apply, since the entire switchgear needs to be evaluated.                                                               |
| 10.2.6 Mechanical impact                                                                                               |                  |   | Does not apply, since the entire switchgear needs to be evaluated.                                                               |
| 10.2.7 Inscriptions                                                                                                    |                  |   | Meets the product standard's requirements.                                                                                       |
| 10.3 Degree of protection of ASSEMBLIES                                                                                |                  |   | Does not apply, since the entire switchgear needs to be evaluated.                                                               |
| 10.4 Clearances and creepage distances                                                                                 |                  |   | Meets the product standard's requirements.                                                                                       |
| 10.5 Protection against electric shock                                                                                 |                  |   | Does not apply, since the entire switchgear needs to be evaluated.                                                               |
| 10.6 Incorporation of switching devices and components                                                                 |                  |   | Does not apply, since the entire switchgear needs to be evaluated.                                                               |
| 10.7 Internal electrical circuits and connections                                                                      |                  |   | Is the panel builder's responsibility.                                                                                           |
| 10.8 Connections for external conductors                                                                               |                  |   | Is the panel builder's responsibility.                                                                                           |
| 10.9 Insulation properties                                                                                             |                  |   |                                                                                                                                  |
| 10.9.2 Power-frequency electric strength                                                                               |                  |   | Is the panel builder's responsibility.                                                                                           |
| 10.9.3 Impulse withstand voltage                                                                                       |                  |   | Is the panel builder's responsibility.                                                                                           |
| 10.9.4 Testing of enclosures made of insulating material                                                               |                  |   | Is the panel builder's responsibility.                                                                                           |
| 10.10 Temperature rise                                                                                                 |                  |   | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating                                                                                             |                  |   | Is the panel builder's responsibility. The specifications for the switchgear must b observed.                                    |
| 10.12 Electromagnetic compatibility                                                                                    |                  |   | Is the panel builder's responsibility. The specifications for the switchgear must b observed.                                    |
| 10.13 Mechanical function                                                                                              |                  |   | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |
|                                                                                                                        |                  |   |                                                                                                                                  |

## **Technical data ETIM 7.0**

| Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)                                                                                                                                |    |     |  |  |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----|-----|--|--|
| Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss10.0.1-27-14-19-01 [AAB905014]) |    |     |  |  |
| Release characteristic                                                                                                                                                                                            |    | С   |  |  |
| Number of poles (total)                                                                                                                                                                                           |    | 4   |  |  |
| Number of protected poles                                                                                                                                                                                         |    | 3   |  |  |
| Rated current                                                                                                                                                                                                     | А  | 4   |  |  |
| Rated voltage                                                                                                                                                                                                     | V  | 230 |  |  |
| Rated insulation voltage Ui                                                                                                                                                                                       | V  | 440 |  |  |
| Rated impulse withstand voltage Uimp                                                                                                                                                                              | kV | 4   |  |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V                                                                                                                                                       | kA | 6   |  |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V                                                                                                                                                       | kA | 6   |  |  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V                                                                                                                                                    | kA | 10  |  |  |

| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V | k | κA  | 10       |
|----------------------------------------------------------------|---|-----|----------|
| Voltage type                                                   |   |     | AC       |
| Frequency                                                      | H | Hz  | 50 - 60  |
| Current limiting class                                         |   |     | 3        |
| Suitable for flush-mounted installation                        |   |     | No       |
| Concurrently switching N-neutral                               |   |     | Yes      |
| Over voltage category                                          |   |     | 3        |
| Pollution degree                                               |   |     | 2        |
| Additional equipment possible                                  |   |     | Yes      |
| Width in number of modular spacings                            |   |     | 4        |
| Built-in depth                                                 | n | mm  | 70.5     |
| Degree of protection (IP)                                      |   |     | IP20     |
| Ambient temperature during operating                           | 0 | °C  | -25 - 75 |
| Connectable conductor cross section multi-wired                | n | mm² | 1 - 25   |
| Connectable conductor cross section solid-core                 | n | mm² | 1 - 25   |

## Additional product information (links)

| Temperature dependency, derating | https://www.eaton.com/content/dam/eaton/technicaldocumentation/technical-data-tables/Derating table |
|----------------------------------|-----------------------------------------------------------------------------------------------------|
|                                  | FAZ6.pdf                                                                                            |