## **DATASHEET - PLS6-D3-MW**



Miniature circuit breaker (MCB), 3 A, 1p, characteristic: D

Part no. PLS6-D3-MW Catalog No. 242694



Similar to illustration

| Delivery program                                     |                 |    |  |
|--|-----------------|----|--|
| Basic function                                       |                 |    | Miniature circuit-breakers                             |
| Number of poles                                      |                 |    | 1 pole   |
| Tripping characteristic                              |                 |    | D  |
| Application  |                 |    | Switchgear for residential and commercial applications |
| Rated current  | In              | Α  | 3  |
| Rated switching capacity according to IEC/EN 60898-1 | I <sub>cn</sub> | kA | 6  |
| Product range  |                 |    | PLS6   |

### **Technical data**

#### **Electrical**

| lated switching capacity according to IEC/EN 60898-1 | I <sub>cn</sub> | kA | 6 |
|--|-----------------|----|---|
|  |                 |    |   |

# Design verification as per IEC/EN 61439

| Technical data for design verification   |                   |    |   |
|--|-------------------|----|---|
| Rated operational current for specified heat dissipation   | In                | Α  | 3   |
| Heat dissipation per pole, current-dependent   | P <sub>vid</sub>  | W  | 0   |
| Equipment heat dissipation, current-dependent  | P <sub>vid</sub>  | W  | 1.2   |
| Static heat dissipation, non-current-dependent   | P <sub>vs</sub>   | W  | 0   |
| Heat dissipation capacity  | P <sub>diss</sub> | W  | 0   |
| Operating ambient temperature min.   |                   | °C | -25   |
| Operating ambient temperature max.   |                   | °C | 75  |
|  |                   |    | linear, per +1 °C, results in a 0.5% reduction of current carrying capacity |
| IEC/EN 61439 design verification   |                   |    |   |
| 10.2 Strength of materials and parts   |                   |    |   |
| 10.2.2 Corrosion resistance  |                   |    | Meets the product standard's requirements.                                  |
| 10.2.3.1 Verification of thermal stability of enclosures   |                   |    | Meets the product standard's requirements.                                  |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                   |    | Meets the product standard's requirements.                                  |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |                   |    | Meets the product standard's requirements.                                  |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                   |    | Meets the product standard's requirements.                                  |
| 10.2.5 Lifting   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.          |
| 10.2.6 Mechanical impact   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.          |
| 10.2.7 Inscriptions  |                   |    | Meets the product standard's requirements.                                  |
| 10.3 Degree of protection of ASSEMBLIES  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.          |
| 10.4 Clearances and creepage distances   |                   |    | Meets the product standard's requirements.                                  |
| 10.5 Protection against electric shock   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.          |
| 10.6 Incorporation of switching devices and components   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.          |
| 10.7 Internal electrical circuits and connections  |                   |    | Is the panel builder's responsibility.                                      |
| 10.8 Connections for external conductors   |                   |    | Is the panel builder's responsibility.                                      |
| 10.9 Insulation properties   |                   |    |   |
| 10.9.2 Power-frequency electric strength   |                   |    | Is the panel builder's responsibility.                                      |
| 10.9.3 Impulse withstand voltage   |                   |    | Is the panel builder's responsibility.                                      |

| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility.   |
|--|--|
| 10.10 Temperature rise                                   | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating                               | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 Electromagnetic compatibility                      | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 Mechanical function                                | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

Connectable conductor cross section multi-wired

Connectable conductor cross section solid-core

| Technical data ETIM 7.0  |                    |             |  |
|--|--------------------|-------------|--|
| Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC0000  | 042)               |             |  |
| Electric engineering, automation, process control engineering / Electrical instal (ecl@ss10.0.1-27-14-19-01 [AAB905014]) | lation, device / M | iniature ci | rcuit breaker system (MCB) / Miniature circuit breaker (MCB) |
| Release characteristic   |                    |             | D  |
| Number of poles (total)  |                    |             | 1  |
| Number of protected poles  |                    |             | 1  |
| Rated current  |                    | Α           | 3  |
| Rated voltage  |                    | V           | 230  |
| Rated insulation voltage Ui  |                    | V           | 440  |
| Rated impulse withstand voltage Uimp   |                    | kV          | 4  |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V  |                    | kA          | 6  |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V  |                    | kA          | 6  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V   |                    | kA          | 0  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V   |                    | kA          | 0  |
| Voltage type   |                    |             | AC   |
| Frequency  |                    | Hz          | 50 - 60  |
| Current limiting class   |                    |             | 3  |
| Suitable for flush-mounted installation  |                    |             | No   |
| Concurrently switching N-neutral   |                    |             | No   |
| Over voltage category  |                    |             | 3  |
| Pollution degree   |                    |             | 2  |
| Additional equipment possible  |                    |             | Yes  |
| Width in number of modular spacings  |                    |             | 1  |
| Built-in depth   |                    | mm          | 70.5   |
| Degree of protection (IP)  |                    |             | IP20   |
| Ambient temperature during operating   |                    | °C          | -25 - 75   |

1 - 25

1 - 25

mm²

mm²