# DATASHEET - PLZ6-B32/1N-MW



### Miniature circuit breaker (MCB), 32A, 1pole+N, type B characteristic

Powering Business Worldwide

PLZ6-B32/1N-MW Part no. Catalog No. 242788

# **Delivery program**

| Basic function                                       |                 |    | Miniature circuit-breakers                             |
|--|-----------------|----|--|
| Number of poles                                      |                 |    | 1 pole+N   |
| Tripping characteristic                              |                 |    | В  |
| Application  |                 |    | Switchgear for residential and commercial applications |
| Rated current  | In              | Α  | 32   |
| Rated switching capacity according to IEC/EN 60898-1 | I <sub>cn</sub> | kA | 6  |
| Product range  |                 |    | PLZ6   |

# **Technical data**

#### **Electrical**

Rated switching capacity according to IEC/EN 60898-1 Icn kA

| Design verification as per IEC/EN 61439  |                   |    |  |
|--|-------------------|----|--|
| Technical data for design verification   |                   |    |  |
| Rated operational current for specified heat dissipation   | In                | Α  | 32   |
| Heat dissipation per pole, current-dependent   | P <sub>vid</sub>  | W  | 0  |
| Equipment heat dissipation, current-dependent  | P <sub>vid</sub>  | W  | 4.4  |
| Static heat dissipation, non-current-dependent   | P <sub>vs</sub>   | W  | 0  |
| Heat dissipation capacity  | P <sub>diss</sub> | W  | 0  |
| Operating ambient temperature min.   |                   | °C | -25  |
| Operating ambient temperature max.   |                   | °C | 75   |
|  |                   |    | linear, per +1 °C, results in a 0.5% reduction of current carrying capacity  |
| IEC/EN 61439 design verification   |                   |    |  |
| 10.2 Strength of materials and parts   |                   |    |  |
| 10.2.2 Corrosion resistance  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |                   |    | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                   |    | Meets the product standard's requirements.   |
| 10.2.5 Lifting   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions  |                   |    | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances   |                   |    | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections  |                   |    | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors   |                   |    | Is the panel builder's responsibility.   |
| 10.9 Insulation properties   |                   |    |  |
| 10.9.2 Power-frequency electric strength   |                   |    | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage   |                   |    | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material   |                   |    | Is the panel builder's responsibility.   |
| 10.10 Temperature rise   |                   |    | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating   |                   |    | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |

| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
|-------------------------------------|--|
| 10.13 Mechanical function           | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

# **Technical data ETIM 7.0**

| C: | Miniature circuit breaker (MCR) (FC00042) |
|----|---|
|    |   |

Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (pc)(@cs10.01-177-14-19-01 [AAR905014])

| (ecl@ss10.0.1-27-14-19-01 [AAB905014])                         |                 |                       |  |  |
|--|-----------------|-----------------------|--|--|
| Release characteristic   |                 | В                     |  |  |
| Number of poles (total)  |                 | 2                     |  |  |
| Number of protected poles                                      |                 | 1                     |  |  |
| Rated current  | Α               | 32                    |  |  |
| Rated voltage  | V               | 230                   |  |  |
| Rated insulation voltage Ui                                    | V               | 440                   |  |  |
| Rated impulse withstand voltage Uimp                           | kV              | 4                     |  |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V    | kA              | 6                     |  |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V    | kA              | 6                     |  |  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V | kA              | 0                     |  |  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V | kA              | 0                     |  |  |
| Voltage type   |                 | AC                    |  |  |
| Frequency  | Hz              | 50 - 60               |  |  |
| Current limiting class   |                 | 3                     |  |  |
| Suitable for flush-mounted installation                        |                 | No                    |  |  |
| Concurrently switching N-neutral                               |                 | Yes                   |  |  |
| Over voltage category  |                 | 3                     |  |  |
| Pollution degree   |                 | 2                     |  |  |
| Additional equipment possible                                  |                 | Yes                   |  |  |
| Width in number of modular spacings                            |                 | 2                     |  |  |
| Built-in depth   | mm              | n 70.5                |  |  |
| Degree of protection (IP)                                      |                 | IP20                  |  |  |
| Ambient temperature during operating                           | °C              | -25 - 55              |  |  |
| Connectable conductor cross section multi-wired                | mm²             | n <sup>2</sup> 1 - 25 |  |  |
| Connectable conductor cross section solid-core                 | mm <sup>2</sup> | π <sup>2</sup> 1 - 25 |  |  |