



**Electric Automation**  
Automation specialists

Reference: T4V250  
Code: 1SDA059526R1

T4V 250 PR223DS In=250A 4p F F

Buy it at [Electric Automation Network](#)



C.BREAKER TMAX T4V 250 FIXED FOUR-POLE WITH FRONT TERMINALS AND SOLID-STATE RELEASE IN AC PR223DS R 250

### Ordering

EAN:	8015644619343
Minimum Order Quantity:	1 piece
Customs Tariff Number:	85362090

### Dimensions

Product Net Width:	140 mm
Product Net Height:	205 mm
Product Net Depth:	103.5 mm
Product Net Weight:	3.05 kg

### Container Information

Package Level 1 Units:	1 piece
Package Level 1 Width:	228 mm
Package Level 1 Height:	228 mm
Package Level 1 Length:	286 mm
Package Level 1 Gross Weight:	3.5 kg

Package Level 1 EAN:	8015644619343
----------------------	---------------

## Additional Information

Electrical Durability:	8000 cycle 120 cycles per hour
Mechanical Durability:	20000 cycle 240 cycles per hour
Number of Poles:	4
Power Loss:	at Rated Operating Conditions per Pole 10,7 W
Product Main Type:	SACE Tmax T
Product Name:	Automatic Circuit Breaker
Product Type:	CB
Rated Current ( $I_n$ ):	250 A
Rated Impulse Withstand Voltage ( $U_{imp}$ ):	8 kV
Rated Insulation Voltage ( $U_i$ ):	1000 V
Rated Operational Voltage:	690 V AC 750 V DC
Rated Service Short-Circuit Breaking Capacity ( $I_{cs}$ ):	(220 V AC) 200 kA (230 V AC) 200 kA (380 V AC) 200 kA (400 V AC) 200 kA (415 V AC) 200 kA (440 V AC) 180 kA (500 V AC) 150 kA (690 V AC) 80 kA
Rated Ultimate Short-Circuit Breaking Capacity ( $I_{cu}$ ):	(220 V AC) 20 kA (230 V AC) 20 kA (380 V AC) 200 kA (400 V AC) 200 kA (415 V AC) 200 kA (440 V AC) 180 kA (500 V AC) 150 kA (660 V AC) 80 kA (690 V AC) 80 kA (250 V DC) 2 Poles in Series 100 kA (500 V DC) 2 Poles in Series 65 kA (750 V DC) 3 Poles in Series 50 kA
Rated Uninterrupted Current ( $I_u$ ):	250 A
Release Type:	EL
Standards:	IEC 60947
Sub-type:	T4
Terminal Connection Type:	Fixed Circuit-Breakers Front
Test Voltage Max ( $U_{test}$ ):	3500 V
Version:	F

## Certificates and Declarations (Document Number)

Data Sheet, Technical Information:	1SDC210023D0201
Declaration of Conformity - CE:	1SDL000165R0004
GL Certificate:	1SDL000163R0061

## Classifications

ETIM 4:	EC000228 - Power circuit-breaker for trafo/generator/ installation prot.
ETIM 5:	EC000228 - Power circuit-breaker for trafo/generator/ installation prot.
Object Classification Code:	Q
UNSPSC:	39121100