



Electric Automation
Automation specialists

Reference: T5L400 1000V
Code: 1SDA063440R1

T5L400 PR221DS-LS/I In400 4p FFC
1000VAC

Buy it at [Electric Automation Network](#)



C.BREAKER TMAX T5L 400 1000V AC FIXED FOUR-POLE WITH FRONT TERMINALS FOR CABLE Cu AND SOLID-STATE RELEASE IN AC PR221DS-LS/I R 400

Ordering

| | |
|-------------------------|---------------|
| EAN: | 8015644660642 |
| Minimum Order Quantity: | 1 piece |
| Customs Tariff Number: | 85362090 |

Dimensions

| | |
|---------------------|----------|
| Product Net Width: | 140 mm |
| Product Net Height: | 205 mm |
| Product Net Depth: | 103.5 mm |
| Product Net Weight: | 4.15 kg |

Container Information

| | |
|------------------------|---------------|
| Package Level 1 Units: | 1 piece |
| Package Level 1 EAN: | 8015644660642 |

Additional Information

| | |
|--|---|
| Electrical Durability: | 7000 cycle 60 cycles per hour |
| Mechanical Durability: | 20000 cycle 120 cycles per hour |
| Number of Poles: | 4 |
| Power Loss: | at Rated Operating Conditions per Pole 16,5 W |
| Product Main Type: | SACE Tmax T |
| Product Name: | Automatic Circuit Breaker |
| Product Type: | CB |
| Rated Current (I_n): | 400 A |
| Rated Impulse Withstand Voltage (U_{imp}): | 8 kV |
| Rated Insulation Voltage (U_i): | 1000 V |
| Rated Operational Voltage: | 1000 V AC 1000 V DC |
| Rated Service Short-Circuit Breaking Capacity (I_{cs}): | (1000 V AC) 10 kA |
| Rated Short-time Withstand Current (I_{cw}): | for 1 s 5 A |
| Rated Ultimate Short-Circuit Breaking Capacity (I_{cu}): | (1000 V AC) 12 kA |
| Rated Uninterrupted Current (I_u): | 400 A |
| Release Type: | EL |
| Standards: | IEC 60947 |
| Sub-type: | T5 |
| Terminal Connection Type: | Fixed Circuit-Breakers Front for Copper Cables |
| Test Voltage Max (U_{test}): | 3500 V |
| Version: | F |

Certificates and Declarations (Document Number)

| | |
|------------------------------------|-----------------|
| Data Sheet, Technical Information: | 1SDC210023D0201 |
| Declaration of Conformity - CE: | 1SDL000165R0005 |
| GL Certificate: | 1SDL000163R0062 |

Classifications

| | |
|-----------------------------|---|
| ETIM 4: | EC000228 - Power circuit-breaker for trafo/generator/ installation prot. |
| ETIM 5: | EC000228 - Power circuit-breaker for trafo/generator/ installation prot. |
| Object Classification Code: | Q |
| UNSPSC: | 39121100 |