



**Electric Automation**  
Automation specialists

Reference: XT4L250  
Code: 1SDA068575R1

XT4L 250 Ekip LS/I In=250A 4p F F

Buy it at Electric Automation Network



C.BREAKER TMAX XT4L 250 FIXED FOUR-POLE WITH FRONT TERMINALS AND SOLID-STATE RELEASE IN AC EKIP-LS/I R 250 A

### Ordering

EAN:	8015644024819
Minimum Order Quantity:	1 piece
Customs Tariff Number:	85362090

### Dimensions

Product Net Width:	140 mm
Product Net Height:	160 mm
Product Net Depth:	82.5 mm
Product Net Weight:	3.5 kg

### Container Information

Package Level 1 Units:	1 piece
Package Level 1 Width:	145 mm
Package Level 1 Height:	210 mm
Package Level 1 Length:	168 mm
Package Level 1 Gross Weight:	3.5 kg

Package Level 1 EAN:	8015644024819
----------------------	---------------

## Additional Information

Circuit Breaker Type to be Associated:	Power distribution
Electrical Durability:	120 cycles per hour 8000 cycle
Mechanical Durability:	Nr. Operations 240 cycles per hour Nr. Operations 25000 cycle
Number of Poles:	4
Opening Time:	CB with SOR 15 ms CB with UVR 15 ms
Product Main Type:	SACE Tmax XT
Product Name:	Automatic Circuit Breaker
Product Type:	CB
Rated Current ( $I_n$ ):	250 A
Rated Frequency (f):	50 / 60 Hz
Rated Impulse Withstand Voltage ( $U_{imp}$ ):	8 kV
Rated Insulation Voltage ( $U_i$ ):	1000 V
Rated Operational Voltage:	690 V AC 500 V DC
Rated Service Short-Circuit Breaking Capacity ( $I_{cs}$ ):	(220 V AC) 150 kA (220 V AC) 150 kA (380 V AC) 120 kA (415 V AC) 120 kA (440 V AC) 100 kA (500 V AC) 60 kA (690 V AC) 20 kA
Rated Ultimate Short-Circuit Breaking Capacity ( $I_{cu}$ ):	(220 V AC) 150 kA (230 V AC) 150 kA (380 V AC) 120 kA (415 V AC) 120 kA (440 V AC) 100 kA (500 V AC) 60 kA (690 V AC) 20 kA
Rated Uninterrupted Current ( $I_u$ ):	250 A
Rated Voltage ( $U_r$ ):	690 V
Release Type:	EL
Standards:	IEC 60947
Sub-type:	XT4
Terminal Connection Type:	Fixed Circuit-Breakers Front
Version:	F

## Certificates and Declarations (Document Number)

Data Sheet, Technical Information:	1SDC210033D0201
------------------------------------	-----------------

Declaration of Conformity - CE:	1SDL000165R0012
GL Certificate:	1SDL000163R0095
LR Certificate:	1SDL000163R0100

## Classifications

ETIM 4:	EC000228 - Power circuit-breaker for trafo/generator/ installation prot.
ETIM 5:	EC000228 - Power circuit-breaker for trafo/generator/ installation prot.
Object Classification Code:	Q
UNSPSC:	39120000