



Reference: CT-AHE

Code: 1SVR550118R4100

CT-AHE Time relay, OFF-delay 1c/o,

0.3-30s, 24VAC/DC

Buy it at Electric Automation Network



The CT-AHE is a single-function electronic time relay from the CT-E timer range. It provides an OFF-delay (delay on break) function with a time range from 0.3 s to 30 s. This time relay operates with a rated control supply voltage of 24 V AC / DC and has a 1 c/o (SPDT) output rated at 250 V / 4 A. A control input works with voltage-related (non-floating) triggering.

Ordering

| EAN: | 4013614346323 |
|-------------------------|---------------|
| Minimum Order Quantity: | 1 piece |
| Customs Tariff Number: | 85364190 |

Container Information

| Package Level 1 Units: | 1 piece |
|-------------------------------|----------|
| Package Level 1 Width: | 84.2 mm |
| Package Level 1 Length: | 24.6 mm |
| Package Level 1 Height: | 83.1 mm |
| Package Level 1 Gross Weight: | 0.081 kg |

Dimensions

| Product Net Width: | 22.5 mm |
|--------------------|---------|
| | |

| Product Net Height: | 78 mm |
|---------------------|---------|
| Product Net Depth: | 78.5 mm |
| Product Net Weight: | 0.07 kg |

Technical

| Timer Relay Type: | OFF-Delay |
|---|---|
| Time Range: | 0.3-30 s |
| Rated Control Supply Voltage (U _s): | 24 V AC/DC |
| Output: | 1 c/o (SPDT) contact |
| Terminal Type: | Screw Terminals |
| Standards: | IEC 61812-1 EN 61812-1 + A11 DIN VDE 0435 part 2021 |

Environmental

| RoHS Status: | Following EU Directive 2002/95/EC August 18, 2005 and amendment |
|--------------|---|
|--------------|---|

Certificates and Declarations (Document Number)

| CB Certificate: | CB_DK-8575 |
|---------------------------------|--------------------------|
| CCC Certificate: | CCC_2010010303393101 |
| cUL Certificate: | cUL508_E140448 |
| Declaration of Conformity - CE: | 1SAD938501-0114 |
| EAC Certificate: | EAC_RU_C-DE.ME77.B.02016 |
| GL Certificate: | GL_94633-94HH |
| GOST Certificate: | GOST_8572616 |
| RMRS Certificate: | RMRS_12.04010.250 |
| RoHS Information: | 1SAA981001-4404 |
| UL Certificate: | UL508_E140448 |

Classifications

| Object Classification Code: | К |
|-----------------------------|------------------------|
| ETIM 4: | EC001439 - Timer relay |
| ETIM 5: | EC001439 - Timer relay |
| UNSPSC: | 39121500 |
| eClass: | 7.0 27371790 |