



Electric Automation
Automation specialists

Reference: CT-ARE
Code: 1SVR550127R4100

CT-ARE Time relay, true OFF-delay 1c/o,
0.3-30s, 24VAC/DC, 220-240VAC

Buy it at [Electric Automation Network](#)



The CT-ARE is a single-function electronic time relay from the CT-E timer range. It provides an OFF-delay (true delay on break) function without auxiliary voltage and with a time range from 0.3 s to 30 s. This time relay operates with a rated control supply voltage of 24 V AC / DC / 220 - 240 V AC and has a 1 c/o (SPDT) output rated at 250 V / 4 A.

Ordering

EAN:	4013614346361
Minimum Order Quantity:	1 piece
Customs Tariff Number:	85364900

Container Information

Package Level 1 Units:	1 piece
Package Level 1 Width:	84.2 mm
Package Level 1 Length:	24.6 mm
Package Level 1 Height:	83.1 mm
Package Level 1 Gross Weight:	0.081 kg

Dimensions

Product Net Width:	22.5 mm
--------------------	---------

Product Net Height:	78 mm
Product Net Depth:	78.5 mm
Product Net Weight:	0.07 kg

Technical

Timer Relay Type:	True OFF-Delay
Time Range:	0.3-30 s
Rated Control Supply Voltage (U _s):	220 ... 240 V AC 24 V AC/DC
Output:	1 c/o (SPDT) contact
Terminal Type:	Screw Terminals
Standards:	IEC 61812-1 EN 61812-1 + A11 DIN VDE 0435 part 2021

Environmental

RoHS Status:	Following EU Directive 2002/95/EC August 18, 2005 and amendment
--------------	---

Certificates and Declarations (Document Number)

CB Certificate:	CB_DK-8575
CCC Certificate:	CCC_2010010303393101
cUL Certificate:	cUL508_E140448
Declaration of Conformity - CE:	1SAD938501-0114
EAC Certificate:	EAC_RU_C-DE.ME77.B.02016
GL Certificate:	GL_94633-94HH
GOST Certificate:	GOST_8572616
RMRS Certificate:	RMRS_12.04010.250
RoHS Information:	1SAA981001-4404
UL Certificate:	UL508_E140448

Classifications

Object Classification Code:	K
ETIM 4:	EC001439 - Timer relay
ETIM 5:	EC001439 - Timer relay
UNSPSC:	39121500
eClass:	7.0 27371790