

Distribution cabinet, HxWxD=2000x800x600mm, IP55, bayable

Part no. Article no. XVTL-MP/BX/IC-6/8/20 114589



Delivery programme

Product range		Control centres XVTL
Basic function		Combination enclosures
Single unit/Complete unit		Complete housing
Degree of Protection		IP55 (with door and flange)
Description		Fragment basic equipment Including open cable entries top, prepared for F3A flange
Material		Sheet steel 2 mm
Surface finish		Polyester powder coating Phosphated RAL 7035, light grey
Colour		RAL 7035, light grey
Information about equipment supplied		including frame, sheet steel doors, back plate, bottom and top plate, mounting plate, lifting eyelets, cylinder lock and branding strip Including support frame for the IVS mounting units including insulating surround and mounted insulated support bracket Without side walls
Width	mm	600
Height	mm	2000
Depth	mm	800

Technical data

General		
Standards		IEC/EN 60439-1 IEC/EN 60439-3 IEC/EN 62208
Protection class		1
		40 °C (intermittent maximum value) 35 °C (maximum value, 24 h average) -5 °C (minimum value)
Installation conditions		Indoor installation
Degree of Protection		IP55 (with door and flange)
Relative humidity		50% (at 40°C)
Power loss		
Max. admissible heat dissipation, ambient air temperature +35 $^{\circ}\mathrm{C}$	W	604
Weight	kg	93
Material characteristics		
Material		Sheet steel 2 mm
Surface treatment		Painting, phosphated and polyester powder coating
Surface finish		Polyester powder coating Phosphated RAL 7035, light grey
Colour		RAL 7035, light grey
Material characteristics		
Type Door		Outside-supported doors with hidden hinges Can be removed from 90°
door opening angle		120° (single mounting) 120° (combination mounting)
Door interlock		Folding handle with espagnolette lock Can be fitted with profile cylinder Three-point interlock
Material properties		
Mechanical		
Cable entry		Various covers allow cable entry from above and/or below

Electrical			
Rated insulation voltage	Ui	V	690
Rated operational voltage	U _e	V	415
Rated frequency	f	Hz	50 (AC)
Rated impulse withstand voltage	U _{imp}	kV	6
Rated operational current	le	CSA	2500
Overvoltage category/pollution degree			IV/3
Rated short-time withstand current (t=1s)	I _{cw}	kA	65
Rated peak withstand current	I _{pk}	kA	143
Max. admissible heat dissipation, ambient air temperature +35 $^{\circ}\mathrm{C}$		W	604
Earthings			Screw M10: 50 x 106 A ² s (base frame, main earthing) Taptite screw M6: 3.9 × 106 A ² s (enclosure side plate, back plate) M6 weld stud: 50 × 106 A ² s (door)

Design verification as per IEC/EN 61439

Heat dissipation, at an ambient temperature of 35°C, delta T: 20 degrees, calculated as per IEC 60890PyC0Individual enclosure, free-standingPyC029Starting enclosure, free-standingPyC024Individual enclosure, free-standingPyC028Individual enclosure for wall mountingPyC028Starting enclosure for wall mountingPyC028Middle enclosure for wall mountingPyC028Individual enclosure for wall mountingPyC028Individual enclosure for wall mountingPyC028Individual enclosure, free-standingPyC028Individual enclosure, free-standingPyC058Individual enclosure, free-standingPyC051Individual enclosure, free-standingPyC051Individual enclosure, free-standingPyC051Individual enclosure, free-standingPyC051Individual enclosure for wall mountingPyC051Individual enclosure for wall mountingPy </th <th></th> <th></th> <th></th> <th></th>				
Induitation departs for standing Note of the standing	Technical data for design verification			
Starting enclosure, free-standing Py CD 23 Middle enclosure, free-standing Py CD 24 Middle enclosure for wall mounting Py CD 25 Middle enclosure for wall mounting Py CD 26 Middle enclosure, free-standing Py CD 31 Middle enclosure, free-standing Py CD 31 Individual acclosure, free-standing Py CD 31 Starting enclosure for wall mounting Py CD 31 Middle enclosure, free-standing Py CD 31 Starting enclosure for wall mounting Py CD 31 Middle enclosure for wall mounting Py				
Midde enclosure, free-standing Py CO 24 Individual enclosure for wall mounting Py CO 28 Middle enclosure for wall mounting Py CO 28 Head disation, is a mabiest temporative of 35°C, delta T-33 degrees, and the station of the station of the standing Py CO 38 Individual enclosure, free-standing Py CO 37 Stating enclosure, free-standing Py CO 37 Middle enclosure for wall mounting Py CO 37	Individual enclosure, free-standing	PV	C0	290
Individual enclosure for wall mountingPiCIPiCIStarting enclosure for wall mountingPiPiSaMedia enclosure for wall mountingPiSaSaPerturbisity of a sambler targerstation d'SC, debt 7: S5 degreesPiSaPart dissigning on closure, free-standingPiCISaMidde enclosure, free-standingPiCISaMidde enclosure, free-standingPiCISaMidde enclosure, free-standingPiCISaMidde enclosure for wall mountingPiCISaStarting enclosure for wall mountingPiCISaTo ZS brongh of materials and partsPiCISaTo ZS brongh of enclosure for wall mountingPiCISaTo ZS brongh of enclosure for wall mounting to enclosure for wall mountingPiCISaTo ZS brongh of enclosure for wall mountingPiCISaTo ZS brongh of enclosure for wall mounting to enclosure for wall mountingPiCISaTo ZS brongh of enclosure for wall mounting to enclosure for wa	Starting enclosure, free-standing	P _V	CO	273
Starting enclosure for wall mountingPkCOSelection of a series of a secience of a seci	Middle enclosure, free-standing	P _V	CO	244
Middle enclosure for wall mountingPut <td>Individual enclosure for wall mounting</td> <td>PV</td> <td>C0</td> <td>287</td>	Individual enclosure for wall mounting	PV	C0	287
Heat dissipation, at a mabient unpersture of 35°C, delta T. 35 degrees,	Starting enclosure for wall mounting	PV	C0	258
calculated as per IEC 0000Pice </td <td>Middle enclosure for wall mounting</td> <td>PV</td> <td>CO</td> <td>236</td>	Middle enclosure for wall mounting	PV	CO	236
Starting enclosure, free-standingPiCiS4Middle enclosure for wall mountingPiCi57Starting enclosure for wall mountingPiCi57Middle enclosure for wall mountingPiCi74Middle enclosure for wall mountingPiCi74102.2 Corresion resistancePiPiPi102.2 Corresion resistance of insulating materials to onormal heatNot applicable.Not applicable.102.3 Verification of resistance of insulating materials to ohormal heatNot applicable.Not applicable.102.4 Resistance to ultra-violet (UV) reductionPiNot applicable.Not applicable.102.5 LiftingNot elevent to indoor installations.PiNot applicable.Not applicable.Not applicable.102.5 Lif				
Midde enclosure, free-standingPoilCol4040Individual enclosure for wall mountingPvCol55Starting enclosure for wall mountingPvCol57Midde enclosure for wall mountingPvCol74Midde enclosure for wall mountingPvCol74Divesting for dimetrials and partsCol74102.2 Strength of materials and partsMeets the product standard's requirements.102.3 Lowrification of resistance of insulating materials to abnormal heatNot applicable.102.3 Lowrification of resistance of insulating materials to abnormal heatNot applicable.102.4 Resistance to ultra-viole (UV) radiationPvMeets the product standard's requirements.102.5 UringNot applicable.Not applicable.102.5 UringMeets she product standard's requirements.Not applicable.102.6 Lowrange and distancesPvMeets she product standard's requirements.102.5 UringNot applicable.Not applicable.102.5 UringMeets she product standard's requirements.102.6 Lowrange and distancesPvMeets she product standard's requirements.102.6 Lowrange and compage distancesNot applicable.102.6 Lowrange and compage distancesPvMeets she product standard's requirements.105.7 InterrigitionState product standard's requirements.105.8 Comporation of svitching devices and componentsPvNot applicable.105.1 Rowrang and products and connectoresFvState panel builder's responsibility.<	Individual enclosure, free-standing	PV	C0	581
Individual anclosure for wall mountingPyC0Starting enclosure for wall mountingPyC0Middle enclosure for wall mountingPyC0Middle enclosure for wall mountingPyC0Total Starting enclosure for wall mountingPyC0102.2 Krength of materials and partsPyC0102.2 Corrosion resistancePyFe102.2 Corrosion resistance of insulating materials to normal headPyFe102.3 Verification of resistance of insulating materials to abnormal headFeMeets the product standard's requirements.102.3 Verification of resistance of insulating materials to abnormal headNot applicable.Not applicable.102.3 Verification of resistance of insulating materials to abnormal headNot applicable.Not applicable.102.3 Verification of resistance of insulating materials to abnormal headNot applicable.Not applicable.102.3 LordinaFeFeNot applicable.102.3 LordinaFeFeNot applicable.102.3 LordinaFeFeFe102.4 Resistance to involve insulationsNot applicable.Not applicable.102.5 LitingFeFeFe104.2 Resistance and compape distancesFeFe104.2 Resistance and compape distancesFeFe105.4 Corrostion of skitching devices and componentsFeFe105.4 Corrostion of skitching devices and componentsFeFe105.4 Corrostion of skitching devices instructionFeFe105.4 Corrosti	Starting enclosure, free-standing	P _V	CO	547
Starting enclosure for wall mounting Py CO 57 Middle enclosure for wall mounting Py CO 44 EVEX 61438 design verification Py CO 44 10.22 Corrosion resistance Middle netrolis and parts Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2.3.Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3.1 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.3.2.3.Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.3.2.4.Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5.Lring Not relevant to indoor installations. 10.2.5 Lring Ket spenalbuilder's responsibility. 10.2.5 Lring Ket spenalbuilder's responsibility. 10.3.0 Represe of protection of ASSEMBLIES Ket spenalbuilder's responsibility. 10.4.1 Creates the product standard's requirements. Ket panel builder's responsibility. 10.5.0 rotection against electric shock Ket p	Middle enclosure, free-standing	P _V	C0	490
Middle enclosure for wall mounting Pv C0 Middle enclosure for wall mounting Pv C0 Middle enclosure for wall mounting Pv C0 10.2 Strength of materials and parts Mets the product standard's requirements. 10.2.3 Verification of thermal stability of enclosures Mets the product standard's requirements. 10.2.3.1 Verification of resistance of insulating materials to normal head and fire due to internal electric effects Mets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to abnormal head and fire due to internal electric effects Not applicable. 10.2.3.1 Verification of resistance of insulating materials to abnormal head and fire due to internal electric effects Not applicable. 10.2.4 Resistance to ultra-violet (UV) radiation Mets Not relevant to indoor installations. 10.2.5 Urifing Not relevant to indoor installations. Not applicable. 10.3.0 Degree of protection of ASSEMBUES Mets the product standard's requirements. 10.3.0 Eque of protection against electric shock 4.01 Qr. meets the product standard's requirements. 10.4.1 Clearances and creepage distances 4.01 Qr. meets the product standard's requirements. 10.5.0 Frotection against electric is shock 4.01 Qr. meets the pro	Individual enclosure for wall mounting	P _V	C0	575
ECKN 61439 design verification Image: Comparison of the state o	Starting enclosure for wall mounting	P _V	CO	517
102.2 Strength of materials and parts Image: Construct of materials and parts Image: Construct of materials and parts 102.2 Corrosion resistance Mets the product standard's requirements. 102.3.1 Varification of themal stability of enclosures Mets the product standard's requirements. 102.3.2 Varification of resistance of insulating materials to abnormal heat Mets the product standard's requirements. 102.3.1 Varification of resistance of insulating materials to abnormal heat Mot applicable. 102.3.1 Varification of resistance of insulating materials to abnormal heat Mot applicable. 102.3.1 Varification of resistance of insulating materials to abnormal heat Mot applicable. 102.4 Resistance to ultra-violet (UV) rediation Mot applicable. 102.5 Methanical impact Mot applicable. 102.5 Infing Mets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Mets the product standard's requirements. 10.6 Incorporation of switching devices and components Is the panel builder's responsibility. 10.6 Incorporation of switching devices and components Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.2 Power	Middle enclosure for wall mounting	P _V	CO	474
10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to abnormal heat Not applicable. 10.2.3.3 Verification of resistance of insulating materials to abnormal heat Not applicable. 10.2.3.4 Verification of resistance of insulating materials to abnormal heat Not applicable. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Not relevant to indoor installations. 10.2.6 Mechanical impact Kt0 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Meets the product standard's requirements. 10.4 Clearances and creepage distances Is the panel builder's responsibility. 10.5 Incorporation of switching devices and components Is the panel builder's responsibility. 10.8 Incorporation of switching devices and components Is the panel builder's responsibility. 10.9 Ineruse Herewy electric strength Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9 Senset the product standard voltage Is VAC 10.9	IEC/EN 61439 design verification			
10.2.3.1 Verification of thermal stability of enclosuresMeets the product standard's requirements.10.2.3.2 Verification of resistance of insulating materials to abnormal heatNot applicable.10.2.3.3 Verification of resistance of insulating materials to abnormal heatNot applicable.10.2.3.4 Verification of resistance of insulating materials to abnormal heatNot applicable.10.2.4 Resistance to ultra-violet (UV) radiationMeets the product standard's requirements.10.2.4 Resistance to ultra-violet (UV) radiationMeets the product standard's requirements.10.2.5 LiftingNot relevant to indoor installations.10.2.7 InscriptionsK1010.2.7 InscriptionsNot speceed by a second as per the latest applicable instruction leaflet.10.3 Degree of protection of ASSEMBLIESInscriptions10.4 Clearances and creepage distancesNot apple abuilder's responsibility.10.5 Incorporation of switching devices and componentsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9 Insulation propertiesIs the panel builder's responsibility.10.9.2 Power/frequency electric strengthIs the panel builder's responsibility.10.9.3 Inpulse withstand voltageIs the panel builder is responsibility.10.9.4 Testing of enclosures made of insulating materialDees not apply to metal enclosures.10.9.1 Intermal electric riseIso not apply to metal enclosures.10.9.2 Power/frequency electric strengthDees not apply to metal enclosures.10.9.3 Impulse withstand voltageDees not apply to metal	10.2 Strength of materials and parts			
10.2.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effectsNot applicable.10.2.3 Striffication of resistance of insulating materials to abnormal heat and fire due to internal electric effectsNot applicable.10.2.4 Resistance to ultra-violet (UV) radiationNot relevant to indoor installations.10.2.5 LiftingNot relevant to indoor installations.10.2.6 Mechanical impactMet assembled and secured as per the latest applicable instruction leaflet.10.2.7 InscriptionsMets the product standard's requirements.10.3 Degree of protection of ASSEMBLIESIs the panel builder's responsibility.10.4 Clearances and creepage distancesIs the panel builder's responsibility.10.5 Protection against electric shockIs the panel builder's responsibility.10.6 Incorporation of switching devices and componentsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9 Insulation propertiesU, esson VAC10.9.2 Power-frequency electric strengthU, esson VAC10.9.3 Impulse withstand voltageIs the panel builder is responsibility.10.9.4 Testing of enclosures made of insulating materialDoes not apply to metal enclosures.10.10 Temperature riseDes not apply to metal enclosures.	10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Not applicable. 10.2.4 Resistance to ultra-violet (UV) radiation Not relevant to indoor installations. 10.2.5 Lifting Not relevant to indoor installations. 10.2.6 Mechanical impact Kto 10.2.7 Inscriptions Kto 10.3 Degree of protection of ASSEMBLIES Not applicable instruction leaflet. 10.4 Clearances and creepage distances FP55 10.4 Clearances and creepage distances State panel builder's responsibility. 10.5 Protection against electric shock State panel builder's responsibility. 10.6 Incorporation of switching devices and components Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.1 Power-frequency electric strength Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Kto 10.9.3 Impulse withstand voltage Get V 10.9.4 Testing of enclosures made of insulating material Dees not apply to metal enclosures. 10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton will provide heat	10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
and fire due to internal electric effectsAnd fire due to internal electric effects10.2.4 Resistance to ultra-violet (UV) radiationNot relevant to indoor installations.10.2.5 LiftingMet; assembled and secured as per the latest applicable instruction leaflet.10.2.6 Mechanical impactK1010.2.7 InscriptionsMets the product standard's requirements.10.3.0 Begree of protection of ASSEMBLIESISE10.4 Clearances and creepage distancesIst the panel builder's responsibility.10.5 Protection against electric shockIst the panel builder's responsibility.10.6 Incorporation of switching devices and componentsIst the panel builder's responsibility.10.7 Internal electrical circuits and connectionsIst the panel builder's responsibility.10.8 Connections for external conductorsIst the panel builder's responsibility.10.9 Insulation propertiesIst epanel builder's responsibility.10.9.2 Power-frequency electric strengthIst epanel builder's responsibility.10.9.3 Impulse withstand voltageIst on an apply to metal enclosures.10.10 Temperature riseDes not apply to metal enclosures.10.10 Temperature riseThe panel builder's responsibil for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.	10.2.3.2 Verification of resistance of insulating materials to normal heat			Not applicable.
10.2.5 LiftingMet; assembled and secured as per the latest applicable instruction leaflet.10.2.6 Mechanical impactK1010.2.7 InscriptionsMets the product standard's requirements.10.3 Degree of protection of ASSEMBLIESIP5510.4 Clearances and creepage distancesSt the panel builder's responsibility.10.5 Protection against electric shock< 0.1 0; meets the product standard's requirements.				Not applicable.
10.2.6 Mechanical impactK1010.2.7 InscriptionsMeets the product standard's requirements.10.3 Degree of protection of ASSEMBLIESIP5510.4 Clearances and creepage distancesIs the panel builder's responsibility.10.5 Protection against electric shock< 0.1 Ω; meets the product standard's requirements.	10.2.4 Resistance to ultra-violet (UV) radiation			Not relevant to indoor installations.
10.2.7 InscriptionsMeets the product standard's requirements.10.3 Degree of protection of ASSEMBLIESP5510.4 Clearances and creepage distancesIs the panel builder's responsibility.10.5 Protection against electric shock< 0.1 0; meets the product standard's requirements.	10.2.5 Lifting			Met; assembled and secured as per the latest applicable instruction leaflet.
10.3 Degree of protection of ASSEMBLIES P55 10.4 Clearances and creepage distances Is the panel builder's responsibility. 10.5 Protection against electric shock <	10.2.6 Mechanical impact			IK10
10.4 Clearances and creepage distancesIs the panel builder's responsibility.10.5 Protection against electric shock<	10.2.7 Inscriptions			Meets the product standard's requirements.
10.5 Protection against electric shockImage: state st	10.3 Degree of protection of ASSEMBLIES			IP55
10.6 Incorporation of switching devices and components Is the panel builder's responsibility. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.	10.4 Clearances and creepage distances			Is the panel builder's responsibility.
10.7 Internal electrical circuits and connectionsImage: section of the				
10.8 Connections for external conductors Image: Content of the panel builder's responsibility. 10.9 Insulation properties Image: Content of the panel builder's responsibility. 10.9.2 Power-frequency electric strength Image: Content of the panel builder's responsibility. 10.9.3 Impulse withstand voltage Image: Content of the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Image: Content of the panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.	10.6 Incorporation of switching devices and components			Is the panel builder's responsibility.
10.9 Insulation propertiesFMFM10.9.2 Power-frequency electric strengthMM10.9.3 Impulse withstand voltageMFM10.9.4 Testing of enclosures made of insulating materialMFM10.10 Temperature riseMFMDoes not apply to metal enclosures.10.10 Temperature riseMFMFM10.10 Temperature riseFMFMFM10.10 Temp	10.7 Internal electrical circuits and connections			
10.9.2 Power-frequency electric strength Image: Power-frequency electric strength Image: Power-frequency electric strength Image: Power-frequency electric strength 10.9.3 Impulse withstand voltage Image: Power-frequency electric strength Image: Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material Image: Power-frequency electric strength Image: Power-frequency electric strength 10.10 Temperature rise Image: Power-frequency electric strength Image: Power-frequency electric strength	10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage 6 kV 10.9.4 Testing of enclosures made of insulating material 0 cos not apply to metal enclosures. 10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.				
10.9.4 Testing of enclosures made of insulating material Does not apply to metal enclosures. 10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.	10.9.2 Power-frequency electric strength			U _i = 690 V AC
10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.	10.9.3 Impulse withstand voltage			6 kV
provide heat dissipation data for the devices.	10.9.4 Testing of enclosures made of insulating material			Does not apply to metal enclosures.
10.11 Short-circuit rating Is the panel builder's responsibility.	10.10 Temperature rise			
	10.11 Short-circuit rating			Is the panel builder's responsibility.

10.12 Electromagnetic compatibility

Is the panel builder's responsibility.

Meets the product standard's requirements.

Technical data ETIM 6.0

10.13 Mechanical function

Cabinet enclosures (EG000011) / Enclosure/switchgear cabinet (empty) (EC000261)

Electric engineering, automation, process control engineering / Electrical cabinet, h	ousing, rack / Electrica	l cabinet (empty) / Electrical cabinet (ecl@ss8.1-27-18-01-01 [AGZ056013])
Width	mm	600
Height	mm	2000
Depth	mm	800
Material		Steel
Type of surface		With powder coating
Colour		Grey
RAL-number		7035
With mounting plate		Yes
Mounting plate depth-adjustable		No
Number of locks		1
Floor installation possible		Yes
Wall fastening possible		Yes
Wall build in		No
Pole fastening		No
Tackable		Yes
Number of doors		1
Suitable for metrical mounting		Yes
Suitable for outdoor set-up		No
Pitched roof		No
EMC-version		Yes
Impact strength		IK10
Degree of protection (IP)		•
With glazed door		No
With ventilation door		No
With backside door		No