

Circuit-breaker 3p, 800A, fixed

Part no. Article no. IZMX16B3-V08F 123347



Delivery programme

Product range			Air circuit-breakers/switch-disconnectors
Product range			Open circuit-breakers
Current Range			Up to 4000 A
Protective function			Selective operation
Installation type			Fixed
Construction size			IZMX16
Release system			Electronic release
Standard/Approval			IEC
Number of poles			3 pole
Degree of Protection			IP20, IP55 with protective cover, IP41 door sealing frame
			suitable for zone selectivity optionally fittable by user with comprehensive accessories
Rated current = rated uninterrupted current	$I_n = I_u$	А	800
Breaking capacity Icu = Ics to 440 V 50/60 Hz	I _{cu}	kA	42
Breaking capacity Ics to 440 V 50/60 Hz	I _{cs}	kA	42
Overload release, min.	l _r	А	400
Overload release, max.	l _r	А	800
Non-delayed	I _i = I _n x		2 - 12, OFF
Delayed	$I_{sd} = I_r x \dots$		2 - 10
Notes			
Main terminals not included, need to be ordered separately.			

Technical data

Standards			IEC/EN 60947
Ambient temperature			
Storage	θ	°C	-40 - +70
Operating (open)		°C	-25 - +70
Mounting position			
			30° 30°
Utilization category			В
Degree of Protection			IP20, IP55 with protective cover, IP41 door sealing frame
Direction of incoming supply			as required
Main conducting paths			
Rated current = rated uninterrupted current	$I_n = I_u$	А	800

Retail unitarry ped current st 3° CIIA80Retail unitarry ped current st 3° CIA80Retail ingeling during st 37 °CVA100Retail ingeling during st 37 °CVA80Retail index index ing 51 - 440 VNVA80Retail index ingeling during st 440 VNN80Strickling string string st 300 N/CN80NStrickling string st 300 N/CN80NStrickling string st 300 N/CN80NStrickling st 300 N/CN <td< th=""><th></th></td<>	
Retar universay to 'C'NNNRetar universay to U and YNoNORetar universay to U and YNNONoNON	I _u A 800
Rated injulie withstant valageUmUmVAC1200Rated injulies withstant valageUpVAC000Verindig extensional valageUpVAC100Switching expectingUpVAC100Switching expecting SwitchingUpVAC100Up to XW SWITching expecting Switching ExpectingUpVAC100Up to XW SWITching ExpectingSwitchingUpUpUp to XW SWITching ExpectingSwitchingUpUpUp to XW SWITching Expecting<	I _u A 800
Read operational ordengeUVVVVUse int decidination denomination is up to U = 440 VintintintDeveloping catagory/polition degreeUVVVRead intuitation watery operation degreeUVVVSwitching capacityLVVVVSwitching capacityLVVVVSwitching capacityLVVVVVSwitching capacity LLVVVVVIt of 100 VS000 M/cLVVVVVVRead short-circuit making capacity LLVV </td <td>l_u A 800</td>	l _u A 800
Bue in It electrical power networks up to U = 44U // Our or bases of support of the subsection whapeIf<	U _{imp} V AC 12000
Bue in It electrical power networks up to U = 44U // Our or bases of support of the subsection whapeIf<	
Derevolution category polulation oblageIIIIIIIRated nut-ciccle landing capacityICIIIIStruct shurt-ciccle landing capacityICIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIII	
Reted inside ion uoting capacityUV000Switching capacityIIBread abort circuit maining capacityIIIup to 490 MaiIIIIToto 1980 MaiIIIIRated abort circuit maining capacity IcanIIIIItot 15IIIIIRated abort circuit maining capacity IcanIIIIIItot 240 V 500 MaiIIIIIIItot 240 V 500 MaiII	
Switching capacitycmRated vicuul making capacityImImip to 400 V5000 H2ImImIt isImImRated short-circuit making capacity ImImImIt isImImImRated short-circuit making capacity ImImImIt isImImImIt isImIm	
Reted short-circuit making capacityIonIonIonip to 600 V5000 HzIonIonIonReted short-forcuit foreking capacity forIonIonIonip to 600 V5000 HzIonIonIonip to 600 V5000 HzIonIonIonip to 600 V5000 HzIonIonIonip to 200 V5000 HzIonIonIonip to 400 V5000 HzIonIonIonip to 600 V5000 HzIonIonIonip to 700 V5000 HzIonIon <td></td>	
up to 480 Y8080 HzHmKA88Bated short-time withstand current 5080 Hz	I _{cm}
up 060 VS000HzManManManManManManRind Shot Shot Shot Shot Shot Shot Shot Shot	
Released with stand current 500 HzNoNoNoNoI = 1 sNoNoNoNoI = 1 sNoNoNoNoI = 1 sNoNoNoNoI = 0 200 V5000 HzNoNoNoNoU = 0 200 V5000 HzNoNo <t< td=""><td></td></t<>	
t = 1 sInvKaZBited short-circuit breaking capacity lanIaIaIaIECEN 08947 operating sequence lag 0-1-COIaKAZup to 240 V 5060 HzIaKAZup to 350 V 5060 HzIaKAZup to 240 V 5060 HzIaKAZUp to 500 V 5060 HzIaKAZChoing delay via shurt releaseIaKAZTotal opening delay via shurt releaseIaIaIaTotal opening delay via shurt releaseIaIaIaItIaIaIaIaIaItIaIaIaIaIaItIaIaIaIaIa<	
Reted short-circuit breaking capacity I _{an} In IEC/EN 60947 operating sequence I _{an} 0-LOD Icu KA up to 240 V 5060 Hz Icu KA up to 680 V 5060 Hz Icu KA IEC/EN 60947 operating sequence I _{an} 0-LOD-COD Icu KA up to 680 V 5060 Hz Icu KA up to 240 V 5060 Hz Icu KA up to 260 V 5060 Hz Icu KA up to 260 V 5060 Hz Icu KA Up to 580 V 5060 Hz Icu KA Operating times Icu KA Chosing delay via spring release Icu Icu Total opening delay via spring release Icu Icu Total opening delay via spring release Icu Icu Itlespan, mechanical Icu S Itlespan, mechanical Icu S Itlespan, electrical Icu Icu Itlespan, electrical Icu Icu Itlespan, electrical Icu Ic	μ kΔ 42
IECECH 60947 operating sequence log 0-1-00ICUICUICUICUup to 240 V 50/60 HzIcuIcuIcuIcuIcuIcuup to 690 V 50/60 HzIcuIcuIcuIcuIcuIcuup to 240 V 50/60 HzIcuIcuIcuIcuIcuIcuup to 560 V 50/60 HzIcuIcuIcuIcuIcuIcuup to 560 V 50/60 HzIcuIcuIcuIcuIcuIcuUp to 560 V 50/60 HzIcuIcuIcuIcuIcuIcuTotal opening delay via shurt releaseIcuIcuIcuIcuIcuIcuIcuIte span, mechanicalIcu	
up to 240 Y5080 HzIcuKA2up to 440 Y5080 HzIcuKA2up to 580 Y5080 HzIcuKA2ibEZPN 86947 operating sequence Icu 0+t-C0-t-C0IcuKA2up to 240 Y5080 HzIcuKA2up to 580 Y5080 HzIcuKA3Operating timesIcuKA3Total opening delay via undervoltage releasems3Total opening delay via undervoltage releasems3Itespan, mechanicalSvitching Vices ION Viers ION Vier	'cn
up to 440 Y 50%0 HzIcuKA2up to 680 Y 50%0 HzIcuKA42ib C/EN 60947 operating sequence Icu 0+-C0-C0IcuKA42up to 240 Y 50%0 HzIcuKA42up to 240 Y 50%0 HzIcuKA42up to 680 Y 50%0 HzIcuKA42up to 680 Y 50%0 HzIcuKA42Operating timesIcuMA42Closing delay via spring releaseIcuMa50Total opening delay via undervoltage releaseIcuma50If tegpan, mechanicalIcuMax50Lifespan, mechanicalSwrtching OFFFIcu10000Lifespan, electricalSwrtching OFFFIcu10000Maximun operating frequencyOperations (Inventional Sector)Icu10000Maximun operating frequencyOperations (Inventional Sector)Icu10000Fixed mountingIcuIcuIcu10000Fixed mountingIcuIcuIcu10000Fixed mountingIcuIcuIcu10000Fixed mountingIcuIcuIcu10000Fixed mountingIcuIcuIcu10000Fixed mountingIcuIcuIcu10000Fixed mountingIcuIcuIcuIcu10000If the space (Icu Circle Icu Cir	
up to 680 V 50/60 Hz Iou Ka Ka 4 IEC/EN 60947 operating sequence I _s 0CO-4-CO Iou Iou 4 up to 240 V 50/60 Hz Ics KA 42 up to 680 V 50/60 Hz Ics KA 42 Operating times Ics KA 42 Closing delay via spring release ms 30 Total opening delay via spring release ms 50 Total opening delay on non-delayed short-circuit release (up to complete arc quenching) ms 25 Lifespan, mechanical Switching queries ms 25 Lifespan, mechanical Switching cycles (N/V) FFF 25 Lifespan, mechanical with maintenance Switching cycles (N/V) 1000 20000 Lifespan, electrical with maintenance Switching cycles (N/V) 10000 10000 Mainum operating frequency Perating N Perating N 10000 Mainum operating frequency Perating N 10000 10000 Mainum operating frequency Perating N 10000 10000 <td< td=""><td></td></td<>	
IEC/N 00947 operating sequence leg 0-t-CO-t-CO Iee KA 4 up to 240 V 50/60 Hz Iee KA 42 up to 680 V 50/60 Hz Iee KA 42 operating times Iee KA 42 Closing delay via spring release ms 30 Total opening delay via underoltage release ms 50 Total opening delay on non-delayed short-circuit release (up to complete ar quenching) ms 25 Itespan, mechanical S 5 Lifespan, mechanical Switching cycles (0W) GFF 25 Lifespan, electrical Switching cycles (0W) GFF 26 Kaimum operating frequency Switching cycles (0W) GFF 10000 Kaim	
up to 240 Y50/60 HzIsKaKaKaup to 450 Y50/60 HzIsKaKaKaUp to 590 Y50/60 HzIsKaKaKaOperating timesIsIsIsIsClosing delay via spring releaseIsIsIsIsTotal opening delay via shunt releaseIsIsIsIsTotal opening delay via shunt releaseIsIsIsIsTotal opening delay via undervoltage releaseIsIsIsIsTotal opening delay via undervoltage releaseIsIsIsIsTotal opening delay on non-delayed short-circuit release (up to complete at generating for gener	I _{cu} kA 42
up to 440 V\$000 Hz Is Au 42 up to 690 V\$000 Hz Ka A2 Operating times ns 30 Closing delay via spring relesse ns 30 Total opening delay via shurt release ns 30 Total opening delay via undervoltage release ms 30 Total opening delay on non-delayed short-circuit release (up to complete or queenching) ms 30 Ifespan ms 30 30 Lifespan, mechanical ms 30 30 Lifespan, mechanical with maintenance Switching cycles (0W) cycles (0W) cyc	
up to 890 V50/60 Hz Is Mathematical strength Mathematica	I _{cs} kA 42
Operating times Image: Closing delay via spring release ms 3 Closing delay via spring release ms 5 Total opening delay via shurt release ms 5 Total opening delay via undervoltage release ms 5 Total opening delay on non-delayed short-circuit release (up to complete ar quenching) ms 5 Lifespan S 5 Lifespan, mechanical Switching cycles (0N/ OFF) Switching cycles (0N/ OFF) Lifespan, mechanical with maintenance Switching cycles (0N/ OFF) Switching cycles (0N/ OFF) Lifespan, electrical Switching cycles (0N/ OFF) Switching cycles (0N/ OFF) Switching cycles (0N/ OFF) Lifespan, electrical with maintenance Switching cycles (0N/ OFF) Switching cycles (0N/ OFF) Switching cycles (0N/ OFF) Lifespan, electrical with maintenance Switching cycles (0N/ OFF) Switching cycles (0N/ OFF) Switching cycles (0N/ OFF) Lifespan, electrical with maintenance Switching cycles (0N/ OFF) Switching cycles (0N/ OFF) Switching cycles (0N/ OFF) Lifespan, electrical with maintenance Switching cycles (0N/ OFF) Switching cycles (0N/ OFF) Switching cycles (0N/ OFF) Kaat mounting Switching cycles (0N/	I _{cs} kA 42
Closing delay via spring release in ms 3 Total opening delay via shunt release ms 5 Total opening delay via undervoltage release ms 5 Total opening delay via undervoltage release ms 25 Total opening delay on non-delayed short-circuit release (up to complete ar quenching) S 3 Lifespan S 5 Lifespan, mechanical Switching cycles (ON/ OFF) S Lifespan, mechanical with maintenance Switching cycles (ON/ OFF) S Lifespan, electrical Switching cycles (ON/ OFF) S Lifespan, electrical with maintenance Switching cycles (ON/ OFF) S Maximum operating frequency O O Maximum operating frequency O O Fixed mounting O O O Solo S S S Solo V S S Fixed mounting O O S Solo S S S Solo S S S Fixed mounting S S S	I _{cs} kA 42
Total opening delay via shuht release 5 Total opening delay via undervoltage release 50 Total opening delay via undervoltage release ms 5 Total opening delay on non-delayed short-circuit release (up to complete ar quenching) ms 5 Lifespan So 5 Lifespan, mechanical Switching cycles (ON GFF) So Lifespan, mechanical with maintenance Switching cycles (ON GFF) So Lifespan, electrical Switching cycles (ON GFF) So Lifespan, electrical Switching cycles (ON GFF) So Lifespan, electrical with maintenance Switching cycles (ON GFF) So Kakimum operating frequency Operationsh So Maximum operating frequency Operationsh So Fixed mounting V So Weight So So Sopole So So Fixed mounting So So Sopole Sopole So Apole Sopole Sopole Fixed mounting Sopole Sopole Sopole Sopole Sopole <	
Total opening delay via undervoltage release no no 5 Total opening delay on non-delayed short-circuit release (up to complete ar quenching) ns 2 Lifespan so 5 Lifespan, mechanical switching cycles (N) OFF) fm 25000000000000000000000000000000000000	ms 30
Total opening delay on non-delayed short-circuit release (up to complete arc quenching) ms 25 Lifespan s s Lifespan, mechanical Switching cycles (DN/ OFF) a 25 Lifespan, mechanical with maintenance Switching cycles (DN/ OFF) a 25 Lifespan, mechanical with maintenance Switching cycles (DN/ OFF) a 25 Lifespan, electrical with maintenance Switching cycles (DN/ OFF) a 2000 Lifespan, electrical with maintenance Switching cycles (DN/ OFF) a a Maximum operating frequency Operations/h a a Heat dissipation at rated current In a a a Fixed mounting a a a 3-pole a a a 4-pole a a a Terminal capacities a a a	ms 25
quenching) quenching quenching quenching Lifespan, mechanical Switching cycles (0N/ OFF) 12500 Lifespan, mechanical with maintenance Switching cycles (0N/ OFF) 2000 Lifespan, electrical Switching cycles (0N/ OFF) 10000 Lifespan, electrical with maintenance Switching cycles (0N/ OFF) 10000 Lifespan, electrical with maintenance Switching cycles (0N/ OFF) 10000 Maximum operating frequency Operationsh F Heat dissipation at rated current In Synole P 0 Fixed mounting W 5 Veight F M 10000 Triced mounting M 5 10000 3-pole W 5 10000 10000 Triced mounting M 5 10000 10000 10000 10000 Fixed mounting W S 10000 10000 10000 10000 10000 10000 10000 10000 10000 10000 10000 10000 10000 10000 10000 100000 100000 1	ms 50
Lifespan, mechanical witching cycles (0N/ OFF) 1200 Lifespan, mechanical with maintenance Switching cycles (0N/ OFF) 2000 Lifespan, electrical Switching cycles (0N/ OFF) 1000 Lifespan, electrical with maintenance Switching cycles (0N/ OFF) 1000 Maximum operating frequency Operations/h CFF) 1000 Maximum operating frequency Operations/h CFF) 0 Fixed mounting W 5 Weight Versit Versit Fixed mounting M 1000 3-pole Kg 1000 3-pole	ise (up to complete arc ms 25
Lifespan, mechanical with maintenance Switching cycles (ON/ OFF) 2000 Lifespan, electrical Switching cycles (ON/ OFF) 0000 Lifespan, electrical Switching cycles (ON/ OFF) 0000 Lifespan, electrical with maintenance Switching cycles (ON/ OFF) 0000 Maximum operating frequency Operations/h 0000 Maximum operating frequency Operations/h 0000 Fixed mounting V 9 Weight V 9 3-pole kg 10 3-pole kg 9 3-pole kg 10 4-pole kg 10	S
Lifespan, electrical Switching cycles (0N/ OFF) 10000 Lifespan, electrical with maintenance Switching cycles (0N/ OFF) 10000 Maximum operating frequency Operationsh 10000 Heat dissipation at rated current In Operationsh 0 Fixed mounting W 59 Weight V 59 Tixed mounting M 1000 3-pole Image: Marce Ma	cycles (0N/
Lifespan, electrical with maintenance Switching cycles (0N/ OFF) 10000 Maximum operating frequency Operations/h 60 Heat dissipation at rated current In V 59 Fixed mounting V 59 Weight Image: Spole Image: Spole 3-pole kg 19 4-pole kg 24	cycles (0N/
Kaximum operating frequency Operations/h 60 Heat dissipation at rated current In 0 0 0 Fixed mounting W 59 Weight 59 50 Fixed mounting Image: Second Secon	cycles (0N/
Heat dissipation at rated current In W Fixed mounting W Weight Fixed mounting I 3-pole I 4-pole I 2-pole I	cycles (ON/
Fixed mountingW59Weight59Fixed mounting3-pole4-polekg19Terminal capacities	Operations/h 60
Weight Fixed mounting 3-pole 4-pole Kg 19 Kg 24	
Fixed mounting Image: Market	W 59
3-pole kg 19 4-pole kg 24	
4-pole kg 24 Terminal capacities	
Terminal capacities	kg 19
	kg 24
Lopper Dar	
Fixed mounting	
Fixed mounting	
Black mm 2 x 5 x 50	mm 2 x 5 x 50
Withdrawable units	
the temperature around the circuit-breaker, which is influence	mm 2 x 5 x 50 These are values used in separate switchgear. The actual values will depend on the temperature around the circuit-breaker, which is influenced by the ambient temperature, the degree of protection (IP), the mounting height, the partitions, and

any external ventilation. Depending on the specific switchgear design, this may result in derating, which can then be compensated for by increasing the crosssectional area. Temperature rise tests in the specific switchgear can provide specific and detailed information.

Permissible continuous current for circuit-breakers operating in switchboards at various internal ambient temperatures. The switchboard's internal ambient temperature should be estimated using the calculation methods of IEC regulation.

Design verification as per IEC/EN 61439

Technical data for design verification			
Rated operational current for specified heat dissipation	In	А	800
Equipment heat dissipation, current-dependent	P _{vid}	W	59
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	70
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 6.0

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation prot. (EC000228)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss8.1-27-37-04-09 [AJZ716010])

Rated permanent current lu	А	800
Rated voltage	V	690 - 690
Rated short-circuit breaking capacity Icu at 400 V, 50 Hz	kA	42
Overload release current setting	А	400 - 800
Adjustment range short-term delayed short-circuit release	А	1600 - 8000
Adjustment range undelayed short-circuit release	А	1600 - 9600
Integrated earth fault protection		No
Type of electrical connection of main circuit		Rail connection
Device construction		Built-in device fixed built-in technique
Suitable for DIN rail (top hat rail) mounting		No
DIN rail (top hat rail) mounting optional		No

Number of auxiliary contacts as normally closed contact	0
Number of auxiliary contacts as normally open contact	0
Number of auxiliary contacts as change-over contact	2
Switched-off indicator available	Yes
With under voltage release	No
Number of poles	3
Position of connection for main current circuit	Back side
Type of control element	Push button
Complete device with protection unit	Yes
Motor drive integrated	No
Motor drive optional	Yes
Degree of protection (IP)	IP20

Dimensions

