



At the end of this document you will find links to products related to this catalog. You can go directly to our shop by clicking HERE. HERE



# Protective hose - WR/PG21-50M - 1666867

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (http://phoenixcontact.com/download)

Protective hose, for protective house screw connection, packing volume: 50 m, Pg21

## **Key Commercial Data**

Packing unit	1 STK		
GTIN	4 017918 136512		

### Technical data

#### Ambient conditions

Ambient temperature (operation)	-40 °C 110 °C
General	

#### General

Pg screw connection	Pg21
Material	PA
Flammability rating according to UL 94	НВ
Color	gray
Bending radius, static	55.00 mm

### Standards and Regulations

Flammability rating according to UL 94	НВ

### Classifications

### eCl@ss

eCl@ss 4.0	27141209
eCl@ss 4.1	27141209
eCl@ss 5.0	27149109
eCl@ss 5.1	27149109
eCl@ss 6.0	27149109
eCl@ss 7.0	27149109
eCl@ss 8.0	27430201

#### **ETIM**

ETIM 2.0	EC000441
ETIM 3.0	EC000441
ETIM 4.0	EC000441
ETIM 5.0	EC001175



# Protective hose - WR/PG21-50M - 1666867


### Classifications

### **UNSPSC**

UNSPSC 6.01	30211808
UNSPSC 7.0901	39121408
UNSPSC 11	39121408
UNSPSC 12.01	39121408
UNSPSC 13.2	39121408

### **Drawings**

#### Dimensional drawing



Assembly instructions for Pg21 corrugated pipe

a = Corrugated screw connection


B = Corrugated pipe

c = Opener

Installation note:

Cut the corrugated pipe in the groove to retain a round shape for insertion. The lighter seal (not depicted in the illustration) is positioned in the corrugated pipe screw connection below the safety latch. The darker outer seal (not depicted in the illustration) is placed over the corrugated pipe screw connection from outside. The corrugated pipe is then pushed as far as possible into the corrugated pipe screw connection then pushed as far as possible into the corrugated pipe screw connection and clicks into place. The screw connection is opened by placing the yellow corrugated pipe opener with force between the safety latch and theyellow corrugated pipe opener with force between the safety latch and the corrugated tube and the corrugated pipe is then pulled out.

#### Dimensional drawing



Assembly instructions for M25 corrugated pipe

a = Corrugated screw connection

b = Corrugated pipe

c = Opener

Installation note:

Cut the corrugated pipe in the groove to retain a round shape for insertion. The lighter seal (not depicted in the illustration) is positioned in the corrugated pipe screw connection below the safety latch. The darker outer seal (not depicted in the illustration) is placed over the corrugated pipe screw connection from outside. The corrugated pipe is and clicks into place. The screw connection is opened by placing the corrugated tube and the corrugated pipe is then pulled out.

Phoenix Contact 2016 @ - all rights reserved http://www.phoenixcontact.com

PHOENIX CONTACT GmbH & Co. KG Flachsmarktstr. 8 32825 Blomberg Germany

Tel. +49 5235 300 Fax +49 5235 3 41200

http://www.phoenixcontact.com





Below is a list of articles with direct links to our shop Electric Automation Network where you can see:

- Quote per purchase volume in real time.
- Online documentation and datasheets of all products.
- Estimated delivery time enquiry in real time.
- Logistics systems for the shipment of materials almost anywhere in the world.
- Purchasing management, order record and tracking of shipments.

To access the product, click on the green button.

Product	Code	Reference	Product link
Protective hose, for protective house screw connection, packing volume: 50 m, Pg21	1666867	WR/ PG21-50M	Buy on EAN