



Installation distribution board, HxWxD=510x600x262mm, IP54

Part no. **BPM-O-600/4.5-IVS**
 Catalog No. **111366**

Delivery program

Product range			Service distribution board IVS
Basic function			Wall-mounting distribution system
Single unit/Complete unit			Complete housing
Degree of Protection			IP55
Description			Profi Plus basic enclosures Monoblock enclosure with door and double ward key lock The enclosure can be turned through 180° for cable entry from below.
Material			Sheet steel
Surface finish			Polyester powder coating Phosphated RAL 7035, light grey
Colour			light gray (RAL 7035)
Information about equipment supplied			Including mounting system for the IVS mounting units including insulating surround and mounted insulated support bracket including open cable entry at top, prepared for F3A flanges, closed at bottom
Width		mm	600
Height		mm	510
Depth		mm	270

Technical data

General

Standards			EN 60439-1/3 IEC 62208
Protection class			1
Degree of Protection			IP55
Power loss			
Max. admissible heat dissipation, ambient air temperature +35 °C		W	108
Weight		kg	22.7

Material characteristics

Material			Sheet steel
Surface treatment			Painting, phosphated and polyester powder coating
Surface finish			Polyester powder coating Phosphated RAL 7035, light grey
Colour			light gray (RAL 7035)
Material characteristics			
Type Door			Doors with covered hinges Can be removed from 90°
door opening angle			100° (single mounting)
Door interlock			Hinge handle with roller lever lock Cylinder lock Double-ward lock

Material properties

Mechanical			
Impact resistance			IK07
Cable entry			Open cable entry, prepared for F3A flanges
Electrical			
Rated operational voltage	U_e	V	690
Rated frequency	f	Hz	50
Rated operational current	I_e	A	630
Max. admissible heat dissipation, ambient air temperature +35 °C		W	108

Earthings			M6 weld stud (base frame) M5 self-tapping screw (enclosure side plate, top/bottom panel) M6 weld stud (door)
-----------	--	--	--

Design verification as per IEC/EN 61439

Technical data for design verification			
Heat dissipation, at an ambient temperature of 35°C, delta T: 20 degrees in top of the enclosure, calculated as per IEC 60890			
Individual enclosure for wall mounting	P _V	CO	57
Starting enclosure for wall mounting	P _V	CO	54
Middle enclosure for wall mounting	P _V	CO	51
Heat dissipation, at an ambient temperature of 35°C, delta T: 35 degrees in top of the enclosure, calculated as per IEC 60890			
Individual enclosure for wall mounting	P _V	CO	114
Starting enclosure for wall mounting	P _V	CO	108
Middle enclosure for wall mounting	P _V	CO	101
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			
Meets the product standard's requirements.			
10.2.3.1 Verification of thermal stability of enclosures			
Meets the product standard's requirements.			
10.2.3.2 Verification of resistance of insulating materials to normal heat			
Meets the product standard's requirements.			
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			
Meets the product standard's requirements.			
10.2.4 Resistance to ultra-violet (UV) radiation			
Not relevant to indoor installations.			
10.2.5 Lifting			
Does not apply to enclosures without lifting aids.			
10.2.6 Mechanical impact			
IK10			
10.2.7 Inscriptions			
Meets the product standard's requirements.			
10.3 Degree of protection of ASSEMBLIES			
IP55			
10.4 Clearances and creepage distances			
Is the panel builder's responsibility.			
10.5 Protection against electric shock			
< 0.1 Ω; meets the product standard's requirements.			
10.6 Incorporation of switching devices and components			
Is the panel builder's responsibility.			
10.7 Internal electrical circuits and connections			
Is the panel builder's responsibility.			
10.8 Connections for external conductors			
Is the panel builder's responsibility.			
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			
U _i = 440 V AC			
10.9.3 Impulse withstand voltage			
4 kV			
10.9.4 Testing of enclosures made of insulating material			
Does not apply to metal enclosures.			
10.10 Temperature rise			
The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.			
10.11 Short-circuit rating			
Is the panel builder's responsibility.			
10.12 Electromagnetic compatibility			
Is the panel builder's responsibility.			
10.13 Mechanical function			
Meets the product standard's requirements.			