



**Floor standing distribution board**

**Part no.** BP-F-1200/17/3-F-IVS-W  
**Catalog No.** 111409

**Delivery program**

Product range			Service distribution board IVS
Basic function			Floor-standing enclosures
Single unit/Complete unit			Complete housing
Degree of Protection			IP30 (only with door)
Description			Profi Plus basic enclosures without door Exchangeable door hinges
Material			Sheet steel
Surface finish			Polyester powder coating Phosphated RAL 9016, traffic white
Colour			RAL 9016, traffic white
Information about equipment supplied			Including mounting system for the IVS mounting units including insulating surround and mounted insulated support bracket including cable entry top and bottom, with push-through flange
Width		mm	1200
Height		mm	1760
Depth		mm	300

**Technical data**

**General**

Standards			EN 60439-1/3 IEC 62208
Protection class			1
Degree of Protection			IP30 (only with door)
Power loss			
Max. admissible heat dissipation, ambient air temperature +35 °C		W	474
Weight		kg	64.7

**Material characteristics**

Material			Sheet steel
Surface treatment			Painting, phosphated and polyester powder coating
Surface finish			Polyester powder coating Phosphated RAL 9016, traffic white
Colour			RAL 9016, traffic white
Material characteristics			
Type Door			Doors with covered hinges Can be removed from 90°
door opening angle			167° (single mounting) 60° (combination mounting)
Door interlock			Hinge handle with three-point turn-lock Cylinder lock

**Material properties**

Mechanical			
Impact resistance			IK07
Cable entry			Various covers allow cable entry from above and/or below
Electrical			
Rated operational voltage	U <sub>e</sub>	V	690
Rated frequency	f	Hz	50

Rated operational current	$I_e$	A	630
Max. admissible heat dissipation, ambient air temperature +35 °C		W	474
Earthings			M6 weld stud (base frame) M5 self-tapping screw (enclosure side plate, top/bottom panel) M6 weld stud (door)

## Design verification as per IEC/EN 61439

Technical data for design verification			
Heat dissipation, at an ambient temperature of 35°C, delta T: 20 degrees in top of the enclosure, calculated as per IEC 60890			
Individual enclosure, free-standing	$P_V$	CO	272
Starting enclosure, free-standing	$P_V$	CO	264
Middle enclosure, free-standing	$P_V$	CO	257
Individual enclosure for wall mounting	$P_V$	CO	237
Starting enclosure for wall mounting	$P_V$	CO	233
Middle enclosure for wall mounting	$P_V$	CO	231
Heat dissipation, at an ambient temperature of 35°C, delta T: 35 degrees in top of the enclosure, calculated as per IEC 60890			
Individual enclosure, free-standing	$P_V$	CO	546
Starting enclosure, free-standing	$P_V$	CO	530
Middle enclosure, free-standing	$P_V$	CO	515
Individual enclosure for wall mounting	$P_V$	CO	474
Starting enclosure for wall mounting	$P_V$	CO	467
Middle enclosure for wall mounting	$P_V$	CO	463
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Not relevant to indoor installations.
10.2.5 Lifting			Met; assembled and secured as per the latest applicable instruction leaflet.
10.2.6 Mechanical impact			IK07
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			IP30
10.4 Clearances and creepage distances			Is the panel builder's responsibility.
10.5 Protection against electric shock			< 0.1 Ω; meets the product standard's requirements.
10.6 Incorporation of switching devices and components			Is the panel builder's responsibility.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			$U_i = 440 \text{ V AC}$
10.9.3 Impulse withstand voltage			4 kV
10.9.4 Testing of enclosures made of insulating material			Does not apply to metal enclosures.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility.
10.13 Mechanical function			Meets the product standard's requirements.