# **DATASHEET - IZMX40H3-P40W**



# Circuit-breaker, 3p, 4000 A, withdrawable

IZMX40H3-P40W

Catalog No. 149852

Part no.

Eaton Catalog No. RESC403W12RNMNN2MNDX



Delivery program			
Product range			Air circuit-breakers/switch-disconnectors
Product range			Open circuit-breakers
Current Range			Up to 4000 A
Protective function			Professional protection
Installation type			Withdrawable
			Cassette must be separately ordered.
			IZMX-DTP-PTM external voltage measuring module required
Construction size			IZMX40
Release system			Electronic release
Standard/Approval			IEC
Number of poles			3 pole
Degree of Protection			IP20, IP55 with protective cover, IP41 door sealing frame
			suitable for zone selectivity suitable for communication with integrated system monitor with integrated test possibility with graphic LCD color display optionally fittable by user with comprehensive accessories
Rated current = rated uninterrupted current	$I_n = I_u$	Α	4000
up to 440 V 50/60 Hz	I <sub>cu</sub>	kA	105
up to 440 V 50/60 Hz	I <sub>cs</sub>	kA	105
Overload release, min.	I <sub>r</sub>	Α	2000
Overload release, max.	I <sub>r</sub>	Α	4000
Non-delayed	$I_i = I_n \times \dots$		2 - 12, OFF
Delayed	$I_{sd} = I_r x \dots$		2 - 10

### **Technical data**

### General

General			
Standards			IEC/EN 60947
Ambient temperature			
Storage	9	°C	-25 - +70 (device with LCD-display -20 - +70)
Operating (open)		°C	-25 - +70 (device with LCD-display -20 - +70)
Mounting position			30° 30°
			30° 30°
Utilization category			В
Degree of Protection			IP20, IP55 with protective cover, IP41 door sealing frame
Direction of incoming supply			as required

#### Main conducting paths Rated current = rated uninterrupted current $I_n = I_u$ Α 4000 $I_{\rm u}$ 4000 Rated uninterrupted current at 50 °C Α 3650 Rated uninterrupted current at 60 °C $I_{\mathsf{u}}$ Α Rated uninterrupted current at 70 $^{\circ}\text{C}$ Α 75 V AC 12000 Rated impulse withstand voltage $U_{\text{imp}}$ Rated operational voltage $\text{U}_{\text{e}}$ V AC 690 Use in IT electrical power networks up to U = 440 VkA 57.6 $I_{\text{IT}}$ Overvoltage category/pollution degree 111/3 ٧ Rated insulation voltage $U_{\rm i}$ 1000 **Switching capacity** Rated short-circuit making capacity $I_{cm}$ up to 440 V 50/60 Hz $\rm I_{\rm cm}$ kΑ 231 up to 690 V 50/60 Hz kA 166 $\rm I_{\rm cm}$ Rated short-time withstand current 50/60 Hz t = 1 skΑ 85 $I_{cw}$ kA 66 t = 3 s $I_{cw}$ Rated short-circuit breaking capacity I<sub>cn</sub> $I_{cn}$ IEC/EN 60947 operating sequence $I_{cu}$ 0-t-C0 up to 240 V 50/60 Hz $\mathrm{I}_{\mathrm{cu}}$ kΑ 105 up to 440 V 50/60 Hz kA 105 $\rm I_{\rm cu}$ up to 690 V 50/60 Hz kA 75 $I_{\text{cu}}$ IEC/EN 60947 operating sequence $I_{cs}$ 0-t-C0-t-C0 up to 240 V 50/60 Hz ${\rm I}_{\rm cs}$ kΑ 105 up to 440 V 50/60 Hz kA 105 $\mathrm{I}_{\mathrm{cs}}$ up to 690 V 50/60 Hz 75 $\mathsf{I}_{\mathsf{cs}}$ kΑ Operating times Closing delay via spring release ms 35 Total opening delay via shunt release ms 22 Total opening delay via undervoltage release 37 ms Total opening delay on non-delayed short-circuit release (up to complete arc 45 ms quenching) Maximum operating frequency Operations/h 60 Heat dissipation at rated current In

Withdrawable units (switch with cassette)	١	W	880
Weight			
Withdrawable			
3-pole	k	kg	70
4-pole	k	kg	86
Cassette			
3 pole	k	kg	27

kg

35

With vertical universal connection.

## Terminal capacities

4 pole

Copper bar			
Withdrawable units			
Black	r	mm	4 x 100 x 10
			These are values used in separate switchgear. The actual values will depend on the temperature around the circuit-breaker, which is influenced by the ambient temperature, the degree of protection (IP), the mounting height, the partitions, and any external ventilation. Depending on the specific switchgear design, this may result in derating, which can then be compensated for by increasing the cross-sectional area. Temperature rise tests in the specific switchgear can provide specific and detailed information.
			Permissible continuous current for circuit-breakers operating in switchboards at various internal ambient temperatures. The switchboard's internal ambient temperature should be estimated using the calculation methods of IEC regulation.

# Design verification as per IEC/EN 61439

boolgii vormoution do por 120/211 or 100			
Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	4000
Equipment heat dissipation, current-dependent	$P_{\text{vid}}$	W	880
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	70
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

### **Technical data ETIM 6.0**

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation prot. (EC000228)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss8.1-27-37-04-09 [AJZ716010])

A V	4000
V	
•	690 - 690
kA	105
Α	2000 - 4000
Α	8000 - 40000
Α	8000 - 48000
	No
	Rail connection
	Built-in device slide-in technique (withdrawable)
	No
	No
	0
	0
	2
	Yes
	kA A A

With under voltage release	No
Number of poles	3
Position of connection for main current circuit	Back side
Type of control element	Push button
Complete device with protection unit	Yes
Motor drive integrated	No
Motor drive optional	Yes
Degree of protection (IP)	IP20