DATASHEET - DC1-342D2FN-A66N



Variable Frequency Drive, 3-/3- 400 V, 2.2 A, 0.75 kW, EMC-Filter

Powering Business Worldwide*

Part no. DC1-342D2FN-A66N Catalog No. 169476

Eaton Catalog No. DC1-342D2FN-A66N

Delivery program

| Delivery program | | | |
|---------------------------------|----------------|----|---|
| | | | This item will continue to be available for a limited time only and is being replaced by the following item: 185744, DC1-342D2FN-A66CE1 |
| Product range | | | Variable frequency drives |
| Part group reference (e.g. DIL) | | | DC1 |
| Rated operational voltage | U _e | | 400 V AC, 3-phase 480 V AC, 3-phase |
| Output voltage with $V_{\rm e}$ | U ₂ | | 400 V AC, 3-phase 480 V AC, 3-phase |
| Mains voltage (50/60Hz) | U_LN | V | 380 (-10%) - 480 (+10%) |
| Rated operational current | | | |
| At 150% overload | l _e | Α | 2.2 |
| Note | | | Rated operational current at a switching frequency of 16 kHz and an ambient air temperature of +40 $^{\circ}\text{C}$ |
| Note | | | Overload cycle for 60 s every 600 s |
| Assigned motor rating | | | |
| Note | | | for normal internally and externally ventilated 4 pole, three-phase asynchronous motors with 1500 rpm ⁻¹ at 50 Hz or 1800 min ⁻¹ at 60 Hz |
| Note | | | Overload cycle for 60 s every 600 s |
| Note | | | at 400 V, 50 Hz |
| 150 % Overload | P | kW | 0.75 |
| 150 % Overload | I _M | Α | 1.9 |
| Note | | | at 440 - 480 V, 60 Hz |
| 150 % Overload | P | HP | 1 |
| 150 % Overload | I _M | Α | 2.1 |
| Degree of Protection | | | IP66/NEMA 4X |
| Interface/field bus (built-in) | | | OP-Bus (RS485)/Modbus RTU, CANopen® |
| Fieldbus connection (optional) | | | SmartWire-DT |
| Fitted with | | | Radio interference suppression filter 7-digital display assembly |
| Frame size | | | FS1 |
| Connection to SmartWire-DT | | | with SmartWire-DT module DX-NET-SWD2 |

Technical data

General

| Standards | | | Specification for general requirements: IEC/EN 61800-2 EMC requirements: IEC/EN 61800-3 Safety requirements: IEC/EN 61800-5-1 |
|--------------------------------|-------------------|----|---|
| Certifications | | | CE, UL, cUL, RCM, UkrSEPRO, EAC |
| Production quality | | | RoHS, ISO 9001 |
| Climatic proofing | ρ_{W} | % | < 95%, average relative humidity (RH), non-condensing, non-corrosive |
| Ambient temperature | | | |
| operation (150 % overload) | θ | °C | -10 - +40 |
| Storage | θ | °C | -40 - +60 |
| Radio interference level | | | |
| Radio interference class (EMC) | | | C2, C3, depending on the motor cable length, the connected load, and ambient conditions. External radio interference suppression filters (optional) may be necessary. |
| Environment (EMC) | | | 1st and 2nd environments as per EN 61800-3 |
| maximum motor cable length | 1 | m | C2 ≤ 5 m |

| | m | Vertical |
|------------------|---|---|
| | m | 0.4000 |
| | | 0 - 1000 m above sea level Above 1000 m: 1% derating for every 100 m max. 4000 m |
| | | IP66/NEMA 4X |
| | | BGV A3 (VBG4, finger- and back-of-hand proof) |
| | | |
| | | |
| U _e | | 400 V AC, 3-phase 480 V AC, 3-phase |
| U _{LN} | V | 380 (-10%) - 480 (+10%) |
| I _{LN} | Α | 3.5 |
| | | AC supply systems with earthed center point |
| f_{LN} | Hz | 50/60 |
| f_{LN} | Hz | 48 - 62 |
| | | Maximum of one time every 30 seconds |
| | | |
| | | Frequency inverter with internal DC link and IGBT inverter |
| IL | Α | 3.3 |
| I _H | % | 175 |
| | | for 2 seconds every 20 seconds |
| U_2 | | 400 V AC, 3-phase 480 V AC, 3-phase |
| f ₂ | Hz | 0 - 50/60 (max. 500) |
| f _{PWM} | kHz | 16 adjustable 4 - 32 (audible) |
| | | U/f control Speed control with slip compensation |
| Δf | Hz | 0.1 |
| | | |
| I _e | Α | 2.2 |
| | | Rated operational current at a switching frequency of 16 kHz and an ambient air temperature of +40 °C |
| | | |
| P_V | W | 63.75 |
| η | % | 91.5 |
| I _{PE} | mA | <1 |
| | | Radio interference suppression filter 7-digital display assembly |
| | | FS1 |
| | | |
| | | for normal internally and externally ventilated 4 pole, three-phase asynchronous motors with 1500 rpm ⁻¹ at 50 Hz or 1800 min ⁻¹ at 60 Hz |
| | | Overload cycle for 60 s every 600 s |
| | | at 400 V, 50 Hz |
| Р | kW | 0.75 |
| | | at 440 - 480 V, 60 Hz |
| Р | НР | 1 |
| 1 | m | screened: 50 screened, with motor choke: 100 unscreened: 75 unscreened, with motor choke: 150 |
| S | kVA | 1.52 |
| | | 1.83 |
| • | , | |
| | | max. 30 % M _N |
| | | adjustable to 100 % |
| | ULN ILN fLN fLN fLN IL IH U2 f2 fPWM PV I IPE | ULN V ILN A ILN Hz ILN Hz IL A IH % U2 I2 I4 IPE MA PV W η % IPE MA P HP I M S kWA |

Control section

| Reference voltage | U_s | V | 10 V DC (max. 10 mA) |
|--------------------------------|-------|---|---|
| Analog inputs | | | 2, parameterizable, 0 - 10 V DC, 0/4 - 20 mA |
| Analog outputs | | | 1, parameterizable, 0 - 10 V |
| Digital inputs | | | 4, parameterizable, max. 30 V DC |
| Digital outputs | | | 1, parameterizable, 24 V DC |
| Relay outputs | | | 1, parameterizable, N/O, 6 A (250 V, AC-1) / 5 A (30 V, DC-1) |
| Interface/field bus (built-in) | | | OP-Bus (RS485)/Modbus RTU, CANopen® |

Assigned switching and protective elements

| Power Wiring | | | |
|---|---|---|-------------|
| IEC (Type B, gG), 150 % | | | FAZ-B6/3 |
| UL (Class CC or J) | A | L | 6 |
| 150 % overload (CT/I _H , at 50 °C) | | | DX-LN3-004 |
| Motor feeder | | | |
| 150 % overload (CT/I _H , at 50 °C) | | | DX-LM3-005 |
| 150 % overload (CT/I _H , at 50 °C) | | | DX-SIN3-004 |

Design verification as per IEC/EN 61439

| Design vernication as per 1EG/EN 01433 | | | |
|--|-------------------|----|--|
| Technical data for design verification | | | |
| Rated operational current for specified heat dissipation | In | Α | 2.2 |
| Heat dissipation per pole, current-dependent | P _{vid} | W | 0 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 63.75 |
| Static heat dissipation, non-current-dependent | P _{vs} | W | 0 |
| Heat dissipation capacity | P _{diss} | W | 0 |
| Operating ambient temperature max. | | °C | -10 |
| Operating ambient temperature max. | | °C | 40 |
| EC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | |
| 10.9.2 Power-frequency electric strength | | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | | Is the panel builder's responsibility. The specifications for the switchgear must observed. |
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. The specifications for the switchgear must observed. |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| | | | |

Technical data ETIM 6.0

| Low-voltage industrial components (EG000017) / Frequency converter =< 1 kV (EC00185 | | |
|---|---------------------|---|
| Electric engineering, automation, process control engineering / Electrical drive / Static | frequency converter | r / Static frequency converter = < 1 kv (ecl@ss8.1-27-02-31-01 [AKE177011]) |
| Mains voltage | V | 380 - 480 |
| Mains frequency | | 50/60 Hz |
| Number of phases input | | 3 |
| Number of phases output | | 3 |
| Max. output frequency | Hz | 500 |
| Max. output voltage | V | 400 |
| Rated output current I2N | Α | 2.2 |
| Max. output at quadratic load at rated output voltage | kW | 0.75 |
| Max. output at linear load at rated output voltage | kW | 0.75 |
| With control unit | | Yes |
| Application in industrial area permitted | | Yes |
| Application in domestic- and commercial area permitted | | Yes |
| Supporting protocol for TCP/IP | | No |
| Supporting protocol for PROFIBUS | | No |
| Supporting protocol for CAN | | Yes |
| Supporting protocol for INTERBUS | | No |
| Supporting protocol for ASI | | No |
| Supporting protocol for KNX | | No |
| Supporting protocol for MODBUS | | Yes |
| Supporting protocol for Data-Highway | | No |
| Supporting protocol for DeviceNet | | No |
| Supporting protocol for SUCONET | | No |
| | | |
| Supporting protocol for LON | | No No |
| Supporting protocol for PROFINET IO | | No |
| Supporting protocol for PROFINET CBA | | No |
| Supporting protocol for SERCOS | | No |
| Supporting protocol for Foundation Fieldbus | | No |
| Supporting protocol for EtherNet/IP | | No |
| Supporting protocol for AS-Interface Safety at Work | | No |
| Supporting protocol for DeviceNet Safety | | No |
| Supporting protocol for INTERBUS-Safety | | No |
| Supporting protocol for PROFIsafe | | No |
| Supporting protocol for SafetyBUS p | | No |
| Supporting protocol for other bus systems | | No |
| Number of HW-interfaces industrial Ethernet | | 0 |
| Number of HW-interfaces PR0FINET | | 0 |
| Number of HW-interfaces RS-232 | | 0 |
| Number of HW-interfaces RS-422 | | 0 |
| Number of HW-interfaces RS-485 | | 1 |
| Number of HW-interfaces serial TTY | | 0 |
| Number of HW-interfaces USB | | 1 |
| Number of HW-interfaces parallel | | 0 |
| Number of HW-interfaces other | | 0 |
| With optical interface | | No |
| With PC connection | | Yes |
| Integrated breaking resistance | | No |
| 4-quadrant operation possible | | No |
| Type of converter | | U converter |
| Degree of protection (IP) | | IP66 |
| Height | mm | 232 |
| Width | mm | 161 |
| Depth | mm | 184 |
| Relative symmetric net frequency tolerance | % | 10 |
| | 70 | - |

| Relative symmetric net current tolerance | % | 10 |
|--|---|----|
| | | |

Approvals

| Product Standards | UL 508C; CSA-C22.2 No. 14; IEC/EN61800-3; IEC/EN61800-5; CE marking |
|--------------------------------------|---|
| UL File No. | E172143 |
| UL Category Control No. | NMMS, NMMS7 |
| CSA File No. | UL report applies to both US and Canada |
| North America Certification | UL listed, certified by UL for use in Canada |
| Specially designed for North America | No |
| Suitable for | Branch circuits |
| Max. Voltage Rating | 3~ 480 V AC IEC: TN-S UL/CSA: "Y" (Solidly Grounded Wey) |
| Degree of Protection | IEC: IP66 |

Dimensions

