DATASHEET - PBSM-402/03-S/A-MW



Residual-current circuit breaker trip block for PLS. 40A, 2 p, 300mA, type $\mbox{S/A}$



Part no. PBSM-402/03-S/A-MW Catalog No. 167016
Alternate Catalog PBSM-402/03-S/A-MW

No.

Similar to illustration

Delivery program			
Basic function			Add-on residual current protection unit
Number of poles			2 pole
Rated current	In	Α	40
Rated short-circuit strength	I _{cn}	kA	same as connected PLS
Rated fault current	$I_{\Delta N}$	Α	0.3
Туре			Type S/A
Tripping		s	selective switch off
Product range			PBSM
Impulse withstand current			surge-proof 5 kA

Technical data

Electrica	

Liectrical			
Rated frequency	f	Hz	50
Rated current	In	Α	40
lifespan			
Electrical	Operations		≧ 4000
Mechanical	Operations		≧ 20000
Mechanical			
Mounting			DIN rail
Degree of Protection			IP20
Thickness of busbar material		mm	0.8 - 2
Climatic proofing			25-55°C/90-95% relative humidity according to IEC 60068-2

Design verification as per IEC/EN 61439

Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	40
Heat dissipation per pole, current-dependent	P _{vid}	W	0
Equipment heat dissipation, current-dependent	P _{vid}	W	13
Static heat dissipation, non-current-dependent	P_{vs}	W	0
Heat dissipation capacity	P _{diss}	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	40
			Starting at 40 °C, the max. permissible continuous current decreases by 3% for every 1 °C
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.

10.2.7 Inscriptions	Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9 Insulation properties	
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 7.0

Circuit breakers and fuses (EG000020) / Residual current circuit breaker (RCCB) (EC000003)

Electric engineering, automation, process control engineering / Electrical installation, device / Residual current protection system / Residual current circuit breaker (RCCB) (ecl@ss10.0.1-27-14-22-01 [AAB906014])

(ecl@ss10.0.1-27-14-22-01 [AAB906014])		
Number of poles		2
Rated voltage	V	230
Rated current	Α	40
Rated fault current	mA	300
Rated insulation voltage Ui	V	
Rated impulse withstand voltage Uimp	kV	
Mounting method		DIN rail
Leakage current type		A
Selective protection		Yes
Short-time delayed tripping		No
Short-circuit breaking capacity (Icw)	kA	0
Surge current capacity	kA	5
Frequency		50 Hz
Additional equipment possible		Yes
With interlocking device		
Degree of protection (IP)		IP20
Width in number of modular spacings		4
Built-in depth	mm	70
Ambient temperature during operating	°C	
Pollution degree		
Connectable conductor cross section multi-wired	mm²	
Connectable conductor cross section solid-core	mm²	

Assets (links)

Manuals

hlr-system/Bedienungs- und Montageanleitungen/180503226 (German)