### **DATASHEET - PHM50**



#### Paco fuse base DIII

Part no. PHM50 Catalog No. 1713615



### **Delivery program**

Product range			Fuse switch-disconnector
Part group reference			PHM
Number of poles			1 pole
Degree of Protection			IP20
Design			service distribution board mounting
Rated uninterrupted current	I <sub>u</sub>	Α	50
Note on rated uninterrupted current !u			Rated uninterrupted current $\mathbf{I}_{\mathbf{u}}$ is specified for max. cross-section.

## **Technical data**

#### General

		IEC/EN 60947, VDE 0660, IEC/EN 60204 Switch-disconnector according to IEC/EN 60947-3
		CE, RoHs; KEMA
θ	°C	-25 - +55
9	°C	-30 - +80
		III/3
		As required
	9	

#### Contacts

Mechanical variables			
Number of poles			1 pole
Electrical characteristics			
Rated uninterrupted current	I <sub>u</sub>	Α	50
Note on rated uninterrupted current $\boldsymbol{!}_{\boldsymbol{u}}$			Rated uninterrupted current $\mathbf{I}_{\mathbf{U}}$ is specified for max. cross-section.
Heat dissipation per pole, current-dependent	$P_{vid}$	W	5

#### **Terminal capacities**

Solid	mm <sup>2</sup>	1.5 - 16
Flexible with ferrules to DIN 46228	mm <sup>2</sup>	
flexible	mm <sup>2</sup>	1.5 - 10
Stripping length	mm	8
Tightening torque for terminal screw	Nm	3

## Design verification as per IEC/EN 61439

In	Α	0
$P_{vid}$	W	5
$P_{vid}$	W	0
$P_{vs}$	W	0
P <sub>diss</sub>	W	0
	°C	-25
	°C	50
		Meets the product standard's requirements.
		Meets the product standard's requirements.
	P <sub>vid</sub> P <sub>vid</sub> P <sub>vs</sub>	P <sub>vid</sub> W P <sub>vid</sub> W P <sub>vs</sub> W P <sub>diss</sub> W °C

10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation	Meets the product standard's requirements.
10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions	Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9 Insulation properties	
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

#### **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Fuse switch disconnector (EC001040)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Off-load switch, circuit breaker, control switch / Fuse switch disconnector (ecl@ss10.0.1-27-37-14-01 [AKF058013])

(ect@5510.0.1-27-37-14-01 [ANT000015])		
Version as main switch		No
Version as safety switch		No
Max. rated operation voltage Ue AC	V	V 400
Rated permanent current lu	Α	A 50
Rated operation power at AC-23, 400 V	kV	kW 0
Conditioned rated short-circuit current Iq	kA	kA 0
Rated short-time withstand current lcw	kA	kA 0
Suitable for fuses		Other
Number of poles		1
With error protection		No
Type of electrical connection of main circuit		Screw connection
Cable entry		Other
Equipped with connectors		Yes
Suitable for ground mounting		No
Suitable for front mounting 4-hole		No
Suitable for busbar mounting		No
Type of control element		Other
Position control element		Front side
Motor drive optional		No
Motor drive integrated		No
Version as emergency stop installation		No
Degree of protection (IP), front side		IP20

### Assets (links)

**Declaration of CE Conformity** 

00003054

**Instruction Leaflets** 

IL008051ZU2018\_05

# **Additional product information (links)**

IL008051ZU Switch-disconnector PHM with fuse		
IL008051ZU Switch-disconnector PHM with fuse	ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL008051ZU2018_05.pdf	
Technical overview cam switch, switch-disconnector	http://de.ecat.moeller.net/flip-cat/?edition=HPLTEv1&startpage=4.2	
System overview cam switch T	http://de.ecat.moeller.net/flip-cat/?edition=HPLTEv1&startpage=4.4	
System overview switch-disconnector P	http://de.ecat.moeller.net/flip-cat/?edition=HPLTEv1&startpage=4.6	
Key to part numbers Cam switch	http://de.ecat.moeller.net/flip-cat/?edition=HPLTEv1&startpage=4.8	
Key to part numbers Switch-disconnector	http://de.ecat.moeller.net/flip-cat/?edition=HPLTEv1&startpage=4.8	
Switches for ATEX	http://www.coopercrouse-hinds.eu/en/products/25-ex-safety-and-main-current-switches.html	