Cover, 3p, for cable lugs, size 3

Part no. NZM3-XKSAE

119869

EL Number 4359068

(Norway)



| General specifications | |
|--|--|
| Product name | Eaton Moeller series NZM connection type NA |
| Part no. | NZM3-XKSAE |
| EAN | 4015081177202 |
| Product Length/Depth | 108 millimetre |
| Product height | 67 millimetre |
| Product width | 71 millimetre |
| Product weight | 0.09 kilogram |
| Compliances | IEC |
| · | UL/CSA RoHS conform |
| Product Tradename | NZM |
| Product Type | Accessories |
| Product Sub Type | Connection type NA |
| Delivery program | |
| Туре | Accessory Terminal Terminal cover |
| Number of poles | Three-pole |
| Frame | NZM3 |
| Used with | NZM3, PN3, NS3 |
| Technical Data - Mechanical - Terminals | |
| Terminal capacity (aluminum conductor) | 10 mm ² - 120 mm ² (1x) 10 mm ² - 120 mm ² (2x) |
| Terminal capacity (copper conductor) | 16 mm² - 240 mm² (1x) 16 mm² - 240 mm² (2x) |
| Design verification as per IEC/EN 61439 | |
| 10.2.2 Corrosion resistance | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | Meets the product standard's requirements. |
| 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | Meets the product standard's requirements. |
| 10.2.5 Lifting | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | Meets the product standard's requirements. |
| 10.3 Degree of protection of assemblies | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | Is the panel builder's responsibility. |
| 10.9.2 Power-frequency electric strength | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility. |
| 10.10 Temperature rise | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must b observed. |
| | Is the panel builder's responsibility. The specifications for the switchgear must b |
| 10.12 Electromagnetic compatibility | observed. |

| Additional information | |
|------------------------|-------|
| Phase separator type | Other |

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Phase separation plate for power circuit breaker (EC002035)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Phase separation plate for circuit breaker (ecl@ss13-27-37-04-25 [ACN959016])

Model Other