String circuit-breaker, DC current, 2p, 30A

Powering Business Worldwide*

Part no. PKZ-S0L30 120939

EL Number 4300318

(Norway)

(Norway)	
General specifications	
Product name	Eaton Moeller® series PKZ-SOL String circuit-breaker
Part no.	PKZ-S0L30
EAN	4015081187690
Product Length/Depth	93 millimetre
Product height	76 millimetre
Product width	58 millimetre
Product weight	0.309 kilogram
Compliances	Contact Manufacturer
Certifications	TÜV-certified IEC/EN 60947-2
Product Tradename	PKZ-SOL
Product Type	String circuit-breaker
Product Sub Type	None
eatures & Functions	
Actuator type	Turn button
Design	Open
Features	Complete device with protection unit
Number of poles	Three-pole
eneral information	
Application	Open areas Utility buildings
Degree of protection	IP00
Mounting Method	DIN rail (top hat rail) mounting optional Top-hat rail fixing (according to IEC/EN 60715, 35 mm)
Overload release current setting - min	23 A
Overload release current setting - max	30 A
Product category	String circuit-breakers Switchgear for photovoltaic systems
Protection class	2
Suitable for	DIN rail (top hat rail) mounting
limatic environmental conditions	
Ambient operating temperature - min	-25 °C
Ambient operating temperature - max	60 °C
Climatic proofing	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78
erminal capacities	
Terminal capacity (flexible with ferrule)	1 x (1 - 6) mm ² , ferrule to DIN 46228 2 x (1 - 6) mm ² , ferrule to DIN 46228
Terminal capacity (solid/stranded AWG)	18 - 14
lectrical rating	
Internal resistance	7 mΩ
Rated operational current (Ie)	30 A at AC-21A
Rated operational voltage (Ue) - min	900 V
Rated operational voltage (Ue) - max	900 V
Rated uninterrupted current (Iu)	30 A
Short-circuit current	5 - 9 A, Ics, Admissible short-circuit current for solar modules
Short-circuit release	6 x le, Electromagnetic trip block
Contacts	

Number of auxiliary contacts (change-over contacts)	0
Number of auxiliary contacts (change-over contacts)	0
	0
Number of auxiliary contacts (normally open contacts)	U
Design verification	
Equipment heat dissipation, current-dependent Pvid	6.3 W
Heat dissipation capacity Pdiss	0 W
Heat dissipation per pole, current-dependent Pvid	2.1 W
Rated operational current for specified heat dissipation (In)	30 A
Static heat dissipation, non-current-dependent Pvs	0 W
10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation	Meets the product standard's requirements.
10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions	Meets the product standard's requirements.
10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation protection (EC000228)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss13-27-37-04-09 [AJZ716018])

Rated permanent current lu	А	30
Rated voltage	V	900 - 900
Rated short-circuit breaking capacity Icu at 400 V, 50 Hz	kA	0
Overload release current setting	A	23 - 30
Adjustment range short-term delayed short-circuit release	Α	0 - 0
Adjustment range undelayed short-circuit release	Α	180 - 180
Power loss	W	6.5
Device construction		Built-in device fixed built-in technique
Integrated earth fault protection		No
Type of electrical connection of main circuit		Screw connection
Suitable for DIN rail (top hat rail) mounting		Yes
DIN rail (top hat rail) mounting optional		Yes
Number of auxiliary contacts as normally closed contact		0
Number of auxiliary contacts as normally open contact		0
Number of auxiliary contacts as change-over contact		0
With switched-off indicator		No
With integrated under voltage release		No
Number of poles		3

Position of connection for main current circuit	Other
Type of control element	Turn button
Complete device with protection unit	Yes
Motor drive integrated	No
Motor drive optional	No
Degree of protection (IP)	IP00