DATASHEET - NZM3-XDKL



Rotary handle, + key lock, size 3

Part no.

No.

NZM3-XDKL Catalog No. 172538 Alternate Catalog NZM3-XDKL



Delivery program

Product range	Accessories
Accessories	Rotary handle on circuit-breaker
Standard/Approval	UL/CSA, IEC
Construction size	NZM3
Description	Makes it possible to operate the switch with a rotational movement and provides locking facilities
Function	Standard, black/grey
Protection class	IP66 UL/CSA Type 4X, Type 12
Locking facility	lockable in position 0 using cylinder lock and key withdrawable
Project planning information	Complete with rotary drive
Actuation	Rotary handle
For use with	NZM3(-4), PN3(-4), N(S)3(-4)
•• •	

Notes

circuit breaker can also be installed in a lying position 90° left/right, with the handle still in the same position.

cannot be combined with:

- remote operator
- side panel mounting
 mechan. interlock
- insulating surround

Design verification as per IEC/EN 61439

	IEC/EN	61439	design	verification
--	--------	-------	--------	--------------

10.2 Strength of materials and parts Meets the product standard's requirements. 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.3.4 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements.	
10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements.	
10.2.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. and fire due to internal electric effects Meets the product standard's requirements.	
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects	
and fire due to internal electric effects	
10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements.	
10.2.5 Lifting Does not apply, since the entire switchgear need	s to be evaluated.
10.2.6 Mechanical impact Does not apply, since the entire switchgear need	s to be evaluated.
10.2.7 Inscriptions Meets the product standard's requirements.	
10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear need	s to be evaluated.
10.4 Clearances and creepage distances Meets the product standard's requirements.	
10.5 Protection against electric shock Does not apply, since the entire switchgear need	s to be evaluated.
10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear need	s to be evaluated.
10.7 Internal electrical circuits and connections Is the panel builder's responsibility.	
10.8 Connections for external conductors Is the panel builder's responsibility.	
10.9 Insulation properties	
10.9.2 Power-frequency electric strength Is the panel builder's responsibility.	
10.9.3 Impulse withstand voltage Is the panel builder's responsibility.	
10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility.	
10.10 Temperature rise The panel builder is responsible for the temperature rise provide heat dissipation data for the devices.	ure rise calculation. Eaton will
10.11 Short-circuit rating Is the panel builder's responsibility. The specification observed.	itions for the switchgear must be
10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specification observed.	itions for the switchgear must be

The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Handle for power circuit breaker (EC000229)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Handle for switch devices (ecl@ss10.0.1-27-37-04-14 [AKF012014])		
Lockable	Yes	
Colour	Black	
Suitable for emergency stop	No	
With extension shaft	No	
Suitable for power circuit breaker	Yes	
Suitable for switch disconnector	Yes	

Dimensions

