DATASHEET - FRCMM-125/4/003



Residual current circuit breaker (RCCB), 125A, 4p, 30mA, type AC

Powering Business Worldwide

FRCMM-125/4/003 Part no. Catalog No. 187814

Delivery program

| Don'tory program | | | |
|------------------------------|-----------------|----|--|
| Basic function | | | Residual current circuit-breakers |
| Number of poles | | | 4 pole |
| Application | | | Switchgear for industrial and advanced commercial applications |
| Rated current | In | Α | 125 |
| Rated short-circuit strength | I _{cn} | kA | 10 with back-up fuse |
| Rated fault current | $I_{\Delta N}$ | Α | 0.03 |
| Туре | | | Type AC |
| Tripping | | s | non-delayed |
| Product range | | | FRCmM-125 |
| Sensitivity | | | AC current sensitive |
| Impulse withstand current | | | Partly surge-proof 250 A |
| Contact sequence | | | T |

Technical data

Built-in width

Mounting

| Electrical | | | |
|--|--------------------|------|-----------------------------|
| Types conform to | | | IEC/EN 61008 |
| Current test marks | | | As per inscription |
| Tripping | | s | non-delayed |
| Rated voltage according to IEC/EN 60947-2 | U_n | V AC | 240/415 |
| Rated frequency | f | Hz | 50 |
| Limit values of the operating voltage | | | |
| Test circuit | | V AC | 184 - 440 |
| Rated fault current | $I_{\Delta n}$ | mA | 30 |
| Sensitivity | | | AC current sensitive |
| Rated insulation voltage | Ui | V | 440 |
| Rated impulse withstand voltage | U_{imp} | kV | 4 (1.2/50µs) |
| Rated short-circuit strength | I _{cn} | kA | 10 with back-up fuse |
| Impulse withstand current | | | 250 A (8/20 μs) surge-proof |
| Max. admissible back-up fuse | | | |
| Short-circuit | gG/gL | Α | 125 |
| Overload | gG/gL | Α | 80 |
| Rated making and breaking capacity / Rated residual making and breaking capacity | $I_m/I_{\Delta m}$ | Α | 1250 |
| lifespan | | | |
| Electrical | Operations | | ≧ 4000 |
| Mechanical | Operations | | ≧ 20000 |
| Mechanical | | | |
| Standard front dimension | | mm | 45 |
| Device height | | mm | 80 |

mm

70 (4TE)

Quick attachment for DIN-rail EN 50022

| Degree of Protection | | | IP40, IP54 (with moisture-proof enclosure) |
|------------------------------|---|-----------------|---|
| Terminals top and bottom | | | Twin-purpose terminals |
| Terminal protection | | | Busbar tag shroud to BGV A3, ÖVE-EN 6 |
| Terminal cross-section | | | |
| Solid | 1 | mm ² | 1.5 - 50 2 x (1.5 - 16) |
| Stranded | ı | mm ² | 1.5 - 50 2 x (1.5 - 16) |
| Thickness of busbar material | ı | mm | 0.8 - 2 |
| Climatic proofing | | | 25-55°C/90-95% relative humidity according to IEC 60068-2 |
| Mounting position | | | As required |
| Contact position indicator | | | red / green |
| Trip indication | | | toggle-center postition |

Design verification as per IEC/EN 61439

| Technical data for design verification | | | |
|--|-------------------|----|--|
| Rated operational current for specified heat dissipation | In | Α | 125 |
| Heat dissipation per pole, current-dependent | P _{vid} | W | 0 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 22.5 |
| Static heat dissipation, non-current-dependent | P _{vs} | W | 0 |
| Heat dissipation capacity | P _{diss} | W | 0 |
| Operating ambient temperature min. | | °C | -25 |
| Operating ambient temperature max. | | °C | 60 |
| | | | Starting at 40 °C, the max. permissible continuous current decreases by 2.2% for every 1 °C |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | |
| 10.9.2 Power-frequency electric strength | | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 7.0

Circuit breakers and fuses (EG000020) / Residual current circuit breaker (RCCB) (EC000003)

| Electric engineering, automation, process control engineering / Electrical installation, device / Residual current protection system / Residual current circuit breaker (RCCB) (ecl@ss10.0.1-27-14-22-01 [AAB906014]) | | | |
|---|---|-----|----------|
| Number of poles | | | 4 |
| Rated voltage | ١ | V | 240 |
| Rated current | A | A | 125 |
| Rated fault current | r | mA | 30 |
| Rated insulation voltage Ui | ١ | V | 440 |
| Rated impulse withstand voltage Uimp | k | kV | 4 |
| Mounting method | | | DIN rail |
| Leakage current type | | | AC |
| Selective protection | | | No |
| Short-time delayed tripping | | | No |
| Short-circuit breaking capacity (Icw) | k | kA | 10 |
| Surge current capacity | k | kA | 0.25 |
| Frequency | | | 50 Hz |
| Additional equipment possible | | | Yes |
| With interlocking device | | | Yes |
| Degree of protection (IP) | | | IP20 |
| Width in number of modular spacings | | | 4 |
| Built-in depth | r | mm | 77.5 |
| Ambient temperature during operating | o | °C | -25 - 40 |
| Pollution degree | | | 2 |
| Connectable conductor cross section multi-wired | r | mm² | 1.5 - 16 |
| Connectable conductor cross section solid-core | n | mm² | 1.5 - 50 |
| | | | |

Dimensions

