Changeover switch, RMQ-Titan, With thumb-grip, momentary, 2 positions, Bezel: black



Part no. M22S-WK 216866

General specifications	
Product name	Eaton Moeller® series M22 Changeover switch
Part no.	M22S-WK
EAN	4015082168667
Product Length/Depth	46 millimetre
Product height	30 millimetre
Product width	30 millimetre
Product weight	0.013 kilogram
Compliances	CE Marked
Certifications	IEC 60947-5 UL 508 EN 60947-5 CSA Std. C22.2 No. 94-91 CSA Std. C22.2 No. 14-05 VDE UL CSA-C22.2 No. 14-05 IEC/EN 60947 CSA File No.: 012528 VDE 0660 UL Category Control No.: NKCR CSA Class No.: 3211-03 CE CSA-C22.2 No. 94-91 IEC/EN 60947-5 UL File No.: E29184 CSA
Product Tradename	M22
Product Type	Changeover switch
Product Sub Type	None
Features & Functions	
Bezel color	Black
Bezel material	Plastic
Color	Black
Design	With thumb-grip
Fitted with:	Front ring
Functions	Stay-put/spring-return function, can be changed with coding parts M22-XC-Y
General information	
Accessories	Thumb grip
Degree of protection	NEMA 4X, 13
Degree of protection (front side)	IP66
Lifespan, mechanical	100,000 Operations
Opening diameter	22.5 mm
Operating frequency	2000 Operations/h
Operating torque	0.3 N·m
Product category	RMQ-Titan
Size	Front diameter: 29.7 mm
Switching angle	40 °
Туре	Selector switch actuator
Ambient conditions, mechanical	
Mounting position	As required
Shock resistance	Mechanical, According to IEC/EN 60068-2-27 30 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms
Climatic environmental conditions	
Ambient operating temperature - min	-25 °C

Ambient storage temperature - mix Ambient storage temperature - max Climatic proximg Communication C		
Analosins starage temperature - max Climate grouting Damp beat, cyclic, to IEC 60058-2-70 Dumb beat, constant, to IEC 60058-2-70 Win SWO RIAD connections Actuator Actuator Color Actuator Indication Spring-relation Actuator of switch pastions 2 Contacts Face for positive opining - min Design verification Design perification Composition that dissipation, current-dependent Prid DW Heat dissipation capacity Plais Heat dissipation control designation (current-dependent Prid DW Rated opinition per pole, current-dependent Prid DW 10.22 Correction resistance Neets the product standard's requirements. Neets the product standard's requirements. Neets the product standard's requirements. 10.23.3 Resist of insul max to abhorate leaving by marked to product standard's requirements. 10.24.3 Neiffication of resistance of insulating materials to normal heat 10.25.5 Lifting 10.26 Mechanical impact 10.27 Exerciptions Meets the product standard's requirements. 10.28 Design or disposition of actual max to abhorate plain of the product standard's requirements. 10.25 Financiptions Meets the product standard's requirements. 10.26 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.27 International description of the control actual control of the control of	Ambient operating temperature - max	70 °C
Climate proofing Damp heat, cyclic, to IEC 5008-2-39 Damp heat, cyclic, to IEC 5008-2-39 Damp heat, cyclic, to IEC 5008-2-39 With SVID-RMQ connections Actuator Actuator of Switch positions Actuator type Actuator type Black Actuator type Actuator type Number of switch positions 2 Contacts Torce for positive opening - min Dosign verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capechy Polis OW Heat dissipation capechy Polis OW Read operational current for specified heat dissipation (In) Read operation of distinct and stability of encolosures Meets the product standard's requirements. 10.2.5 Urification of resistance and creation of the switching area reads to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchinger meets to be evaluated. Meets the product standard's requirements. 10.2 Powers frequency electric strength 10.3 Improve electric directive a	Ambient storage temperature - min	40 °C
Communication Commercian to SmartWire-DT Wish SWD-RMQ connections Ves Actuator Actuator refor Actuator refor Actuator rype Actuator rype Toggle Number of switch positions Contacts Force for positive apening - min Ossign evention Beginnen theat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss OV Heat dissipation capacity Pdiss OV Rated operational current for specified head dissipation [in] Static heat dissipation, con-current-dependent Pvid OV Rated operational current for specified head dissipation [in] OA Static heat dissipation, con-current-dependent Pvid OV Rated operational current for specified head dissipation [in] OA Static heat dissipation, con-current dependent Pvid OV Rated operational current for specified head dissipation [in] OL23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. OL23.2 Verification of thermal stability of enclosures Meets the product standard's requirements. OL23.2 Resistance in ultra-violet LIVI) rediction OL25. Ultimal OL25. Efficience of resistance of situation and heat/five by internal elect effects Meets the product standard's requirements. OL26. Hease enquire OL26. In product standard in a requirements. Meets the product standard's requirements. OL26. In province of protection of assemblies OL26. Dees not apply, since the entire exvirchgear needs to be evaluated. OL27 internal electrical circuits and connections Meets the product standard's requirements. OL28 Deep on a product standard's requirements. OL29 Power-requirements. OL29 Power-requirements. OL29 Connections for external conductors See not apply, since the entire exvirchgear needs to be evaluated. OL29 Tensor requirements. OL29 Connections for external conductors See not apply, since the entire exvirchgear needs to be evaluated. OL20 From the entire switchgear needs to be evaluated. OL20 From the entire switchgear needs to be evaluated. OL20 From the entire switchgear needs to be evaluated. OL20 From the entire switchgear needs to be evaluated. OL20 F	Ambient storage temperature - max	80 °C
Connection to SmartWire-DT Actuator color Actuator (Color Spring-return Momentary Color Spring-return Color Color Color Spring-return Color Co	Climatic proofing	
Actuator color Actuator (nection Black Actuator function Spring-return Momentary Actuator (nection Spring-return Momentary Busing verification Equipment heat dissipation, current-dependent Pvid OW Retard operational current for specified heat dissipation (nection Appendix Pvid OW Retard operational current for specified heat dissipation (Inc) OA Static heat dissipation, non-current-dependent Pvid OW Retard operational current for specified heat dissipation (Inc) OA Static heat dissipation, non-current-dependent Pvid OW Retard operational current for specified heat dissipation (Inc) 10.2.3.1 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist of incul, mat to abnormal heat/fire by internal elect effects 10.2.4 Resistance to ultra-vided (LIV) radiation 10.2.5 Lifting Open of protection of assemblies 10.3.0 Egree of protection of assemblies 10.3.0 Egree of protection of assemblies 10.3.1 Egree of protection of assemblies 10.4 Cherances and croepage distances 10.5 Protection against electric shock 10.6 Recorporation of witching devices and components 10.7 Internal electrical circuits and connections 10.8 Encorporation of witching devices and components 10.9 Foreign expression of assemblies 10.10 Temperation of expression and connections 10.10 Temperation of expression and expression of insulating material 10.10 Temperation of expression and expression of insulating material 10.10 Temperation of expression and expression for the switchgear mast be observed. 10.11 Short-circuit rating 10.12 Electromagnetic compati	Communication	
Actuator color Actuator function Actuator type Toggle Number of switch positions Contacts Force for positive opening - min Design verification Equipment heat dissipation, current dependent Pvid OW Heat dissipation apactory Pdiss Heat dissipation apactory Pdiss West dissipation per pole, current-dependent Pvid OW Heat dissipation project	Connection to SmartWire-DT	
Actuator function Spring-return Monometary Actuator type Toggle Number of switch positions 2 Contacts Fore for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid DeSign verification Equipment heat dissipation, current-dependent Pvid DeV Heat dissipation per pole, current-dependent Pvid DeV DeV Heat dissipation per pole, current-dependent Pvid DeV DeV Heat dissipation per pole, current-dependent Pvid DeV	Actuator	
Actuator type Number of switch positions Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation, nor-current-dependent Pvid Heat dissipation, nor-current dependent Pvid Heat dissipation, nor-current-dependent Pvid Heat dissipation, nor-current-dependent Pvid Heat dissipation, nor-current dependent	Actuator color	Black
Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation, current-dependent Pvid Heat dissipation, current-dependent Pvid Heat dissipation, current-dependent Pvid Reted operational current for specified heat dissipation (In) Reted dissipation per pole, current-dependent Pvid Reted operational current for specified heat dissipation (In) Reted dissipation per pole, current-dependent Pvid Reted dissipation, non-current-dependent Pvid Reted dissipation, non-current-dependent Pvid Retes dissipation, non-current-dependent Pvid Meets this product standard's requirements. Retes the product standard is requirements. Retes the product standard is requirements. Retes the product standard's requirements to be evaluated. Retes the product standard's requirements to be evaluated. Retes the product standard's requirements to be evaluated. Retes the product standard's require	Actuator function	
Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation, current-dependent Pvid Net and dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs Net and sissipation of thermal stability of enclosures Neets the product standard's requirements. Neets the product standard's requir	Actuator type	Toggle
Porce for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss OW Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs OW 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Nerification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Obes not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Incorporation of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 To reperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Number of switch positions	2
Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss 0 W Rated operational current for specified heat dissipation (In) Static heat dissipation, con-current-dependent Pvid 0 W Rated operational current for specified heat dissipation (In) 0 A Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist, of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting 10.25 Nechanical impact 10.25 Lifting 10.26 Mechanical impact 10.27 Inscriptions Meets the product standard's requirements. 10.3 Deprec of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and commections 10.8 Connections for external conductors 10.9 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.15 Internal electrical circuits and commections 10.16 Incorporation of insulating material 10.17 Internal electrical circuits and commections 10.18 the panel builder's responsibility. 10.19 Temperature rise 10.10 Temperature rise 10.11 Mont-circuit rating 10.12 Electromagnetic compatibility 10.15 He panel builder's responsibility. The specifications for the switchgear must be observed. 10.11 Mechanical function The device meets the requirements, provided the information in the instruction	Contacts	
Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss 0 W Rated operational current for specified heat dissipation (In) Static heat dissipation, con-current-dependent Pvid 0 W Rated operational current for specified heat dissipation (In) 0 A Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist, of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting 10.25 Nechanical impact 10.25 Lifting 10.26 Mechanical impact 10.27 Inscriptions Meets the product standard's requirements. 10.3 Deprec of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and commections 10.8 Connections for external conductors 10.9 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.15 Internal electrical circuits and commections 10.16 Incorporation of insulating material 10.17 Internal electrical circuits and commections 10.18 the panel builder's responsibility. 10.19 Temperature rise 10.10 Temperature rise 10.11 Mont-circuit rating 10.12 Electromagnetic compatibility 10.15 He panel builder's responsibility. The specifications for the switchgear must be observed. 10.11 Mechanical function The device meets the requirements, provided the information in the instruction	Force for positive opening - min	0 N
Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs OW 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions 10.3 Degree of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.8 Connections for external conductors 10.8 The panel builder's responsibility. 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Internal electrical circuits and connections 10.9 Internal electrical circuits and connections 10.9 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Internal electrical circuits and connections 10.9 Power-frequency electric strength 10.9 Internal electrical circuits and connections 10.1 Internal electrical circuits and connections 10.1 Internal electrical circuits and connections 10.2 Internal electrical circuits and connections 10.3 Internal electrical circuits and connections 10.4 Tesnal electric s	· · · · ·	
Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Ox Static heat dissipation, non-current-dependent Pvs OW 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Resistance to ultra-violet (UV) radiation 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.28 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.8 Connections for external conductors 10.8 Connections for external conductors 10.9 Prover-frequency electric strength 10.9 Prover-frequency electric strength 10.9 Prover-frequency electric strength 10.9 Prover-frequency electric strength 10.9 Incorporation of switching devices and components 10.9 Prover-frequency electric strength 10.9 Incorporation of switching and connections 11.9 Thermal electrical circuits and connections 12.9 Prover-frequency electric strength 13.9 The panel builder's responsibility. 14.9 The panel builder's responsibility. 15.9 The panel builder's responsibility. 16.9 The panel builder's responsibility. 17.1 The specifications for the switchgear must be observed. 18.1 The panel builder's responsibility. The specifications for the switchgear must be observed.		0 W
Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of insulating materials to normal heat 10.2.3.2 Serification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Machanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Desperature rise 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function		
Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of thermal stability of enclosures 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24.8 Resistance to ultra-violet (UV) radiation 10.25 Lifting 10.26 Mechanical impact 10.27 Inscriptions 10.30 Begree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric istrength 10.9.2 Power-frequency electric istrength 10.9.3 Impulse withstand voltage 10.9.1 Stein got enclosures made of insulating material 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
Static heat dissipation, non-current-dependent Pvs 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of thermal stability of enclosures 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting 10.26 Mechanical impact 10.27 Lifting 10.26 Mechanical impact 10.27 Inscriptions 10.30 Does not apply, since the entire switchgear needs to be evaluated. 10.40 Clearances and creepage distances 10.44 Clearances and creepage distances 10.55 Protection against electric shock 10.56 Incorporation of switching devices and components 10.57 Internal electrical circuits and connections 10.58 Incorporation of switching devices and components 10.59 Power-frequency electric strength 10.50 Supply switchstand voltage 10.50 Internal electrical circuits and connections 10.51 Internal electrical circuits and connections 10.52 Internal electrical circuits and connections 10.54 Internal electrical circuits and connections 10.55 Internal electrical circuits and connections 10.56 Internal electrical circuits and connections 10.57 Internal electrical circuits and connections 10.58 Internal electrical circuits and connections 10.59 Internal electrical circuits and connections 10.50 Internal electrical circuits and connections 10.51 Internal electrical circuits and connections 10.52 Internal electrical circuits and connections 10.53 Internal electrical circuits and connections 10.54 Internal el		
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Des not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Rechanical function 10.13 Mechanical function 10.14 Electromagnetic compatibility 10.15 Repairs and connections for the switchgear must be observed. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function		
10.2.3 1 Verification of thermal stability of enclosures 10.2.3 2 Verification of resistance of insulating materials to normal heat 10.2.3 8 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.3 Testing of enclosures made of insulating material 10.9 Internal electrical conductors 10.9 Testing of enclosures made of insulating material 10.9 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Step panel builder's responsibility. 10.12 Electromagnetic compatibility 10.13 Ended the panel builder's responsibility. 10.14 Esting of enclosures made of insulating material 10.15 Short-circuit rating 10.16 Temperature rise 10.17 Short-circuit rating 10.18 Chanical function The device meets the requirements, provided the information in the instruction		
10.2.3 Verification of resistance of insulating materials to normal heat 10.2.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Internal electrical circuits and connections 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Clearance of protection of assemblies 10.15 Internal electric strength 10.16 Internal electric strength 10.17 Internal electric strength 10.18 Connections for external conductors 10.19 Internal electric strength 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Impulse withstand voltage 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Electromagnetic compatibility 10.15 Internal electric compatibility 10.16 Internal electric compatibility 10.17 Internal electric compatibility 10.18 The device meets the requirements. 10.19 Tenperature rise 10.10 Tenperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Hechanical function 10.14 Electromagnetic compatibility 10.15 Internal builder's responsibility. The specifications for the switchgear must be observed. 10.11 The device meets the requirements, provided the information in the instruction		
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	· ·	
10.2.4 Resistance to ultra-violet (UV) radiation Please enquire Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. In Internal electrical circuits and connections Is the panel builder's responsibility. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. In It Be panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	•	
10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.2 Meets the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	·	
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction		
10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Resting of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 1s the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed.	•	
10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	·	· · · · · · · · · · · · · · · · · · ·
10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed.	10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 1s the panel builder's responsibility. 10.8 Connections for external conductors 1s the panel builder's responsibility. 10.9.2 Power-frequency electric strength 1s the panel builder's responsibility. 10.9.3 Impulse withstand voltage 1s the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 1s the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.7 Internal electrical circuits and connections 1s the panel builder's responsibility. 10.8 Connections for external conductors 1s the panel builder's responsibility. 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 1s the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 1s the panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 1s the panel builder's responsibility. Is the panel builder's responsibility. Not applicable. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 1c.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 1s the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 1s the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.10 Temperature rise	Not applicable.
observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating	
	10.12 Electromagnetic compatibility	
	10.13 Mechanical function	

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Front element for selector switch (EC000222)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for selector switches (ecl@ss13-27-37-12-13

[AKF031019])	
Number of switch positions	2
Type of control element	Toggle
Suitable for illumination	No
Colour control element	Black
Colour indicator light cap	Other
Construction type lens	Round

Hole diameter	mm	22.5
Width opening	mm	0
Height opening	mm	0
Switching function latching		No
Spring-return		Yes
With front ring		Yes
Material front ring		Plastic
Colour front ring		Black
Degree of protection (IP), front side		IP66
Degree of protection (NEMA)		4X, 13