Double actuator pushbutton, RMQ-Titan, Actuators and indicator lights non-flush, momentary, White lens, black, black, inscribed, Bezel: titanium



Part no. M22-DDL-S-X4/X5

218145

EL Number 4355671

(Norway)

(Norway)	
General specifications	
Product name	Eaton Moeller® series M22 Double actuator pushbutton
Part no.	M22-DDL-S-X4/X5
EAN	4015082181451
Product Length/Depth	30 millimetre
Product height	55 millimetre
Product width	30 millimetre
Product weight	0.015 kilogram
Certifications	CSA-C22.2 No. 94-91 CSA-C22.2 No. 14-05 UL Category Control No.: NKCR IEC/EN 60947 IEC/EN 60947-5 UL UL 508 CSA VDE 0660 CE CSA Class No.: 3211-03 CSA File No.: 012528 UL File No.: E29184 LR GL DNV
Product Tradename	M22
Product Type	Double actuator pushbutton
Product Sub Type	None
Features & Functions	
Bezel color	Titanium
Bezel material	Plastic
Design	Non-Flush Classical
Features	Labelled
Fitted with:	Front ring
Inscription	Inscribed
Lens color	White
General information	
Degree of protection	NEMA 12 IP66 NEMA 13 NEMA 3R NEMA 4X
Degree of protection (front side)	IP66 NEMA 4X
Lifespan, mechanical	200,000 Operations
Opening diameter	22.5 mm
Operating frequency	3600 Operations/h
Product category	RMQ-Titan
Size	Front dimensions: 29,7 x 54,7 mm
Suitable for	Illumination
Туре	Double actuator
Ambient conditions, mechanical	
Mounting position	As required
Shock resistance	30 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms Mechanical, According to IEC/EN 60068-2-27

Climatic environmental conditions Ambient paperating unsperature - max Ambient stargage temperature - max Ambient stargage temperature - max Ambient stargage temperature - max Climatic preparating temperature - max Climatic preparating Communication Comm		
Ambient spraging temperature - max Ambient sprage temperature - max Ambient sprage temperature - max Climatic proofing Comercian to Smart/Vire-DT Ves With SVD-RMMI connections Comercian to Smart/Vire-DT Ves With SVD-RMMI connections Comercian to Smart/Vire-DT Ves With SVD-RMMI connections Comercian to Smart/Vire-DT Actuator Actuator Actuator Actuator Actuator Black Actuator Black Actuator Spring return Momentary Contacts Comercian to Smart/Vire-DT ON Despina verification Equipment head disapation, current-dependent Pvid Head disapation, current-dependent Pvid Head disapation, current-dependent Pvid Head disapation, current-dependent Pvid Head disapation part put in Head disapation, current-dependent Pvid Head disapation practic price Equipment head disapation, current-dependent Pvid Head disapation practic price Equipment head disapation, current-dependent Pvid Head disapation practic price Equipment head disapation, current-dependent Pvid Head disapation practic price Equipment head disapation, current-dependent Pvid Head disapation practic price Equipment head disapation, current-dependent Pvid OV Grant disapation, practic price Equipment head disapation practic price Equipment head disapation, practic price	Climatic environmental conditions	
Ambient storage temperature - min Climatic proofing Communication Communication Commencion to SmartWee-DT Yes Commencion to SmartWee-DT Yes With SWD-RMD connections Yes Actuating force Actuating forc	Ambient operating temperature - min	-25 °C
Ambient storage temperature - max Climatic proofing Communication Comercion to SmartWire OT Yes Yes Non-Actuator Actuator Spring-estum Momentary Contacts Force for positive opening - min Design verification Peliparent dissipation, current-dependent Pvid Heat dissipation per pote, current-dependent Pvid Heat dissipation per pote, current-dependent Pvid Heat dissipation nor pote, current-dependent Pvid Astero process of the product standard's requirements. 10.2.3 Verification of resistance or insulating materials to normal heat 10.2.3 Verification of resistance or insulating materials to normal heat 10.2.3 Resistance to other-violet UVI rediation 10.2.5 Estima Does not apply, since the entire swotchpear needs to be evaluated. 10.2.6 Pelarances and creepage distances 10.4 Pelarances and creepage distances 10.5 Porcetion resistance Meets the product standard's requirements. 10.2.3 Verification of resistance or insulating materials to normal heat 10.2.5 Estima Does not apply, since the entire swotchpear needs to be evaluated. Meets the product standard's requirements. 10.2 Posser of papy, since the entire swotchpear needs to be evaluated. Meets the product standard's requirements. 10.2 Posser of papy, since the entire swotchpear needs to be evaluated. Meets the product standard's requirements. 10.5 Posser of papy, since the entire swotchpear needs to be evaluated. Meets the product standard's requirements. 10.6 Commentions for external conductors 10.7 Internal electrical circuits and connections 10.8 Lengances and creepage distances Meets the product standard's requirements to be ovalua	Ambient operating temperature - max	70 °C
Climatic profiling Communication Connection to SmartWine-DT Actuator Actuating force Actuator Actuating force Actuator Actuating force Actuator Contacts Force for positive opening - min Design verification Equipment heat dissipation, current dependent Pvid Market dissipation capacity Prios North Heat dissipation capacity Prios North Heat dissipation capacity Prios North Heat dissipation, corrent dependent Pvid OW Heat dissipation capacity Prios North Heat dissipation, corrent dependent Pvid OW North Heat dissipation capacity Prios North Heat dissipation, corrent dependent Pvid OW North Heat dissipation capacity Prios North Heat dissipation, corrent dependent Pvid OW North Heat dissipation capacity Prios North Heat dissipation, non-current-dependent Pvid OW North Heat dissipation (any prior), current dependent Pvid OW North Heat dissipation (any prior), current dependent Pvid North Heat dissipation (any prior), current dependent Pvid Needs the product standard's requirements. One not apply, since the entire switchger needs to be evaluated. Needs the product standard's requirements. One not apply, since the entire switchger needs to be evaluated. Needs the product standard's requirements. One not apply, since the entire switchger needs to be evaluated. Needs the product standard's requirements. One not apply, since the entire switchger needs to be evaluated. Needs the product standard's requirements. One not apply, since the entire switchger needs to be evaluated. Needs the product standard's requirements. One not apply, since t	Ambient storage temperature - min	40 °C
Damp heat, constant, to IEC 60006-2-78 Communication Connection to SmartWire-DT Actuator Actuator face Black Actuator face Actuator face Actuator face Actuator face Actuator face Actuator face Black Actuator face Actuator face Actuator face Actuator face Actuator face Actuator face Black Actuator face Actuator fac	Ambient storage temperature - max	80 °C
Connection to SmartWire-UT Actustor Actustor S N Actustor	Climatic proofing	
Actuator Actuator of roce Actuator function Design verification Compared to not dissipation, current-dependent Pvid Actuator function Actuator capacity Poiss Actuator expectify Poiss Actuator capacity Poiss Actuator resistance Actuator of resistance product actuator of requirements. Actuator capacity Poiss Actuator capacity Actuator Actuat	Communication	
Actuating force Actuator function Actuator function Actuator function Actuator function Actuator function Black Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid OW Heat dissipation capacity Pdiss UW Heat dissipation per polit, current-dependent Pvid OW Actuator current respective opening - min OW Static heat dissipation current respective function (in) Static heat dissipation current respective function (in) Ox Static heat dissipation of profit of the dissipation (in) Ox Static heat dissipation, non-current-dependent Pvid OW Heat dissipation of non-current dependent Pvid OW 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.2.3 Resistance of insulation materials to normal heat 10.2.2.3 Resistance or translation of resistance of insulation materials to normal heat 10.2.3 Insulation of thermal stability of enclosures Meets the product standard's requirements. 10.2.4 Refined or resistance of insulation materials to normal heat 10.2.5 Lifting Ones not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Ones not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Ones not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and rereppe distances Ones not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Ones not apply, since the entire switchgear needs to be evaluated. 10.6 Clearances and rereppe distances Ones not apply, since the entire switchgear needs to be evaluated. 10.6 Clearances and rereppe distances Ones not apply, since the entire switchgear needs to be evaluated. 10.6 Clearances and rereppe distances Ones not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Acetanciens for external conductors Is the pan	Connection to SmartWire-DT	
Actuator color Actuator function Contacts Force for positive opening - min Design vertification Equipment heat dissipation, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Heat dissipation, current-dependent Pvid Heat dissipation, current-dependent Pvid Heat dissipation, non-current-dependent Pvid DV Rated operational current for specified heat dissipation (in) Static heat dissipation, non-current-dependent Pvis Heat dissipation of restrained pendent Pvis Heat dissipation on thermal stability of enclosures Meets the product standard's requirements. Heat the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Heat product standard's requirements. Heat product standard's requirements. Heat product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Heat product standard's requirements. Heat product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Heat product standard's requirements. Heat product standard's requirements. Heat product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Heat product standard's requirements. Heat product standard's require	Actuator	
Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid All 22 Corrosion resistance 102.31 Verification of thermal stability of enclosures 102.32 Verification of resistance of insulating materials to normal heat 102.32 Verification of resistance of insulating materials to normal heat 102.33 Resists, of insul. mat. to abnormal heat/fire by internal elect. effects 102.44 Resistance to ultra-violet (UV) radiation 102.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.6 Mechanical impact 102.7 Inscriptions Meets the product standard's requirements. 103.0 Begree of protection of assemblies 104.0 Clearances and creepage distances 105 Protection against electric shock 106 Incorporation of switching devices and components 107 Internal electrical circuits and connections 108 Connections for external conductors 109 All Stating of enclosures made of insulating material 109 All Stating of enclosures made of insulating material 109 All stating of enclosures made of insulating material 109 All stating of enclosures made of insulating material 1010 Timperature rise 1011 Short-circuit rating Lectromagnetic compatibility Let panel builder's responsibility. Let panel builder's responsibility. The specifications for the switchgear must be observed. 1013 Mechanical function The device meets the requirements, provided the information in the instruction	Actuating force	5 N
Force for positive opening - min Design verification	Actuator color	Black
Posce for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pfiles OW Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs OW 10.22 Corrosion resistance 10.23.1 Verification of themsel stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.2 Verification of resistance of insulating materials to normal heat 10.24.3 Resistance to ultra-violet (IUV) radiation 10.25. Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.27.1 Inscriptions Meets the product standard's requirements. 10.29.2 Power of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.27.1 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.8 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.9 Protection against electric streams and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric streamy 10.9.3 Timpulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.1 Timpulse withstand voltage Is the panel builder's responsibility. 10.2 Electromagnetic compatibility Is the panel builder's responsibility. The specifications f	Actuator function	. •
Design verification Equipment heat dissipation, current-dependent Pvid 0W Heat dissipation capacity Pdiss 0W Rated operational current for specified heat dissipation (In) 0A Static heat dissipation, con-current-dependent Pvid 0W Rated operational current for specified heat dissipation (In) 0A Static heat dissipation, non-current-dependent Pvid 0W 10.22 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3.3 Resist of insul, mat to abnormal heat/Price by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Please enquire Dese not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Dese not apply, since the entire switchgear needs to be evaluated. 10.2.1 Macriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Dese not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Dese not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Dese not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Dese not apply, since the entire switchgear needs to be evaluated. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.15 Electromagnetic compatibility 10.16 Electromagnetic compatibility 10.17 Mechanical functi	Contacts	
Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss 0 W Rated operational current for specified heat dissipation (In) Static heat dissipation non-current-dependent Pvid 0 W Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.1 Inscriptions Meets the product standard's requirements. 10.3.0 Pegree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage 10.14 Short-circuit rating Step panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 The panel builder's responsibility. The specifications for the switchgear must be observed. 10.16 Electromagnetic compatibility 10.17 Internal electric actions for the switchgear must be observed. 10.18 Connections for external conductors Is the panel builder's responsibility. The specifications for the switchgear must be observed.	Force for positive opening - min	0 N
Heat dissipation capacity Pdiss Heat dissipation propole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24.4 Resistance to ultra-violet (UV) radiation 10.25.1 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.26 Mechanical impact 10.27 Inscriptions 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Internal electric strength 10.9 Internal electric strength 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Design verification	
Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of thermal stability of enclosures 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.23.8 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24.8 Resistance to ultra-violet (UV) radiation 10.25 Lifting 10.26 Mechanical impact 10.27 Inscriptions 10.28 Degree of protection of assemblies 10.24 Resistance and creepage distances 10.25 Lifting 10.26 Incorporation of assemblies 10.27 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.15 Electromagnetic compatibility 10.16 Electromagnetic compatibility 10.17 Electromagnetic compatibility 10.18 Electromagnetic compatibility 10.19 Electromagnetic compatibility 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.16 Heave meets the requirements, provided the information in the instruction	Equipment heat dissipation, current-dependent Pvid	0 W
Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of fresistance of insulating materials to normal heat 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.23.8 Resistance to ultra-violet (UV) radiation 10.24. Resistance to ultra-violet (UV) radiation 10.25. Lifting 10.26 Mechanical impact 10.27 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Impulse withstand voltage 10.9 Is the panel builder's responsibility. 10.9 Impulse withstand voltage 10.1 Thermal electric idea circuit reting 10.1 Thermal electric strength 10.2 Is the panel builder's responsibility. 10.3 Impulse withstand voltage 10.4 Is the panel builder's responsibility. 10.5 Protection agents the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and connections 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.1 Thermal electric developed in the switchgear must be observed. 10.1 Short-circuit reting 10.1 Electromagnetic compatibility 10.2 Electromagnetic compatibility 10.3 Mechanical function 10.1 Mechanical function	Heat dissipation capacity Pdiss	0 W
Static heat dissipation, non-current-dependent Pvs 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resists of insul. mat. to abnormal heat/fire by internal elect. effects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting 10.26 Mechanical impact 10.27 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Interpreture rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. 10.Weets the product standard's requirements. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Des not apply, since the entire switchgear needs to be evaluated. 10.Des	Heat dissipation per pole, current-dependent Pvid	0 W
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.3.8 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Incorporation of switching devices and components 10.17 Internal electrical circuits and connections 10.18 Lepanel builder's responsibility. 10.29 Tower-frequency electric strength 10.3 Impulse withstand voltage 10.4 Testing of enclosures made of insulating material 10.5 Is the panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Mechanical function 10.17 Mechanical function	Rated operational current for specified heat dissipation (In)	0 A
10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3.0 Begree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.4 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.9.1 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Meets the product standard's requirements. 10.16 Temperature inse 10.17 Internal electric and connections 10.18 Lepanel builder's responsibility. 10.19 Temperature rise 10.10 Temperature rise 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Temperature inse rise of insulation for the switchgear must be observed. 10.11 Mechanical function 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Temperature inse rise of insulation for the switchgear must be observed. 10.18 Mechanical function 10.19 Temperature inse rise requirements, provided the information in the instruction of the switchgear must be observed. 10.19 Mechanical function	Static heat dissipation, non-current-dependent Pvs	0 W
10.2.3 2 Verification of resistance of insulating materials to normal heat 10.2.3 3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 1 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 1 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 1 Is the device meets the requirements, provided the information in the instruction	10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation Please enquire 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed.	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 They are panel builder's responsibility. 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.4 Resistance to ultra-violet (UV) radiation	Please enquire
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact	
10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. In the specifications for the switchgear must be observed. In the device meets the requirements, provided the information in the instruction	·	
10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10 be evaluated. 11 be panel builder's responsibility. 12 Is the panel builder's responsibility. 13 Is the panel builder's responsibility. 14 Is the panel builder's responsibility. 15 Is the panel builder's responsibility. 16 Is the panel builder's responsibility. 17 Is the panel builder's responsibility. 18 Is the panel builder's responsibility. 19 Is the panel builder's responsibility. 10 Is the panel builder's responsibility.	· ·	
10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. Not applicable. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction		
Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	, ·	
10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. Is the panel builder's responsibility. Not applicable. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction		
10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Stream of external conductors 15 the panel builder's responsibility. 16 the panel builder's responsibility. 17 Is the panel builder's responsibility. 18 the panel builder's responsibility. 19 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 The device meets the requirements, provided the information in the instruction		
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. Not applicable. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		· · · · ·
10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		· · · · · · · · · · · · · · · · · · ·
10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	·	
observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	· ·	observed.
		observed.
	10.13 Mechanical function	

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Front element for push button (EC000221)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for push-button actuators (ecl@ss13-27-37-12-10 [AKF028019])

[AKI 020013])		
Colour button		Black
Number of command positions		2
Construction type lens		Oval
Hole diameter	mm	22.5
Width opening	mm	0

Height opening	m	nm	0
Type of button			Flat
Suitable for illumination			Yes
With protective cover			No
Labelled			Yes
Switching function latching			No
Spring-return			Yes
With front ring			Yes
Material front ring			Plastic
Colour front ring			Titanium
Degree of protection (IP), front side			IP66
Degree of protection (NEMA), front side			4X