DATASHEET - FAZT-B1/3



Miniature circuit breaker (MCB), 1A, 3p, B-Char, AC

Powering Business Worldwide*

Part no. FAZT-B1/3 Catalog No. 240874 Alternate Catalog FAZT-B1/3

No.

EL-Nummer 1605619

(Norway)

Similar to illustration

Delivery program

| Delivery program | | | |
|---|-----------------|----|--|
| Basic function | | | Miniature circuit-breakers |
| Number of poles | | | 3 pole |
| Tripping characteristic | | | В |
| Application | | | Switchgear for industrial and advanced commercial applications |
| Rated current | In | Α | 1 |
| Rated switching capacity acc. to IEC/EN 60947-2 | I _{cu} | kA | 25 |
| Product range | | | FAZ-T |

Technical data

Electrical

| Standards | | | IEC/EN 60947-2 |
|---|-----------------|------|----------------|
| Rated voltage according to IEC/EN 60947-2 | U_n | V AC | 415 |
| Rated switching capacity acc. to IEC/EN 60947-2 | I _{cu} | kA | 25 |
| Rated service short-circuit breaking capacity according to IEC/EN 60947-2 | I _{cs} | | 12,5 kA |
| Max operational voltage according to IEC/EN 60947-2 | | V AC | 440 |
| Rated switching capacity according to IEC/EN 60947-2 (max operational voltage) | I _{cu} | kA | 15 |
| Rated service short-circuit breaking capacity according to IEC/EN 60947-2 (max operational voltage) | I _{cs} | | 7,5 kA |
| Max operational voltage DC according to IEC/EN 60947-2 | | V DC | 60/pole |
| Rated voltage according to IEC/EN 60898-1 | U_n | V AC | 415 |
| Rated switching capacity according to IEC/EN 60898-1 | I _{cn} | kA | 15 |
| Rated service short-circuit breaking capacity according to IEC/EN 60898-1 | I _{cs} | | 7,5 kA |
| Rated insulation voltage | Ui | V | 440 |
| Rated frequency | f | Hz | 50/60 |
| Characteristic | | | B, C, D |
| Direction of incoming supply | | | as required |
| lifespan | | | |
| Electrical | Operations | | ≧ 4000 |
| Mechanical | Operations | | ≧ 10000 |
| | | | |

Mechanical

| Wechanical | | |
|------------------------------------|--------|---|
| Standard front dimension | mm | 45 |
| Enclosure height | mm | 80 |
| Mounting width per pole | mm | 17.5 |
| Mounting | | Quick attachment with 3 latch positions for top-hat rail IEC/EN 60715 |
| Degree of Protection | | IP20 |
| Terminals top and bottom | | Twin-purpose terminals |
| Terminal protection | | Finger- and back-of-hand proof according to BGV A3 and ÖVE-EN 6 |
| Terminal capacities | mm^2 | 1 - 25 |
| Tightening torque of fixing screws | N/m | max. 2.4 |
| Thickness of busbar material | mm | 0.8 (exept N 0.5 SU) |
| Mounting position | | As required |
| | | |

Design verification as per IEC/EN 61439

| Technical data for design verification | |
|--|--|
| | |

| Rated operational current for specified heat dissipation | In | Α | 1 |
|--|-------------------|----|--|
| Heat dissipation per pole, current-dependent | P _{vid} | W | 0 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 4.7 |
| Static heat dissipation, non-current-dependent | P_{vs} | W | 0 |
| Heat dissipation capacity | P _{diss} | W | 0 |
| Operating ambient temperature min. | | °C | -40 |
| Operating ambient temperature max. | | °C | 75 |
| | | | linear, per +1 °C, results in a 0.5% reduction of current carrying capacity |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| $10.2.3.3 \ Verification \ of \ resistance \ of \ insulating \ materials \ to \ abnormal \ heat \ and \ fire \ due \ to \ internal \ electric \ effects$ | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | |
| 10.9.2 Power-frequency electric strength | | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| | | | |

Technical data ETIM 7.0


Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss10.0.1-27-14-19-01 [AAB905014])


| (ecl@ss10.0.1-27-14-19-01 [AAB905014]) | | |
|--|----|------------|
| Release characteristic | | В |
| Number of poles (total) | | 3 |
| Number of protected poles | | 3 |
| Rated current | Α | A 1 |
| Rated voltage | V | V 230 |
| Rated insulation voltage Ui | V | V 440 |
| Rated impulse withstand voltage Uimp | kV | kV 4 |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V | kA | kA 15 |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V | kA | kA 15 |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V | kA | kA 25 |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V | kA | kA 25 |
| Voltage type | | AC |
| Frequency | Hz | Hz 50 - 60 |
| Current limiting class | | 3 |
| Suitable for flush-mounted installation | | No |
| | | |

| Concurrently switching N-neutral | | No |
|---|-----|----------|
| Over voltage category | | 3 |
| Pollution degree | | 2 |
| Additional equipment possible | | Yes |
| Width in number of modular spacings | | 3 |
| Built-in depth | mm | 70.5 |
| Degree of protection (IP) | | IP20 |
| Ambient temperature during operating | °C | -25 - 75 |
| Connectable conductor cross section multi-wired | mm² | 1 - 25 |
| Connectable conductor cross section solid-core | mm² | 1 - 25 |

Characteristics



Dimensions



Additional product information (links)

Temperature dependency, derating

 $https://www.eaton.com/content/dam/eaton/technical documentation/technical-data-tables/Derating\ table\ FAZ_T.pdf$